




# ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520Web: [www.aegcl.co.in](http://www.aegcl.co.in)



No. AEGCL/CGM/SLDC/T-122/SF(AERC)/19/2022/06

Date: 31/01/2022

## CORRIGENDUM-II

BID identification No :MD/AEGCL/SEM/SLDC/01/2021 Date 24/12/2021

### **CORRIGENDUM TO THE BIDDING DOCUMENTS FOR**

1. "SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF SAMAST COMPLIANT 0.2 S CLASS ABT ENERGY METERS (433 NOS.) ON EXISTING METERING PANEL FOR GSSS OF AEGCL, TO BE INSTALLED AT THE T-D INTERFACE POINTS AND THE SUPPLIED METERS ARE TO BE INTEGRATED WITH NETWORK SWITCH AND LOCAL PC FOR VIEWING & DATA DOWNLOADING IN THE 70 NOS. OF GSSS OF AEGCL."
2. "SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF 0.5S CLASS LT METERS IN GRID SUBSTATIONS OF AEGCL AND THE SUPPLIED METERS ARE TO BE INTEGRATED WITH THE LOCAL PC AVAILABLE AT SUBSTATIONS THROUGH NETWORK SWITCH."

The following provisions of the tender documents against the subject package are revised to the following extent:

1.0 Under Section Mandatory Financial Criteria (Table 2) ,Page No.10 the clause 26.1 has been modified as follows:

12.1 Table 2: Mandatory Financial Criteria

The following mentioned financial criteria is mandatory for the submission and the Participant is expected to submit the mentioned supporting documents.

S.N.	Financial Requirements	Documents Needed	Form to be filled
1	The Participant must have a positive net worth in each of the last Five (5) financial years (FY 2016-17 to FY 2020-21). Here, net worth means the sum total of the paid up capital and free reserves (excluding reserves created out or revaluation) reduced by aggregate value of accumulated losses (including debit balance in profit and loss account for current year) and intangible assets.	A certified document by a Chartered Accountant or audited balance sheet of last Five (5) financial years ending at the date of RFP opening needs to be submitted.	Form "FIN-1" with attachments
2	Minimum Average Annual Turnover (MAAT) of Participant should not be less than one hundred (100) Crores for best 3(three) financial years out of past 5(five) financial years(FY 2016-17 to FY 2020-21)	Audited balance sheet of Participant of last five (5) financial years ending at the date of RFP opening in support of above needs to be submitted.	Form "FIN-2" with attachments



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR, GUWAHATI - 781001

CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: [www.aegcl.co.in](http://www.aegcl.co.in)



3	Financial Resources/ Cash Flow: The Bidder(s) must demonstrate access to, or availability of financial resources such as liquid assets, unencumbered real assets, line of credit, and other financial means, other than any contractual advance payment to meet the <b>Cash-flow</b> requirement of Rs 1,00,00,000(1 crore only)		Form "FIN-3" with attachments
---	---	--	-------------------------------

2. Annexure-C , BOQ items, Page no: 46 has been modified as follows:

## Annexure C

### Bill of Quantities (BOQ):

The schedules of requirement in respect of 'Major Goods and Services' are listed below:  
**SUPPLY PART**

#### Field Level Infrastructure at Substation Switchyard

SN	Description	UOM	Total Qty
1	0.2s Class ABT Meter (Annexure-I)	No	433
2	0.5S CLASS LT Meters (Annexure-I)	No	70
3	Resin Cast Ring Type LT CT 0.5, 5 VA - Set of 4 CTs (200/5A or 400/5A)	set	70
4	Industrial Grade Network Switch, L2, 8/16 Port + 2 SFP Port + SFP Module, unmanaged	No	80
5	CMRI(Common Meter Reading Instrument)	No	20
6	Client PCs : Client PCs, i-3 processor, 8GB RAM, 1TB HDD (Preferred Commercial Model) with keyboard and optical mouse (minimum 21" TFT monitor) <b>with latest windows version operating system (Prof), MS office standard edition, 600VA UPS</b>	Set	69
7	Others (For any additional Hardware required for Complete installation and commissioning, tenderer to specify like <b>Fiber Optic</b>	No	LS



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520Web: [www.aegcl.co.in](http://www.aegcl.co.in)



<p><b>Distribution Panel (FODP), Armored Single Mode Fiber Optic Cable, Armored Multi Mode Fiber Optic Cable, Miscellaneous Communication Cable(CAT6/CAT5e armored), RJ45 Connector Optical Patch Cord etc.</b></p> <p><b>For connection of meter to CT, PT the following items need to be supplied: Wire ( 2.5 Sq MM) For CT &amp; PT wiring.</b></p>		
--	--	--

**Bidders may assess the quantities required for the same prior to RFQ submission.**

**\*\* Software for fulfilling performance along with required licenses for all supplied hardware as per technical specification is to be provided by the contractor**

## 3. Annexure-D: Sample format for submission of Price Bid has been modified as follows:

**PRICE SCHEDULE (To be submitted in the Part-II, 'Price bid' in sealed envelope in quadruplicate)**

Sl No	Particulars	Qty & unit	Unit Price	Unit F&I	Unit Total	Total Price	HSN code
1.	Supply of 0.2s class ABT energy meter	433 nos.					
2.	Supply of 0.5s class LT CT meters	70 nos.					
3	Supply of resin case ring CT	70 set.					
4	Industrial Ethernet Switch	69 nos.					
5	Common Meter reading Instrument	20 nos.					
6	Client PCs : Client PCs with keyboard and optical mouse (minimum 21" TFT monitor) with windows-10	69 nos.					



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520Web: [www.aegcl.co.in](http://www.aegcl.co.in)



	operating system, MS office, 600VA UPS						
7	Installation, Testing & Commissioning of 0.2s class ABT meters by replacing the old meter in the existing/new C&R panel with retrofitting works if required.	433 nos.					
8	Installation, Testing & Commissioning of 0.5s class LT energy meters with external ring CT set by replacing the old meter in the existing/new panel with retrofitting works if required.	70 nos.					
9	Installation of 69 nos. of Industrial Ethernet switch	69 nos.					
1	Networking from meter to meter & Integration of 433 nos. of ABT energy meters to network switch, Installation of BCS software at Substation PC etc and data should be available at Local PC for viewing & data downloading through BCS.	69 nos. of Substations.					



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: [www.aegcl.co.in](http://www.aegcl.co.in)



However the quantity may vary as per the actual installation. The price will be excluding GST, however the GST will be added as per the prevailing rate at the time of placing the LOA.

4.0 Under Section: Mandatory Eligibility Criteria ,Page No.10 the clause 28.3 is read as 26.3 and 28.4 is read as 26.4.

Chief General Manager  
SLDC, AEGCL, Kahilipara

Memo No. AEGCL/CGM/SLDC/T-122/SF(AERC)/19/2022/06(a)

Date: 31/01/2022

Copy to:-

The DGM,IT cell, O/o the MD, AEGCL for upload in the AEGCL's website.

Chief General Manager