



**CORRIGENDUM**

NIT NO. AEGCL/DGM /TTC/TEZ/T-20/2024/243

Dated.15.06.2024

**Name of work:**


Procurement of 33kV motorized isolators and replacement of existing 33kV manually operated isolators at 132kV Rowta GSS

- 33kV Isolator with earth switch (33kV Paneri Fdr, 33kV Mazbat Fdr, 33kV Rowta fdr): 3sets.
- 33kV Isolator without earth switch (33kV Dalgaoon Fdr:1 set)"

This is for general information that:

- Sl no. 19 Auxiliary Voltage (a) Control & Interlock of Clause no. 25.0 of the aforementioned Bid " Technical specifications of 33kV Motorized Isolators may kindly be read as 110V DC 80% to 110%
- Sl no. 26.6 of the said bid "AUXILIARY SWITCHES" may kindly be read as  
All isolators and earthing switches shall be provided with 110VDC auxiliary switches for their remote position indication on the control board and for electrical locking with other equipment. The auxiliary switch shall be provided with a minimum of 20 auxiliary contacts- 10 normally open and 10 normally closed; and 10 normally open and 10 normally closed for earth switch. Separate auxiliary switches shall be provided for isolating and earth switches. 6 additional NO and NC contact to be provided as spare in each case.

All other terms and conditions of the bid shall remain same.


  
Deputy General Manager,  
Tezpur T&T Circle, AEGCL,  
Tezpur

Memo. No. AEGCL/DGM/TTC/TEZ/T-20/2024/1685-29

Dated. 02/07/2024

Copy to:-

- The Chief General Manager (O&M), CAR, AEGCL, Bijulee Bhawan, Ghy-1, for favour of kind information.
- The General Manager, Central Assam zone, AEGCL, Nagaon for favour of kind information.
- The AGM (IT), Bijulee Bhawan, Paltan Bazar, Guwahati-1, for information and necessary action.
- The Assistant General Manager, 132/33kV Depota GSS, AEGCL for information.
- The Public Relation Officer, AEGCL, Bijulee Bhawan for information and necessary action.

  
Deputy General Manager,  
Tezpur T&T Circle