

ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3



PHONE: 0361-2739520 Web: www.aegcl.co.in

CORRIGENDUM-III

BID IDENTIFICATION NO: AEGCL/MD/Tech-795/RITES/Haflong/2023/BID
TENDER DETAILS/NAME OF WORK: Turnkey Construction of a 132kV Railway Traction Bay at 132kV Haflong GSS, AEGCL including Supply of Bay Equipment and Materials and Associated Works

With reference to the above, the following item descriptions in BOQ are amended to be read as below:

1. **Schedule No. 1**- Supply for 132kV bay at 132kV Haflong GSS (at BoQ1)

SI. No.	Item description
2	Control & Relay Panel with Automation (Simplex Type) complete with BCU, ethernet switch and all accessories as required for integration with existing SAS
2.1	For 132 kV Feeder Capable of integration into Existing SAS (SIEMENS) at Haflong GSS

2. **Schedule No. 2**- Freight & Insurance for 132kV bay at 132kV Haflong GSS (at BoQ2)

9,	SI. No.	I. No. Item description	
	2	Control & Relay Panel with Automation (Simplex Type) complete with BCU, ethernet switch and all accessories as required for integration with existing SAS	
	2.1	For 132 kV Feeder Capable of integration into Existing SAS (SIEMENS) at Haflong GSS	

The following may be noted by the bidders:

- 1. The interested bidders are requested to quote in the existing BoQ uploaded in the e-tender portal keeping in mind the aforementioned amended item descriptions. The modified descriptions (as above) shall be incorporated by AEGCL in the evaluation stage.
- 2. As per clause 3.1.6, Section-3, Volume-I of the bid document, it may be mentioned here that the integration of the newly supplied CRP to the existing Siemens make SAS at 132kV Haflong GSS, AEGCL has to be done by authorized representatives of the OEM only. Also, if the OEM of the supplied C&R Panel is different from the OEM of the existing SAS, then the integration of the supplied C&R Panel with the existing SAS has to be done by the authorized representatives of both the OEM.
- 3. The arrangement for the integration of the C&R Panel with the existing SAS of AEGCL, as desired, shall be under the contractor's scope.

All other terms and conditions of the bid document shall remain same.

Sd/-Chief General Manager (PP&D) Assam Electricity Grid Corporation Limited

Memo No: AEGCL/MD/Tech-795/RITES/Haflong/2023/12(a) Copy to:

_...

Date:02.09.2023

1. IT Cell, O/o the MD, AEGCL, for publication of the corrigendum in AEGCL's Website

Sd/-Chief General Manager (PP&D) Assam Electricity Grid Corporation Limited