Technical Specification: Industrial Air Conditioner for Control Room/Kisok

TYPE OF AIR CONDITIONER: DUCTABLE SPLIT TYPE		
Outdoor unit		
Sl.No.	**Specifications**	**Required Ratings and particulars**
1	Tonnage	3 and above
2	Rated Power Supply	1 phase, 50Hz/ 3 phase, 50 Hz
3	Compressor Type	Centrifugal/Rotary or equivalent (Note: Reciprocating compressor will not be accepted)
4	Compressor Warranty(yr)	5 and above
5	Condenser type	Air cooled
6	Make	Hitachi, Bluestar, Daikin, Voltas
Indoor unit		
Sl.No.	**Specifications**	**Required Ratings and particulars**
1	Air Flow Rate (CFM)	1200 CFM and above
2	Moisture Removal Rate(kg/hr)	5 and above
3	Rated Power Supply	1 phase, 50Hz
4	Nominal Cooling capacity (Btu/Hr)	36000 and above