



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in Email: cgm.ppd@aegcl.co.in



CORRIGENDUM-I & TIME EXTENSION-I

Bid Identification No.: AEGCL/MD/Tech-1030/CABLES/PACKAGE-B/BID
IFB No.: AEGCL/MD/Tech-1030/CABLES/2022/PKG-B/IFB, dtd 17.12.2022
NIT No.: AEGCL/MD/TECH- 1030/CABLES/2022/PKG-B/NIT, dtd 17.12.2022

Name of Work: Supply of Power & Control Cables and Related Services of 1.1 kV Class for Various Substations in Assam (Package-B)

A. The response to the query for bids identified against the above referred Bid identification; IFB & NIT nos. is noted to the following extent –

Sl. No	Tender Requirement	Query	Response from AEGCL
1	As per cl. No. 3.9.0 of section 3 of Bid document; the cable shall be wound on non-returnable steel drums of suitable size, packed and marked.	Please note there are 4 different substations in each package (A & B) for which separate lengths were mentioned and from those lengths some are way too less to be accommodated in steel drums (like 150 mtr, 205 mtr, 300 mtr). Hence please confirm whether we can offer cables with wooden drums where the required length is less than 500 mtr.	Confirmed. The Bidder may offer cables with wooden drums where the required length is less than 500 mtr.
2	As per cl. No. 3.7.10 (i) of section 3 of Bid document; Temperature index value shall be minimum 250°C at oxygen index of 21 when tested as per NES 715.	Temperature index shall be tested as per ASTM D2863, please confirm.1600 Amps for Incomer	Confirmed.
3	As per cl. No. 3.7.10 (i) of section 3 of Bid document; Flammability test	Please note testing method for Flammability test is not mentioned, it should be carried out as per IEC	Confirmed.



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in Email: cgm.ppd@aegcl.co.in



B. The bid submission deadline for bids identified against the above referred Bid identification; IFB & NIT nos. is hereby extended as follows:

Bid Submission End Date	12:00 Hrs. 09.01.2023
Bid Opening Date	14:00 Hrs. 10.01.2023

All other terms and conditions shall remain same.

**Sd/-
Chief General Manager (PP&D)
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati –1**

Memo No. AEGCL/MD/Tech-1030/CABLES/2022/28

Dated: 02.01.2023

Copy to:

1. The AGM -IT, O/o the MD, AEGCL, for publication of the notice in AEGCL's Website.

**Sd/-
Chief General Manager (PP&D)
Assam Electricity Grid Corporation Ltd.**