

ASSAM ELECTRICITY GRID CORPORATION LIMITED
Regd. Office:1st floor, Bijulee Bhawan,Paltanbazar,Guwahati-781001
CIN:U40101 AS2003SGC007238
Phone:0361-2739520/Fax:0361-2739513 web:www.aegcl.co.in



Bidding Document

For

33kV Bus Augmentation work at Khaloigaon GSS

**DEPUTY GENERAL MANAGER
TEZPUR T&T CIRCLE
AEGCL, TEZPUR-784001**

**Tender Cost: ₹ 1000.00
EMD: ₹8,000.00**

For & on behalf of the **Managing Director, AEGCL, the Deputy General Manager, Tezpur T&T Circle, AEGCL, Dhanuwa Nagar, Tezpur**, invites tenders in prescribed form, from reputed Firms/Contractors/Manufacturers with sound technical and financial capabilities for the following work. A single stage two envelope procedure (**Techno-Commercial and Price Bid**) will be adopted for this tender.

Sl. No.	Name of work	Time of completion In Days
1	33KV Bus Augmentation work at Khaloigaon GSS	60 days from date of site handover

1.0 Cost of Bidding Document:

Bidder has to pay Non-Refundable tender document cost of **Rs.1000.00 (Rupees One Thousand)** only in the form of **A/C payee Demand draft (Non-refundable)** pledged in favour of **AEGCL, BijuleeBhawan, Paltanbazar, Guwahati-1, Payable at Guwahati**.

2.0 Bidding Address:

Tender papers can be purchased on application in plain paper from the **Deputy General Manager, Tezpur T&T Circle, AEGCL, Tezpur on all working days upto 12.00 Hrs. of 23rd November, 2021**.

3.0 Validity of Bids and Bids Prices:

3.1 Bids shall remain valid for the period of 180 days after the bid submission deadline date prescribed by AEGCL. In exceptional circumstances, prior to the expiration of the bid validity period, AEGCL may request Bidders to extend the period of validity of their bids. The request and the responses shall be made in writing. If a bid security shall also be extended for a corresponding period.

3.2 Bidder may refuse the request without forfeiting its bid security. A Bidder granting the request shall not be required or permitted to modify its bid.

3.3 Bidders shall quote for the entire scope of supply and services on a "single responsibility" basis such that the total bid price covers all the Supplier's obligations mentioned in or to be reasonably inferred from the bidding document in respect of the design, manufacture, including procurement, delivery, and completion of the entire scope.

3.4 Bidders shall give a breakdown of the prices in the manner and detail called for in the Price Schedules.

4.0 Bid Security:

4.1 All bids must be accompanied by a bid security amounting to **Rs. 8,000.00** only in the form of Bank Guarantee/Demand Draft from any Nationalised Bank payable at Guwahati in favour of **AEGCL, BijuleeBhawan, Paltanbazar, Guwahati-01**.

- 4.2 If a bid security is specified, any bid not complying then his bid shall be rejected by the Employer as non-responsive.
- 4.3 The bid security of the successful Bidder shall be returned as promptly as possible once the successful Bidder has signed the Contract and furnished the required performance security.
- 4.4 The bid security of unsuccessful Bidders shall be returned as promptly as possible upon the successful Bidder's furnishing of the performance security.
- 4.5 The bid security may be forfeited:
- a) if a Bidder withdraws its bid during the period of bid validity specified by the Bidder.
 - b) if the successful Bidder fails to:
 - (i) sign the Contract with in the specified period.
 - (ii) furnish a performance security within 15 (fifteen) days' time.
- 4.6 The Bid Security of a JV shall be in the name of the JV that submits the bid. If the JV has not been legally constituted at the time of bidding, the Bid Security shall be in the names of all future partners as named in the letter of intent.
- 4.7 If a bid securing declaration is not executed in accordance with the above, AEGCL will declare the Bidder ineligible to be awarded a contract by the AEGCL for the period of time stated in the Form of Bid Securing Declaration.

5.0 Format and Signing of Bid:

- 5.1 The Bidder shall prepare one original of the Technical Bid and one original of the Price Bid comprising the Bid and clearly mark it –ORIGINAL - TECHNICAL BID and –ORIGINAL - PRICE BID.
- In addition, the Bidder shall submit three copies of the bid, in the number specified and clearly mark each of them –COPY. In the event of any discrepancy between the original and the copies, the original shall prevail.
- 5.2 The original and all copies of the Bid shall be typed or written in indelible ink and shall be signed by a person duly authorized to sign on behalf of the Bidder. This authorization shall consist of a written confirmation as specified in the Bid Document and shall be attached to the bid. The name and position held by each person signing the authorization must be typed or printed below the signature. All pages of the bid where entries or amendments have been made shall be signed or initialled by the person signing the bid.
- 5.3 A bid submitted by a JV shall be signed so as to be legally binding on all partners.
- 5.4 Any interlineations, erasures, or overwriting shall be valid only if they are signed or initialled by the person signing the bid.

6.0 Submission and Opening of Bids:

6.1 Submission, Sealing and Marking of Bids:

- 6.1.1 Bidders may submit their bids by mail or by hand. When so specified in the Bid Document, bidders shall have the option of submitting their bids electronically. Procedures for submission, sealing and marking are as follows:
- Bidders submitting bids by mail or by hand shall enclose the original and each copy of the Bid,

including alternative bids, if permitted in accordance with above, in separate sealed envelopes, duly marking the envelopes as –ORIGINAL and –COPY. These envelopes containing the original and the copies shall then be enclosed in one single envelope.

- 6.1.2 The inner and outer envelopes shall:
- (a) bear the name and address of the Bidder;
 - (b) be addressed to the Bidding Authority.
 - (c) bear the specific identification of this bidding process indicated in the Bid Document
- 6.1.3 The outer envelopes and the inner envelopes containing the Technical Bid shall bear a warning not to open before the time and date for the opening of Technical Bid.
- 6.1.4 The inner envelopes containing the Price Bid shall bear a warning not to open until advised by the AEGCL.
- 6.1.5 If all envelopes are not sealed and marked as required, the Employer will assume no responsibility for the misplacement or premature opening of the bid.

6.2 Deadline for Submission of Bids vis-à-vis Bid Opening:

- 6.2.1 Bids must be received by the AEGCL at the address and no later than **12.00 Hours (IST) of 23rd November, 2021.**
- 6.2.2 Subsequently, the bids will be opened publicly at **12.00 Hours (IST) of 24th November, 2021.**
- 6.3 AEGCL may, at its discretion, extend the deadline for the submission of bids by amending the Bidding Document, in which case all rights and obligations of the AEGCL and Bidders previously subject to the deadline shall thereafter be subject to the deadline as extended.

7.0 Eligible Bidders:

- 7.1 A Bidder may be a private entity or a government-owned entity or any combination of such entities with the intent to enter into an agreement supported by a letter of intent or under an existing agreement in the form of a joint venture, consortium, or association (JV). In the case of a JV:
- a) all partners shall be jointly and severally liable, and
 - b) the JV shall nominate a Representative who shall have the authority to conduct all business for and on behalf of any and all the partners of the JV during the bidding process and, in the event the JV is awarded the Contract, during contract execution.
- 7.2 A Bidder, and all partners constituting the Bidder, shall have Indian nationality. A Bidder shall be deemed to have the nationality of a country if the Bidder is a national or is constituted, incorporated, or registered and operates in conformity with the provisions of the laws of Republic Of India. This criterion shall also apply to the determination of the nationality of proposed subcontractors or suppliers for any part of the Contract including related services.
- 7.3 AEGCL considers a **conflict of interest** to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations, and that such conflict of interest may contribute to or constitute a prohibited practice under Anticorruption Policy of Government of India and Government Of Assam. In pursuance Anticorruption Policy's requirement that Employer as well as

bidders, suppliers, and contractors observe the highest standard of ethics. AEGCL will take appropriate actions if it determines that a conflict of interest has flawed the integrity of any procurement process.

Consequently all Bidders found to have a conflict of interest shall be disqualified. A Bidder may be considered to be in a conflict of interest with one or more parties in this bidding process if, including but not limited to:

- (a). they have controlling partners in common; or
- (b). they receive or have received any direct or indirect subsidy from any of them; or
- (c). they have the same legal representative for purposes of this bid; or
- (d). they have a relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder, or influence the decisions of the Employer regarding this bidding process; or
- (e). a Bidder participates in more than one bid in this bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all Bids in which it is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a Bidder, in more than one bid; or
- (f). a Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the plant and services that are the subject of the bid.

7.4 A firm that is under a declaration of ineligibility by the AEGCL or any Government Entity or PSU at the date of the deadline for bid submission or thereafter i.e. on or before contract signing date shall be disqualified.

7.5 Bidders shall provide such evidence of their continued eligibility satisfactory to the AEGCL, as the Employer shall reasonably request.

7.6 In case a prequalification process has been conducted prior to the bidding process, this bidding is open only to prequalified Bidders.

8.0 **Financial Capability:**

8.1 Bidder will require to submit along with the bid the audited balance sheets and other legal financial statements acceptable to AEGCL, for the last 3 (three) years to demonstrate the current soundness of the Bidders financial position and its prospective long term profitability. As a minimum, an Applicant's net worth calculated as the difference between total assets and total liabilities should be positive.

8.2 **Average Annual Turnover** : Minimum average annual turnover **INR 1,08,000.00** calculated as total certified payments received for contracts in progress or completed, within the last 3 (Three) Years.

8.3 **Financial Resources**: Bidder need to demonstrate access to, or availability of, financial resources such as liquid assets, unencumbered real assets, lines of credit, and other financial means, other than any contractual advance payments to meet:

- (1) the following cash-flow requirement, **INR 1,08,000.00** and
- (2) the overall cash flow requirements for this contract and its current works commitment.

9.0 **Experience:**

- 9.1 Experience on relevant work under contracts in the role of manufacturers, contractor, subcontractor, or management contractor for at least the last 7(Seven) years prior to the bid submission deadline.
- 9.2 Participation as manufacturer, contractor Experience having successfully completed similar works during last 7 years ending last day of the month previous to the one in which applications are invited should be either of the following:
- (a) Three (3) similar completed works costing not less **1,43,000.00**
 - (b) Two (2) similar completed works costing not less than **1,80,000.00**
 - (c) One (1) similar completed works costing not less than **2,90,000.00**
- 9.3 The Bidder who is not a manufacturer of equipment as required for in this Bid for execution of the works shall submit **an undertaking using form “ Manufacturer’s Authorisation- notarized”**
- 9.4 T Similar work implies the works related to **Supply of materials such as Single tension string with hardware fittings for twin Zebra, Single suspensionstring with hardware fitting for twin Zebras, Spacer for twin Zebra, T clamp suitable for twin zebra to single Panther, UPG Clamp for Zebra, Disc Insulator 120 KN along with erection and commissioning etc.** The Bidder must have experience of executing work of similar nature previously. The bidder must submit experience and completion certificate for scrutiny by AEGCL. Each of such project/ works should consist of completion certificate as per Clause 9.1.

10.0 Evaluation Criteria:

- 10.1 Evaluation will be done on the basis of *Bid Clause* No.7.0, Eligibility, Cl. No. 8.0, Financial Capability, Cl. No. 9.0., Experience and in accordance with the **Annexure I** to be duly filled in, signed and submitted by the bidder.
- 10.2 Price Bid of only **Responsive Techno-Commercial Bidders** will be opened.
- 10.3 **Arithmetical Error**, if observed while in Price Bid evaluation, same will only be corrected.
- 10.4 **Any post bid correction request will NOT BE ENTERTAINED.**
- 10.5 **Price Bid Envelope of the Non-responsive Techno Commercial Bidders will be returned** to the respective bidders against submission of a written request by the bidder.
- 10.6 **PRICE BID EVALUATION PROCESS:**
- A. Identification:
The following methodology will be practised for identification and treatment of the Abnormally Low Bids (ALB) in this tender process of AEGCL:
 - (i) Absolute Approach is to be considered when there is fewer than five substantially responsive bidders and if the bid price is 20% or more below AEGCL’s cost estimate then AEGCL’s tender evaluation committee should clarify the Bid price with the bidder to determine whether the Bid is Abnormally low.
 - (ii) Relative approach is to be considered when there are at least 5(five) nos. of substantially responsive bids and the lowest bid price is 20% or more below AEGCL’s cost estimate. In this approach, first the Average bid price is determined and then by deducting the standard deviation from the Average bid price, potentially ALB may be determined.
 - B. In case of an ALB, the tender evaluation committee/appropriate authority of the respective tenders shall undertake the following three stage review process which is as below:
 - (i) To identify ALB as per the steps mentioned in SI no. 5.A.(i) and 5.A.(ii) Whichever is applicable.

(ii) To seek and analyse the clarifications from the abnormally low Bidder in terms of resource inputs and pricing, including overheads, contingencies and profit margins. In that respect, the committee may refer to guideline of World Bank, AIIB, ADB etc. prescribed for ALB.

(iii) To decide whether to accept or reject the bid.

(iv) On acceptance of the bid, whether Additional Performance Security is to imposed on the bidder supplemented by adequate justification.

C. In case of acceptance of ALB with Additional Performance Security:

(i) If any abnormally low bid is accepted under point 5.B.(iii) with additional performance security, it is to be noted that the total performance security should not exceed 20% of the total contract value.

(ii) The additional performance security shall be treated as part of the original performance security and shall be valid for a period similar to that applicable for defect liability period of the contract.

(iii) Non submission of the additional performance security shall constitute sufficient ground for rejection of the bid and similar assessment shall then be initiated for next ranked bidder if that bidder is also identified as ALB.

11.0 Late Bid:

11.1 Any bid submitted **after the due date and time** will be rejected without any prejudice.

11.2 AEGCL will not be responsible for any Postal and/or Courier Delay in delivering the bid. The same received after the scheduled closing date and time will be rejected without any prejudice.

11.3 Bidding through EMAIL WILL NOT BE ACCEPTED.

12.0 Clarification:

12.1 A prospective Bidder requiring any clarification of the Bidding Document shall contact the AEGCL in writing at the AEGCL's address indicated in the BDS or raise his enquiries prior to 7 (seven) days of closing of the bid. The Employer will respond to any request for clarification, provided that such request is received no later than seven (7) days prior to the deadline for submission of bids. The AEGCL's response shall be in writing with copies to all Bidders who have acquired the Bidding Document including a description of the inquiry but without identifying its source. Should AEGCL deem it necessary to amend the Bidding Document as a result of a request for clarification, it shall do so.

12.2 The Bidder is advised to visit and examine the site where the work is to be Carried out and its surroundings and obtain for itself on its own responsibility all information that may be necessary for preparing the bid and entering into a contract for the provision of plant and services. The costs of visiting the site shall be at the Bidder's own expense.

12.3 The Bidder and any of its personnel or agents will be granted permission by the Employer to enter upon its premises and lands for the purpose of such visit, but only upon the express condition that the Bidder, its personnel, and agents will release and indemnify the Employer and its personnel and agents from and against all liability in respect thereof, and will be responsible for death or personal injury, loss of or damage to property, and any other loss, damage, costs, and expenses incurred as a result of the inspection.

12.4 The Bidder's designated representative is invited to attend a pre-bid meeting, if provided for in the BDS. The purpose of the meeting will be to clarify issues and to answer questions on any matter that may be raised at that stage.

12.5 The Bidder is requested, as far as possible, to submit any questions in writing, to reach the AEGCL not

later than one week before the pre-bid meeting if there is provision of Pre Bid Meeting.

12.6 Minutes of the pre-bid meeting, including the text of the questions raised, without identifying the source, and the responses given, together with any responses prepared after the meeting, will be transmitted promptly to all Bidders who have acquired the Bidding. Any modification to the Bidding Document that may become necessary as a result of the pre-bid meeting shall be made by AEGCL exclusively through the issue of an Addendum but not through the minutes of the pre-bid meeting.

12.7 Nonattendance at the pre-bid meeting will not be a cause for disqualification of a Bidder.

13.0 Amendment of Bidding Document:

13.1 At any time prior to the deadline for submission of bids, the Employer may amend the Bidding Document by issuing addenda.

13.2 Any addendum issued shall be part of the Bidding Document and shall be communicated in writing to all who have obtained the Bidding Document from AEGCL.

13.3 To give prospective Bidders reasonable time in which to take an addendum into account in preparing their bids, AEGCL may, at its discretion, extend the deadline for the submission of bids.

14.0 Preparation of Bids by the Bidders:

14.1 **Cost of bidding:** The Bidder shall bear all costs associated with the preparation and submission of its Bid, and AEGCL shall not be responsible or liable for those costs, regardless of the conduct or outcome of the bidding process.

14.2 **Language of Bid:** The Bid, as well as all correspondence and documents relating to the bid exchanged by the Bidder and AEGCL, shall be written in the English language.

14.3 Bid Prices and Discounts:

14.3.1 Unless otherwise specified in the Bid Document and/or AEGCL's Requirements, bidders shall quote for the entire plant and services on a —single responsibility basis such that the total bid price covers all the Contractor's obligations mentioned in or to be reasonably inferred from the bidding document in respect of the including procurement and subcontracting (if any), delivery, construction, installation and completion of the Work. This includes all requirements under the Contractor's responsibilities for completing the work and where so required by the bidding document, the acquisition of all permits, approvals and licenses, etc.; the operation, maintenance and training services and such other items and services as may be specified in the Bidding Document, all in accordance with the requirements of the General Conditions. Items against which no price is entered by the Bidder will not be paid for by the Employer when executed and shall be deemed to be covered by the prices for other items.

14.3.2 Bidders are required to quote the price for the commercial, contractual and technical obligations outlined in the bidding document. If a Bidder wishes to make a deviation, such deviation shall be listed. The Bidder shall also provide the additional price if any, for withdrawal of the deviation.

14.3.3 Bidders shall give a breakdown of the prices in the manner and detail called for in the Price Schedules. Where no different Price Schedules are included in the Bidding Document, bidders shall present their prices in the following manner:

(a) Separate numbered Schedules shall be used for each of the following elements.

(i) The total amount from each Schedule shall be summarized in a Grand Summary giving the total bid price(s) to be considered.

- 14.3.4 The price of the work shall be quoted as the Base Price or EXW Price
- 14.3.5 Sales Tax, GST, all other taxes (as applicable) payable on the work should be indicated separately. In case of failure to indicate so AEGCL will consider such taxes are included in the Offered Price.
- 14.3.6 Whenever forest produces like sand, stone, timbers etc are used in the work the contractor have to furnish documentary proof that requisite royalty on such produces has been paid to the concerned Department.
- 14.3.7 When the work being "work contract" which is one and individual and which involves no separate contract for the sale of materials, the contractor shall have not be entitled to get any VAT and or any other taxes, levies reimbursed from the AEGCL for the supply of the materials.
- 14.3.8 Taxes like work contract, income tax, GST etc. which need to be deducted at source as per the prevailing law of the land, will be deducted at source.
- 14.3.9 The Prices shall be FIXED and FIRM:** The Bided Price should on Fixed Price basis, prices quoted by the Bidder shall be fixed during the Bidder's performance of the contract and not subject to variation on any account. A bid submitted with an adjustable price quotation will be treated as non-responsive and rejected.

15.0 Additional Requirements:

- 15.1 Bidders(s) knowledge from actual personal investigation of the resources of the region or District (S) in which he/they offers the work.
- 15.2 Detailed list of tools, plants, equipment's and machinery available with the tenderer along with their value (A copy of approved assessor's certificate to be enclosed or affidavit), if applicable.
- 15.3 Name, qualifications of the technical supervisors and staff under the employment of the tenderer and organization on hand and proposed to be engaged for the subject work (Authenticated by a Chartered Accountant or sworn through affidavit), if applicable.
- 15.4 In case the tenderer is a partnership Firm, the work experience, solvency and turn over shall be in the name of partnership Firm only.
- 15.5 Copy of Contract labour license.
- 15.6 The Bidder shall furnish copy of their PAN Card. The card must be in the name of firm, in case the tenderer is a partnership Firm.
- 15.7 GST registration No. and valid labour license.
- 15.8 Registered Power of attorney, if any.
- 15.9 Audited balance sheet and IT return for last three (3) years.

15.10 The contractor must possess a valid Electrical License of 132 kV and above issued by the competent authority.

16.0 Negotiation with successful bidder:

The AEGCL reserve the right to hold negotiations with lowest who should be lowest, valid, eligible and technically acceptable tenderer considered for award of contract directly if the rates were not unreasonably high.

17.0 Scope

17.1 The major works included in the scope of this bids are listed below:

- a) Supply of materials as per **Price Schedule**.
- b) Dismantling of existing bus and restringing of the bus with new ACSR Zebra , Clamps & Connector and associated works.

17.2 It is not the intent to specify completely herein all details of design and construction of the equipment/materials and accessories. However, the equipment/material and accessories shall conform in all respects to the relevant IS/IEC standards and be capable of performing in continuous operation up to the bidder's guarantees in a manner acceptable to the Employer. The Employer shall be entitled to reject any work or material, which in his judgement is not in full accordance therewith.

17.3 Whether called for specifically or not, all materials, accessories and services required for the completion of the work are deemed to be considered as a part of the Bidder's scope, unless and until mentioned very clearly as excluded.

17.4 The various items of works are described very briefly in the schedule of Bid Form, Price Schedules. The various items as defined in this schedules shall be read in conjunction with the corresponding section in the technical specifications including amendments and additions if any.

17.5 The Bidder's rates shall be based on the description of activities in the schedule as well as specifications detailed in Technical Specifications.

17.6 The Bill of Quantities is furnished in **Price schedule**. Bidders are requested to note the following points:

- a) The items mentioned in the Price schedule shall only be used while preparing the Price Schedules. If any items which is not specifically mentioned in the Price schedule but required to complete the works as per scope & specification shall be deemed to be included in any of the items of the Price Schedule
- b) The quantities in price schedule are for bidding purpose and for bid comparison purpose only. Quantities may vary to the extent of (+) 15 % to (-) 15% in terms of total Contract Price.

17.7 The entire supply shall be completed within the stipulated time. However, for the erection part the entire job is based on the subject to availability of the shutdown. The process of part payment is entirely as per the bid clause no 34.

18.0 Contractor to inform himself fully

The Contractor should ensure that he has examined the General Conditions, qualifying criteria, Specifications and Schedules and has satisfied himself as to all the conditions and circumstances affecting the contract price and fixed his price according to his own views on these matters and acknowledge that no additional allowances except as otherwise provided therein will be levied.

The Employer shall not be responsible for any misunderstanding or incorrect information obtained by the Contractor other than information given to the Contractor in writing by the Purchaser

19.0 Conformity with Indian Electricity rules & other local regulations:

19.1 The Contractor shall note that all substation works shall comply with the latest provisions of Indian Electricity Rules and with any other regulations. Local authorities concerned in the administration of the rules and regulation relating to such works shall be consulted, if necessary, in regard to the rules and regulations that may be applicable.

19.2 The materials covered by this specification shall, unless otherwise stated be designed, constructed and tested in accordance with the latest revisions of relevant Indian Standards and shall conform to the regulations of local statutory authorities.

19.3 The Contractor shall also comply with the Minimum Wages Act 1948 and the payment of Wages Act (both. Of the Government of India and State of Assam) and the rules made there under in respect of any employee or workman employed or engaged by him or his Sub-Contractor.

19.4 All registration and statutory inspection fees, if any, in respect of his work pursuant to this Contract shall be to the account of the Contractor. However, any registration, statutory inspection fees lawfully payable under the provisions of the statutory laws and its amendments from time to time during erection in respect of the Substation Works, ultimately to be owned by the Employer, shall be to the account of the Employer. Should any such inspection or registration need to be re-arranged due to the fault of the Contractor or his Sub-Contractor, the additional fees to such inspection and/or registration shall be borne by the Contractor.

19.5 In case of any conflict between the standards and this specification, this specification shall govern.

20.0 Type Test Reports

20.1 He product must be type tested at CPRI or NABL accredited laboratory for critical performance at the time of bid submission. Bidder must submit full type test reports for the offered products alongwith the techno commercial bid.

Materials, which have never been tested for critical performance, shall not be accepted. In such cases, a promise or agreement by a bidder to have the equipment tested after award of a contract is not acceptable.

20.2 All Bids must be accompanied by the Type Test Certificates of materials offered (refer Clause 21.5 below). Such type test certificates shall be acceptable only if:-

a) Tests are conducted in an independent and well known testing laboratory, or

c) Tests are conducted in manufacturer's own laboratory. In this case (i) the laboratory must have ISO 9000 (or its equivalent) series certification; and (ii) tests have been witnessed by technically qualified representatives of earlier clients or purchaser.

20.3 *Test reports to be acceptable must be related directly to the materials offered. Test reports for higher class of equipment are acceptable with commitment to perform the type tests free of any charge on the particular equipment(s) after the award of contract.*

20.4 Type Test Reports older than five (5) years on the date of Technical bid opening shall not be accepted.

20.5 Full Type Test Reports of at least the following equipment must be submitted by the successful bidder:-

1. Clamp & Connectors
2. Hardware fitting

21.0 Inspection & Inspection certificate:

21.1 AEGCL representatives shall have full facilities for unrestricted inspection of the raw materials and works.

21.2 The acceptance of any quantity of material shall in no way relieve the contractor of his responsibility for meeting all the requirements of the specification and shall not prevent subsequent rejection, if such material are later found to be defective.

21.3 Any item specification if not available in this document, contractor shall supply and execute the items meeting the relevant IS specification with the approval of the purchaser.

22.0 Employer Supervision

22.1 The scope of the duties of the Employer, pursuant to the contract, will include but not be limited to the following.

- a) Witness or authorize his representative to witness works at site.
- b) Inspect, accept or reject any material and work under the Contract.
- c) Issue certificate of acceptance and/or progressive payment and final payment certificate.
- d) Review and suggest modification and improvement in completion schedules from time to time.
- e) Issue completion certificate.

23.0 SPECIFICATIONS FOR HARDWARE FITTINGS, SPACER AND CLAMPS

23.1 General

- a) The Contractor shall supply disc insulators for suspension and tension strings as required complete with all necessary hardware and accessories, including fittings for fixing insulators to steel structures as required and clamps.
- b) The porcelain shall be sound, free from defects, thoroughly vitrified and smoothly glazed.
- c) Unless otherwise specified, the glaze shall be brown colour. The glaze shall cover all the porcelain parts of the insulators except those areas which serve as support during firing or are left unglazed for purpose of assembly.
- d) The design of the insulator shall be such that stress due to expansion and contraction in any part of the insulator shall not lead to deterioration. The porcelain shall not be engaged directly with hard metal.

- e) Cement use in the construction of insulator shall not cause fracture by expansion or loosening by contraction and proper care shall be taken to locate the individual parts correctly during cementing. The cement shall not give rise to chemical reaction with metal fitting and its thickness shall be as uniform as possible.
- f) Pins and caps shall be made of drop forged steel, duly hot dip galvanized as per IS 2629. These shall not be made by jointing, welding, shrink fitting or any other process.
- g) Security clips/split pins shall be made of good quality of stainless steel.
- h) Suspension and tension insulators shall be wet process porcelain with ball and socket connection. Insulators shall be interchangeable and shall be suitable for forming either suspension or tension strings.
- i) Post type insulators shall be of long rod type or solid core type and preferably of single piece type for all voltage classes. These shall be complete with necessary fittings to hold Aluminium tubes or ACSR conductor as required.
- j) The items of hardware and fittings shall make complete assemblies which are necessary for their satisfactory performance. Such parts shall be deemed to be within the scope of this specification.

23.2 Parameters for Disc Insulator Strings

- a. Standard specification and tests shall be as per IS:71-1991
- b. IS:2486(Part I-1993 Part-II 1989 Part III 1991) Specification for insulator fittings for overhead tower lines with a nominal voltage greater than 1000 Volt. general requirements and tests, dimensional requirements, locking devices.
- c. The porcelain shall be sound and thoroughly vitrified. The design of the insulators shall be such that stress due to expansion and contraction in any part of the insulator shall not lead to deterioration.
Cement used in the construction of the insulator shall not cause fracture by expansion or loosening by contraction. The cement shall not give rise to chemical reaction with metal fittings. Insulators shall be interchangeable and shall be suitable for forming either tension or suspension strings.
- d. Insulators shall have none of the following defects:
 1. Ball pin shake
 2. Cementing defects near the pin like small blue holes, small hair cracks, lumps etc.
 3. Sand fall ferro particles defects on the surface of the insulators.
 4. Shell eccentricity.

Parameters	120KN
Highest system voltage(rms)	12Kv
Type	Ball and socket
Colour	Brown
Surface	Glazed
Locking device	W or R type security clip of stainless steel
Size of disc	255x145MM/280x145MM
Size of disc	16 or 20mm
Creepage distance (min)	320mm
Electro Mechanical strength	120KN

Power frequency with stand test voltage Dry	75kV
Wet	45kV
Minimum Dry impulse withstand voltage (+/- wave)	125kV peak
Puncture voltage	1.3X actual dry flash over voltage

23.3

Suspension and Tension Clamps

1. SUSPENSION CLAMPS

- a. Standard Specification and tests as per IS 2486(Part 1,2,3,4)
- b. Breaking strength – 120KN
- c. Slip strength shall be greater than 95% of UTS of the conductor
- d. All ferrous parts shall be hot dip galvanized as per IS 2629. Small fittings like spring washers, nuts etc. may be electrogalvanized
- e. For galvanizing, zinc conforming to Grade Zn98 of IS: 209. , 1992 shall be used
- f. General Tolerance +/- 3%
- g. Clamp materials –aluminium alloy(high strength)
- h. Yoke plate Mild steel HDG and breaking strength 230KN
- i. Stainless steel R clip shall be provided with socket.

2. TENSION CLAMP

- j. Standard Specification and tests as per IS 2486(Part 1,2,3,4)
- k. Breaking strength – 120KN
- l. Slip strength shall be greater than 95% of UTS of the conductor
- m. All ferrous parts shall be hot dip galvanized as per IS 2629. Small fittings like spring washers, nuts etc. may be electrogalvanized
- n. For galvanizing, zinc conforming to Grade Zn98 of IS: 209. , 1992 shall be used
- o. General Tolerance +/- 3%
- p. Clamp materials –aluminium alloy(high strength)
- q. Yoke plate Mild steel HDG and breaking strength 230KN
- r. Stainless steel R clip shall be provided with socket.

23.4

T Clamp, Isolator clamp and spacer

1. Standard specification and tests shall be as per IS:5561
2. For connecting ACSR conductor aluminium alloy casting conforming to designation A6 of IS617
3. Bolts, nuts and washers shall be made of mild steel and hot dip galvanized as per IS 2629. Small fittings like spring washers , nuts etc. may be electrogalvanized.
4. The quality of HDG ferrous components shall be determined by the test given in IS: 2633 and shall satisfy the requirement of that standard.
5. The rated short time current shall be one of the standard values laid down in Indian Standards for the associated circuit breakers , switches, disconnectors etc.
6. Current carrying capacity same as conductor full current rating . For two different conductors, conductor with smaller rating shall be considered.
7. No part of a clamp shall be less than 15mm thick.
8. All sharp edges and corners shall be blurred and rounded off.
9. For bimetallic connectors, copper alloy liner of minimum thickness of 2mm shall be cast integral

- with aluminium body.
10. From outermost hole edge to nearest edge of any clamps and connectors the distance shall not be less than 10 mm.

24.0 Service Conditions:

The materials supplied shall be suitable for operation under the following climatic and other conditions:

- a) Peak ambient day temperature in still air: 45 °C
- b) Minimum night temperatures : 0 °C
- c) Ground temperatures: 40 °C
- d) Reference ambient day temperature : 45 °C
- e) Relative Humidity
 - i). Maximum : 100 %
 - ii). Minimum : 10 %
- f) Altitude : Below 1000 M above MSL
- g) Maximum wind pressure : As per IS: 802
- h) Seismic Intensity: ZONE-V as per IS 1893.

25.0 Guaranteed Technical Particulars:

This specification covers the minimum requirements for the design, engineering, manufacturing, inspection, testing and supply of Single tension string with all Hardware fittings for twin Zebra without turn buckle bolted type, Single Suspension String with all Hardware Fittings for Twin Zebra, T Clamp suitable for ACSR Zebra to Panther, T Clamp suitable for Twin Zebra to Single Panther, spacer clamp for twin zebra, 33kV Isolator Twin Pad Clamp for ACSR Zebra etc. In addition to concurrence to this specification following consideration to be taken:

Compliance with applicable IS codes & standards as well as any statutory regulation in existence for a specific item.

The Guaranteed Technical Particulars of the materials shall be furnished by the Bidders with the Technical Bid. The Bidder shall also furnish any other information's as in their opinion is needed to give full description and details to judge the item(s) offered by them.

The data furnished in Guaranteed Technical Particulars should be the minimum or maximum value (as per the requirement of the specification) required. A Bidder may guarantee a value more stringent than the specification requirement. However, for testing purpose or from performance point of view, the material shall be considered performed successfully if it achieves the minimum/maximum value required as per the technical specification. No preference what so ever shall be given to the bidder offering better/more stringent values than those required as per specification except were stated otherwise.

Packing:

All the materials shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at Site till the time of erection. The Supplier shall be responsible for any loss or damage during transportation, handling and storage due to improper packing.

The Supplier shall include and provide for securely protecting and packing the materials so as to avoid loss or damage during transport by air, sea, rail and road.

All packing shall allow for easy removal and checking at site. Wherever necessary, proper arrangement for

attaching slings for lifting shall be provided. All packages shall be clearly marked for with signs showing 'up' and 'down' on the sides of boxes, and handling and unpacking instructions as considered necessary. Special precaution shall be taken to prevent rusting of steel and iron parts during transit by sea.

The cases containing easily damageable material shall be very carefully packed and marked with appropriate caution symbols, i.e. fragile, handle with care, use no hook etc. wherever applicable.

Each package shall be legibly marked by the-Supplier at his expenses showing the details such as description and quantity of contents, the name of the consignee and address, the gross and net weights of the package, the name of the Supplier etc.

Materials handling and storage:

(a) All the supplies under the Contract as well as Employer supplied items (if any) arriving at site shall be promptly received, unloaded and transported and stored in the stores by the Contractor.

(b) Contractor shall be responsible for examining all the shipment and notify the Employer immediately of any damage, shortage, discrepancy etc. for the purpose of Employer's information only. The Contractor shall submit to the Employer every week a report detailing all the receipts during the week. However, the Contractor shall be solely responsible for any shortages or damages in transit, handling and/or in storage and erection at site. Any demurrage, and other such charges claimed by the transporters, railways etc., shall be to the account of the Contractor.

(c) The Contractor shall maintain an accurate and exhaustive record-detailing out the list of all items received by him for the purpose of erection and keep such record open for the inspection of the Employer.

(d) All items shall be handled very carefully to prevent any damage or loss. The materials stored shall be properly protected to prevent damage. The materials from the store shall be moved to the actual location at the appropriate time to avoid damage of such materials at Site.

(e) All the materials stored in the open or dusty location must be covered with suitable weatherproof and flameproof covering material wherever applicable.

(f) The Contractor shall be responsible for making suitable indoor storage facilities, to store all items/materials, which require indoor storage.

(g) The Contractor shall have total responsibility for all equipment and materials in his custody, stored, loose, semi-assembled and/or erected by him at site. The contractor shall make suitable security arrangements including employment of security personnel to ensure the protection of all materials, equipment and works from theft, fire, pilferage and any other damages and loss.

(h) The Employer will verify the storage facilities arranged by the contractor and despatch clearance will be provided only after Employer is satisfied.

26.0 Scope of Work:

- a) Supply of materials as per **Price Schedule**.
- b) Dismantling & Restrunging of the existing 33KV Bus at Khaloigaon GSS
- c) Carriage of conductor from TSD-II, Samaguri GSS to 132 KV Khaloigaon GSS

27.0 Contract Agreement:

27.1 An agreement shall have to be drawn on non-judicial stamp of appropriate value with the Department by the selected Contractor in AEGCL's General Conditions of Supply and Erection 2009 of contract within 15 (fifteen) days from the date of issue of the LOI/Work Order.

27.2 Wherever there is any variation in between the conditions of the AEGCL's General Conditions of Supply and Erection 2009 and the above terms & conditions, this bid conditions will supersede the conditions of the AEGCL's General Conditions of Supply and Erection 2009.

28.0 Liquidated Damage:

28.1 The date of completion of work shall be deemed to be the essence of the contract and shall not be completed no later than the date specified in the contract. In case of failure to complete the work within the stipulated period AEGCL shall be entitled to:

28.2 Recover an amount at the rate of 1% (One percent) of the Contract Price per week or part thereof of delay, subject to maximum of 10% (Ten percent) of the contract price as liquidated damage to AEGCL. However, the payment of liquidated damages shall not in any way relieve the Contractor from any of its obligations to complete the works or from any other obligations and liabilities of the Contractor under the Contract.

28.3 To complete the balance work giving notice to the Contractor/Firm and to recover any extra expenditure incurred thereby for having to complete the work at a higher price at the risk and responsibility of the Contractor/Firm.

28.4 Contractual failure:- Refer clause No.27.1 of AEGCL's General Conditions of supply and erection 2009.

29 PERT Chart and/or BAR Chart:

29.1 The successful bidder within 10 (ten) days before the contract is awarded will make out a detailed PERT Chart covering all activities along with detailed program chart on accepted scheme indicating various stages of execution, method of execution and completion of work in different stages keeping the period of completion in view and submit the same to the Engineer for the consideration and approval.

30.0 Insurance:

The bidder shall arrange for any pay/cost of personnel accident insurance, medical treatment etc. in respect of their employees assigned to the works for all time and shall govern by Law of land.

31.0 Warranty:

31.1 The Supplier/Manufacturer warrants that all the Goods are new, unused, and of the most recent or current models, and that they incorporate all recent improvements in design and materials, unless provided otherwise in the Contract.

31.2 The Supplier/Manufacturer further warrants that the Goods shall be free from defects arising from any act or omission of the Supplier or arising from design, materials, and workmanship, under normal use in the conditions prevailing in the country of final destination.

31.3 If during the Period Warranty any defect is found, the Purchaser shall give Notice to the Supplier/Manufacture stating the nature of any such defects together with all available evidence thereof, promptly following the discovery thereof. The Purchaser shall afford all reasonable opportunity for the Supplier/Manufacturer to inspect such defects.

31.4 If having been notified, the Supplier/Manufacturer fails to remedy the defect within a period of 15 (fifteen) days, the Purchaser may, following notice to the Supplier/Manufacturer, proceed to do such work, and the reasonable costs incurred by the Purchaser in connection therewith shall be paid to the Purchaser by the Supplier or may be

deducted by the Purchaser from any amount due the Supplier or claimed under the Performance Security.

31.5 The term period of warranty shall mean the period of 18 months from the date of Taking Over of the Work by AEGCL. A Taking over Certificate (TOC) will be issued by the appropriate authority.

32.0 Safety:

Each and every safety measures for MAN and MACHINE will be the sole responsibility of the Contractor without any prejudice. Compensation claim if any will also be the responsibility of the contractor without any prejudice. As the contract is Turnkey in nature hence AEGCL will not bear any responsibility towards such claim.

33.0 Pollution:

Each and every measure should be taken to adhere to the standard norms to avert any occasion of Air Pollution, Water Pollution, Soil Pollution and Sound Pollution. In case of any deviation leading to any legal action the Contractor will be solely responsible without any prejudice.

34.0 Payment terms:

34.1 No advance/Mobilization advance shall be made in this contract.

34.2 (A) Progressive payment for supply items within the Country

34.2.1 Within 60 (sixty) days from the date of submission of the invoice against supply, not more than 60% (sixty Percent) payment of the total supply Invoice value would be made, on receipt and acceptance of materials in full and good condition. However GST amount on invoice would be paid 100% or as per Govt. Rules.

34.2.2 Maximum 4(Four) Nos. of progressive supply invoices would be entertained.

34.2.3 Remaining 40% (Forty percent) **Retention Amount** would be released subject to fulfillment of the following conditions-

34.2.3.1 a) 50% of balance supply amount would be paid on completion of 50% of the total erection works of the project

34.2.3.2 b) Remaining 50% of the supply amount would be paid on completion of 100% erection, testing and commissioning activities of the project, which should be certified by the Project Manager.

34.3 (B) Progressive payments for erection works

34.3.1 1. Within 60 (sixty) days from the date of submission of invoice against foundation, erection & civil works, not more than 80% (eighty percent) of the total verified invoice would be made. However, GST amount on Invoice would be paid 100% or as per Govt. Rules.

34.3.2 Maximum 8(eight) Nos. of progressive erection Invoice/ Bill would be entertained during entire erection work.

34.3.3 The 1st Progressive erection Invoice/Bill would be entertained on completion of 30% of total erection cost of the Project.

34.3.4 Maximum 6 Nos. of additional progressive erection Invoice/Bill would be entertained. Minimum value of each Invoice should be 10% of the total ordered value for foundation erection and civil works.

- 34.3.5 Remaining 20% of the erection value would be paid on successful completion of 100% erection, testing and commissioning activities of the project, which should be certified by the Project Manager.
- 34.4 Payment will be made by DGM, Tezpur (T&T) Circle, AEGCL, Dhanuwa Nagar, Tezpur. The Bidder / Firm will have to be submitted the following Net Banking details.
- (a) Banker's Name & Branch
 - (b) Account No
 - (c) Banker's address
 - (d) Banker's IFSC Code
 - (e) Banker's RTGS Code

35.0 Performance security deposit:

- 35.1 The successful bidder shall have to deposit through a **Bank Guarantee** from a Nationalized or scheduled Bank of RBI in AEGCL's standard proforma on non-judicial stamp of appropriate value for an amount equivalent to 10% (ten percent) of the total value of the order as performance security, immediately within 10 (ten) days from the issue of the letter of intent/detailed orders (as the case may be), duly pledged in favour of **AEGCL, BijuleeBhawan, Paltanbazar, Guwahati-1**, and such security deposit shall be valid up to 30 days beyond the warranty period of 12 (twelve) months. The Bank Guarantee (BG) should be submitted to the **O/O the Deputy General Manager, Tezpur T&T Circle, AEGCL, Tezpur-784001** by the issuing Bank under registered post AD.
- 35.2 Please note that, if the selected Bidder / Firm fails to furnish the requisite performance security as stated above and sign the contract within the stipulated period, 10 percent Security money will be deducted from the total Bill value.
- 35.3 If the bidder / firm fails or neglects to observe and perform any of his obligations under the contract, Purchaser (AEGCL) shall have the right to forfeit either in full or in part at his absolute discretion, the security deposit furnished by the Contractor/Firm.
- 35.4 No interest shall be payable on such deposits.

36.0 Retention Money:

- 36.1 In addition to above performance security deposit, retention money will be retained by the Engineer/Purchaser as per Bid Clause 40. The amount will be held by the Purchaser (AEGCL) till the work under the contract is completed and the completion certificate is issued.
- 36.2 If the Firm/Bidder fails or neglects to observe and perform any of his obligations under the contract, the Purchaser (AEGCL) shall have the right to forfeit either in full or in part at his absolute discretion, the security deposit furnished by the supplier/contractor.
- 36.3 No interest shall be payable on such deposit.

37.0 Force Majeure Condition:

Force Majeure condition shall be considered as any circumstances beyond reasonable control of the party claiming relief, including but not limited to strikes, lockout, civil commotion, riot insurrection, hostilities, mobilization, war, fire, flood, earthquake, malicious damage or accidents could entitle contractor to extension time. Any such delay should intimated within 10 (ten) days from the beginning of such delay to consider/approved, any claim without prior information may not be considered under force Majeure.

38.0 Settlement of Dispute and Arbitration:

Any dispute arising out of the contract will be first settled bilaterally between AEGCL and Contractor. In case, dispute cannot be settled bilaterally, it will be referred to arbitration to be by an arbitrator appointed by AEGCL. The contractor shall not stop the work during settlement of any dispute. All disputes shall be subjected to the jurisdiction of District Court of Kamrup District.

39.0 Right to Reject:

The AEGCL reserves the right to reject any or all the bids without assigning any reason thereof and the AEGCL further reserves the right to split up the work order in favour of more than one Contractor. The AEGCL also reserves the right to reject the lowest or any other price without assigning any reason.

The clauses which are not appearing in this document (bid) will be as per The General Condition of Supply and Erection 2009 of AEGCL. The General Condition of Supply and Erection 2009 of AEGCL is available in the AEGCL's website www.aegcl.co.in under Acts, Rules and Policies Tab.

Letter of Technical Bid

[Bidder's Letterhead]

Date: _____

Tender No.: _____

Invitation for Bid No.: _____

To: _____

We, the undersigned, declare that:

(a) We have examined and have no reservations to the Bidding Document, including Addenda No.: _____.

(b) We offer to supply in conformity with the Bidding Document and in accordance with the completion/delivery schedule specified in the bid document, the following Goods and Related Services: _____

- (c) Our Bid shall be valid for a period of _____ days from the date fixed for the bid submission deadline in accordance with the Bidding Document, and it shall remain binding upon us and may be accepted at any time before the expiration of that period;
- (d) If our Bid is accepted, we commit to obtain a Performance Security in the amount of _____ percent of the Contract Price for the due performance of the Contract;
- (e) We are not participating, as Bidders, in more than one Bid in this bidding process;
- (f) We understand that this Bid, together with your written acceptance thereof included in your notification of award, shall constitute a binding contract between us, until a formal Contract is prepared and executed.
- (g) Our firm, its affiliates or subsidiaries, including any Subcontractors or Suppliers for any part of the contract, has not been declared ineligible by AEGCL, APDCL or APGCL under the Employer's country laws or official regulations
- (h) We understand that you are not bound to accept the lowest evaluated bid or any other bid that you may receive.

Name _____

In the capacity of _____

Signed _____

Duly authorized to sign the Bid for and on behalf of _____

Date _____

Price Proposal Submission Sheet

Date: _____

Tender No.: _____

Invitation for Bid No.: _____

To: _____

We, the undersigned, declare that:

- (a) We have examined and have no reservations to the Bidding Document, including Addenda No.: _____
- (b) We offer to supply in conformity with the Bidding Document and in accordance with the completion/delivery schedule specified Schedule of Supply & Erection, the following Goods and Related Services:

(c) The total price of our Bid, excluding any discounts offered in item (d) below is:

(d) The discounts offered and the methodology for their application are:

(e) The following commissions, gratuities, or fees have been paid or are to be paid with respect to the bidding process or execution of the Contract:

Name of Recipient	Address	Reason	Amount

(If none has been paid or is to be paid, indicate "none.")

Name _____

In the capacity of _____

Signed _____

Duly authorized to sign the Bid for and on behalf of _____

Date _____

Bidding Forms:

Name of work:

Bid Identification No:

General

- (i) Name of the Firm/Contractor:
- (ii) Full Address:
- (iii) Constitution of the Firm:
 - a) Whether Partnership or any type:

A) Experience

- (i) No of years the Firm/Contractor has been in operation under its present name.
- (ii) Details of work executed/being executed by the tenderer in the last three years.
- (iii) Testimonials from Clients Company on various works executed for the last three years.
(Details of works executed/under execution in the last three years including other department)

Sl. No.	Name of work & W/O No.	Worked Done Under	Value of Work	Specified date of completion	Present status/completed on

--	--	--	--	--	--

B) Financial Position

(i) Financial Turnover during the last three years (copies of Audited Annual report, Accounts or a statement duly certified by a chartered accountant and Income Tax return.

Year	Turn over

Any other details that the tenderer may like to furnish to substantiate their financial and technical ability to undertake this work and complete the same within stipulated period of completion.

Name of the Bidder:-

Signature of the Bidder/Firm

Full Name

Postal Address

Phone/Mobile No.

PRICE BID

PRICE SCHEDULE

(To be submitted in the Part-II, 'Price bid' in sealed envelope in quadruplicate)

Sl no	Description	Unit	Qty	Unit Price exclusive of	Total Price exclusive of

				Taxes (Rs.)	Taxes (Rs.)
1	2	3	4	5	6
Supply of Materials					
1	Single Tension String with all Hardware Fittings for Twin Zebra for 120KN Disc Insulator 20mm dia ball (without turn buckle bolted type)	Set	12		
2	Single Suspension String with all Hardware Fittings for Twin Zebra for 120KN Disc Insulator 20mm dia ball	Set	2		
3	T Clamp suitable for ACSR Zebra to Panther	Nos	18		
4	T Clamp suitable for Twin Zebra to Single Panther		34		
5	Spacer clamp for Twin Zebra	Nos	60		
6	33kV Isolator Twin Pad Clamp for ACSR Zebra	Nos	12		
Erection Part					
1	Manpower required for dismantling and declamping of existing bus	JOB	1		
2	Manpower required for restringing and clamping of new bus	JOB	1		
Cost of transporting Conductor					
1	Loading of conductor on truck (length of Zebra conductor required= 0.36km) (Weight of Zebra conductor=0.36Km x 1.621MT/km=0.58MT)	MT	0.58		
2	Transporting of conductor from TSD-II,Samaguri to Nagaon GSS ,Khaloigaon		Km MT 42 0.58		
3	Unloading of conductor on truck (length of Zebra conductor required= 0.36km) (Weight of Zebra conductor=0.6Km x 1.621MT/km=0.58MT)	/MT	0.58MT		
			Total		
			Add 18% GST		
			Total		

Name of the Bidder:-

Signature of the Bidder/Firm

Full Name

Postal Address

Phone/Mobile No.

Form of Bid Security (Bank Guarantee)

(To be stamped in accordance with Stamp Act)

(The non-Judicial Stamp Paper should be in the name of issuing Bank)

Date: _____

Bid Reference No.: _____

WHEREAS, _____ [Name of Bidder] (hereinafter called "the Bidder") has submitted his bid dated _____ [Date] for the supply of _____ [Name of Contract] (hereinafter called "the Bid").

KNOW ALL MEN by these presents that We _____ [Name of Bank] of _____ [Name of Place] having our registered office at _____ (hereinafter called "the Bank) are bound unto _____ [Name of Purchaser] (hereinafter called "the Purchaser ") in the sum of _____1 for which payment well and truly to be made to the said Purchaser the Bank binds himself, his successors and assigns by these presents.

SEALED with the Common Seal of the said Bank this ___ day of _____ 20__.

THE CONDITIONS of this obligation are:

- 1) If the Bidder withdraws its Bid during the period of bid validity specified by the Bidder in the Bid Submission Sheet, except as provided in the relevant Bid **Clause**;
- Or
- 2) If the Bidder refuses to accept the correction of errors in his Bid;
- Or
- 3) if the Bidder, having been notified of the acceptance of his Bid by the Employer during the period of Bid validity;
 - a) fails or refuses to execute the Form of Contract Agreement in accordance with the Instructions to Bidders, if required; or
 - b) fails or refuses to furnish the Performance Security, in accordance with the Instructions to Bidders;

We undertake to pay to the Purchaser up to the above amount upon receipt of its first written demand, without the Purchaser having to substantiate its demand, provided that in its demand the Purchaser will note that the amount claimed by it is due to it owing to the occurrence of one or all of the three conditions, specifying the occurred condition or conditions.

This Guarantee will remain in force up to and including the date ___ days after the deadline for submission of bids as such deadline is stated in the Instructions to Bidders or as it may be extended by the Purchaser, notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank not later than the above date.

DATE _____ SIGNATURE OF THE BANK _____

WITNESS _____ SEAL _____

(Signature, Name, and Address)

Manufacturer's Authorization Format

Date:

NIT no:

To,
 WHEREAS _____ who are official manufacturers
 of _____ having factories at
 _____ do hereby
 authorize _____ to submit a bid in relation to the Invitation
 for Bids indicated above, the purpose of which is to provide the following goods manufactured by us
 _____ and to subsequently negotiate and sign the Contract.

Name _____

In the Capacity of _____

Signed _____

Duly authorized to sign the Authorization for and behalf of

Date _____

ANNEXURE: I

Following information is to be furnished in the 'Technical and Commercial bid' as first page.

(Please tick mark where necessary.)

1)	Earnest money (EMD)	:Submitted/Not submitted
	a) Amount of EMD	:Rs.
	b) Submitted in the form of	

	Bank Guarantee /Demand Draft	: Yes/No.
2)	Validity of the offer	: days from the date of opening of 'Technical & Commercial Bid' &'Price bid'.
3)	Nature of price offered	
	i) 'FIRM' Price	: Yes/No
4)	Terms of payment (Whether agreeable to accept payment as specified in clause- 39)	: Yes/No
5)	Date of completion of supply/Erection. (Please specify the date of completion of supply/Erection as per specification)	: Yes/No
6)	Delay in Supply/Construction (Whether agreeable to accept AEGCL's terms as specified in Clause no- 31 of 'General conditions of supply & erection of AEGCL')	: Yes/No
7)	'Security and performance guarantee' (Whether agreeable to accept as specified in Clause no-35)	: Yes/No
8)	Sales tax clearance certificate of the current year furnished	: Yes/No
9)	Whether drawing etc. as per specification are furnished	: Yes/No
10)	List of orders executed for similar works furnished	: Yes/No
11)	Performance certificate from the Govt/Govt undertaking furnished	: Yes/No
12)	Deviation from the specifications	
	a) Technical	: Yes/No
	b) Commercial	: Yes/No
13)	Information in respect of technical capability is furnished	: Yes/No
14)	Information in respect of Financial capability certificate from the Banker is furnished	: Yes/No
15)	Certificate as per Cl.no. 15.2 enclosed	: Yes/No
16)	Certificate as per Cl.no. 15.3 enclosed	: Yes/No
17)	Copy of Contract Labour License, Cl. No. 15.5	: Yes/No
18)	PAN card as per Cl. No. 15.6	: Yes/No
19)	GST registration no. and valid labour license as per Cl. No. 15.7	: Yes/No
20)	Registered Power of Attorney as per Cl.no. 15.8 enclosed.	: Yes/No

21)	Audited Balance Sheet & IT Return as per Cl. No. 15.9	: Yes/No
22)	Valid Electrical License as per Cl. No. 15.10	: Yes/No

It is certified that the rates have been quoted as per terms and conditions laid down in the tender specification and without any deviation.

Name of the Bidder:-

Signature of the Bidder/Firm

Full Name

Postal Address

Phone/Mobile No.

ANNEXURE-II

GUARANTEED TECHNICAL PARTICULARS REQUIRED BY AEGCL FOR INSULATOR STRING

(A)	INSULATOR STRINGS	Single Suspension String	Single Tension String
1	Maker's Name & Address		
2	Applicable Standard		
	a) Type of Insulator units (Ball & socket)		
	b) Size and designation of ball & socket with standard to which it will conform		
	c) No. of Disc per String		
3	Minimum Failing Load		
4	Power frequency withstand test voltage		
5	Impulse withstand Test voltage		
8	Confirm whether string type tested with offered disc insulator as per IS (yes/No)		

(C)	T CLAMP, ISOLATOR TERMINAL CLAMP & Spacers	T CLAMP (ACSR Zebra to Panther)	T CLAMP (Twin Zebra to Single Panther)	ISOLATOR Twin Pad CLAMP (ACSR zebra)	Spacer Clamp (Twin Zebra)
-----	--	---------------------------------	--	--------------------------------------	---------------------------

1	Manufacture's Name & Address				
2	Standard to which confirming				
3	Application				
6	Material (State percentage composition of constituents and impurities present)				
	a)Clamp Body				
	b)Bolts and Nuts				
	c)Spring washers				
	d)Liners if any				
7	Rated current (Ampere)				
8	Maximum temperature rise over ambient temperature when carrying rated current(°C)				
9	Rated terminal load				
10	Factor of safety				
15	Manufactures Drg No.				
16	Type Tests Certificate				
17	Mechanical test				
	a)Heat run test				
	b)Materials compositing tests				
	c)Tests for checking blow holes cracks etc				