



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520

Web: www.aegcl.co.in

Corrigendum -I

IFB No. AEGCL/MD/Tech-1168/ERS/2025-26/IFB Dated 17.06.2025

Bid identification No: AEGCL/MD/Tech-1168/ERS/2025-26/BID Dated 17.06.2025

Pre-Bid Meeting Minutes dated 26.06.2025

Name of the work: “Design, Manufacturing, Testing and Supply of 220kV Emergency Restoration System Tower at Central Assam Region”

The bid identified against the above referred Bid identification no. is amended to the following extent

Table-I

Sl No	Tender Clause/Description	Clause Details	Clarification/Modified Clause
1	Section 3: Purchasers Requirement: (3. Scope (Brief description of the scope of the work)) And Prebid Meeting Minutes Table 1 (Point 2) and Table 2 (Point 2)	Supply of PLC-CADD software (Edition: STANDARD +FE (SAPS)) including PLS -pole & PLS tower latest version (1 licenses & 2 years validity) or Manufacturers’ own ERS software for line design using ERS structures, self-supporting permanent towers, monopoles, guyed towers etc. including software for thermal up-gradation by using various conductors, sag tension calculations tower loading trees, tower analysis, foundation designs, guy wire loads and tower spotting etc. and training on PLS-CADD or Manufacturers’ own ERS software to purchasers Engineers and one computers/ laptops duly loading software. The bidder shall quote including this item in the prices of ERS.”	The supply of PLC-CADD software (Edition: STANDARD +FE (SAPS)) including PLS -pole & PLS tower latest version (1 licenses & 2 years validity) or Manufacturers’ own ERS software has been dropped. However, all bidder must provide training on design, installation etc. of ERS using PLS-CADD only to purchasers Engineers. Moreover, Bidder should submit Design documents of ERS with various configuration Erection drawing in A3 size paper showing all loading & design parameters as per technical specification of AEGCL along with supply of ERS materials. This should include following for each tower configuration i.e. Line & Tower Configuration along with design criteria considered, Anchor position & Attachment Points.



2	PART-III, Materials Requirement/Bill of Quantities (BoQ) and Section 7, BOM, 5.2 (i, ii) & 5.3(i)	Materials Requirement/Bill of Quantities (BoQ):	PART-III, Materials Requirement/Bill of Quantities (BoQ) and Section 7, BOM, 5.2 (i, ii) & 5.3(i) shall be read as 2.7 meter/design specific instead of ± 1.5 m. Accordingly, the rate may be quoted. This Modification in the BoQ shall be taken into consideration at the time of financial evaluation. The details of the 5.2 (i, ii) & 5.3(i) is given in the Table-II below
	PART-III, Materials Requirement/Bill of Quantities (BoQ) and Section 7, BOM, 10.1, 10.2, 10.3	Materials Requirement/Bill of Quantities (BoQ):	PART-III, Materials Requirement/Bill of Quantities (BoQ) and Section 7, BOM, 10.2, shall be read as 5days each ERS design Training on PLS-CADD software

Table-II

SI No	Activity Description	Item Description	Unit	Minimum Qty of ERS
5.2	Suspension; Tension & Guy Insulator Assemblies & Conductor Hardware	Horizontal V (single brace, single post) Pilot Suspension Insulator String assy, along with hardware fittings comprising of		
i)		Composite long rod suspension insulator (± 2.7 m Length/design specific, 160kN Tensile Strength)	Sets	3
ii)		Composite long rod post insulator (± 2.7 m Length/design specific, min. 64mm Core dia, 120kN Tensile Strength, 30kN Compressive Strength)	Sets	6



ASSAM ELECTRICITY GRID CORPORATION LIMITED
Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520

Web: www.aegcl.co.in



5.3		Tension Insulator String along with Hardware fittings comprising of		
iii)		Composite long rod suspension insulator (± 2.7 m Length/design specific, 160kN Tensile Strength)	Sets	24
10.0		Field & Software Training		
10.2		5days each ERS design Training on PLS-CADD software	Nos.	1

All other terms and conditions shall remain same.

Sd/-
**Chief General Manager (PP&D),
AEGCL**