## A E G C L

## ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR







## Corrigendum-I

## BID IDENTIFICATION NO: AEGCL/MD/Tech-1093/IOCL Digboi Refinery/2023/BID

The following clarifications may be noted for the work namely "Route Survey & Soil Investigation for Construction of 220kV Transmission Line for Power Import to IOCL Digboi from 220kV Tinsukia GSS" against Bid Identification No. mentioned above –

SI	Item	Query	Clarification
No.		-	
1	Price Schedule item no. 6.3	30Km tree schedule preparation work is to be required as per schedule, but rote length is 39km as mentioned in item no. 1 & 2	The bidders are requested to quote the price for 30km. This shall be later amended based on actual route length.
2	Price Schedule item no. 8.1	Soil Investigation is to be carried out for 3 nos. of locations as per schedule, but depth of boreholes are not mentioned properly.	The maximum depth of boreholes for normal soil shall be 10 meters.

All other terms and conditions of the bidding document remain same.

Sd/Chief General Manager (PP&D)
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati –01

Dtd: 06.03.2024

Memo No AEGCL/MD/Tech-1093/IOCL Digboi Refinery/2023/33 Copy to :

1. The AGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website.

Sd/-Chief General Manager (PP&D) Assam Electricity Grid Corporation Ltd Bijulee Bhawan, Paltanbazar, Guwahati –01