



No: AEGCL/DGM/LAC/TT/TLS-69/2024/ 247

Dated: 11/7/2024

Corrigendum-III/ Time Extension - III

Bid Identification No: AEGCL/DGM/LAC/TT/TLS-69/2024/720; Dated: 07.06.2024

Name of work: Procurement of 11KV Outdoor VCB, 11KV CT, 11KV LA, 11KV PT At 132/11 KV Capital GSS, AEGCL

This is for general information that the bid identified against the above referred NIT/ Bid Identification no. has been amended to the following extent and are to be read, interpreted and coordinated with all other sections of the Bid document.

1. Bid Clause no. 2.9.0 and sub-clause SI no. 5 (I) "Technical parameters of 11kV CT" has been amended as under:-


Detail of Secondary Cores	Metering	Protection
Accuracy class	0.2 *	5P10
Burden (VA)	15	15
Instrument security Factor	≤5	-
Accuracy Limit Factor	-	10

*Note: Accuracy class should be 0.2 instead of 0.5

2. The last date and time for bid submission and opening for the bidding document for the above tender notice is extended as under:

- Tender submission end date: 12:00 Hrs of 22.07.2024
- Techno-commercial bid opening date: 14:30 Hrs of 23.07.2024

All other terms & conditions shall remain same.


Deputy General Manager
Lower Assam T&T Circle,
AEGCL, Narengi, Guwahati-26

Memo No AEGCL/DGM/LAC/TT/TLS-69/2024/ 247 (a-d)

Dated: 11/7/2024

Copy to :

- 1) The Chief General Manager-O&M (LAR), AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01 - for kind information.
- 2) The CGM (T&C, Comm), AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01 - for kind information
- 3) The General Manager, Lower Assam T&T Zone, AEGCL, Narengi, Guwahati-26 - for kind information.
- 4) The AGM-(IT), O/o the MD, AEGCL Bijulee Bhawan, Paltan Bazar, Guwahati-01 - for information and publication of the NIT in the official website of AEGCL.
- 5) Notice Board.

o/c


Deputy General Manager