



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR, GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in




CORRIGENDUM-I

BID Identification No: **AEGCL/MD/CAR/HTLS/Sonabil-Depota-Ghoramari/2026/ BID/1**

With reference to the above the AEGCL clarification to the various queries received has been enclosed as Annexure-I. Further, prescribed format for the EMD/Bid Security Bank Guarantee has been enclosed as Annexure-II.

All other terms and conditions of the bidding document remain same.


Chief General Manager (O&M), CAR
AEGCL, Bijulee Bhawan
Paltanbazar, Guwahati-1

Memo No: AEGCL/MD/HTLS/Sonabil-Depota-Ghoramari/2026/16. Date 11.09.2026
Copy to:

1. The DGM(IT), O/o The MD, AEGCL, for publication of the corrigendum notice in AEGCL website (Soft copy enclosed).
2. Ref. File.


Chief General Manager (O&M), CAR
AEGCL, Bijulee Bhawan
Paltanbazar, Guwahati-1

Annexure-1

**Reply To Queries Received
BID Identification No: AEGCL/MD/CAR/HTLS/Sonabil-Depota-Ghoramari/2026/BID/1**

Sl. No	Queries By	Existing Bid Clause	Change requested by Prospective Bidders	AEGCL Remarks
1	M/S Galaxy Transmissions Pvt.Ltd, Maharashtra	2.4.1(a) The Bidder should have manufactured, tested and supplied at least Fifty (50) km of High temperature low sag (HTLS) conductor of same technology as that of the conductor being offered in this package having minimum thirty three (33) number of strands or 150 sq. mm. aluminum cross section area in last Seven(7) years as on the originally scheduled last date of bid submission (soft copy) mentioned above. \$ Satisfactory operation means Certificate issued by the Employer certifying the operation without any adverse remark.	The Bidder should have manufactured, Type tested and manufactured High temperature low sag (HTLS) conductor of same technology as that of the conductor being offered in this package having minimum thirty three (33) number of strands or 150 sq. mm. aluminum cross section area in last Seven(7) years as on the originally scheduled last date of bid submission (soft copy) and the same should have been in satisfactory type tested . And In addition the conductor manufacturer should have supplied at least Fifty (50) km of Any High temperature low sag (HTLS) conductor having minimum thirty three (33) number of strands or 150 sq. mm. aluminum cross section area in last Seven(7) years as on the originally scheduled last date of bid submission (soft copy) and the same should have been in satisfactory operations for a period of at least one (1) year as on the originally scheduled last date of bid submission (soft copy) mentioned above. A copy of performance report stating satisfactory performance should be available from Employer for at least 1 year prior to bid submission date.	The criteria as per BID Clause 2.4.1(a) stands as original. Any alternative relaxation of this technical QR is not acceptable.
2	M/S Spectrum Infra Ventures Pvt Ltd, Guwahati.	2.4.1 (d) Erection Experience (i) The bidder should have Successfully completed stringing of not less than 40 km of cumulative route length of transmission lines of 132 kV or higher voltage class as a prime contractor or as a partner in Joint Venture within the last Seven (7) years as on the originally scheduled last date of bid submission (soft copy) mentioned above. 2.4.2 In case, the Bidder, do not meet the Erection Experience criteria stipulated at para 2.4.1 (d) above on its own, the bidder should have in its bid, propose a Sub-Contractor meeting the above criteria. 2.4.3 (i) The bidder should have successfully completed physical construction of transmission line project(s) involving stringing of not less than following cumulative route length of 132 kV or higher voltage class transmission line as a prime contractor or as a partner in a joint venture within the last seven (7) years as on the originally scheduled last date of bid submission (soft copy) mentioned above: For the current package: 40KM or above	"The bidder should have successfully completed stringing of not less than 40 km of cumulative route length of transmission lines of 33 kV or higher voltage class as a prime contractor or as a partner in Joint Venture within the last Seven (7) years as on the originally scheduled last date of bid submission (soft copy) mentioned above." We further request that the corresponding requirement at Para 2.4.3(i) be amended to the same effect, so that the two provisions remain consistent. All other conditions attaching to these clauses, including the cumulative route length of 40 km, the seven-year window, the limitation of joint venture experience to the scope actually executed by the bidder, and the requirement of a provisional or final taking over certificate as proof of successful completion, may be retained unchanged, so that the rigour of the criterion is fully preserved while the eligible pool is widened.	The criteria as per BID Clause 2.4.1(d) and 2.4.3(i) stands as original. Any alternative relaxation of this technical QR is not acceptable.

Reply To Queries Received

BID Identification No: AEGCL/MD/CAR/HTLS/Sonabil-Depota-Ghoramari/2026/BID/1

Sl. No	Queries By	Existing Bid Clause	Change requested by Prospective Bidders	AEGCL Remarks
3	APAR Industries Limited, Vodadora	1.3.9.2.The bid security amounting to ₹64, 35, 312.0 shall be paid .via online mode in the Assam e-tender portal- https://assamtenders.gov.in or in the forms of an unconditional bank guarantee (BG) from a Scheduled or Nationalized Bank. ITB Clause no. 1.3.9.1 The Bidder shall furnish a bid security amounting to ₹64,35,312.00 (through Online mode)	With reference to ITB Clause No. 1.3.9.2 for subject Tender, it is understood that the Bid Security amounting to ₹64,35,312.00 may be furnished in the form of an unconditional Bank Guarantee (BG) issued by a Scheduled Bank or Nationalized Bank. However, as per BDS (ITB Clause No. 1.3.9.1), the Bid Security is required to be submitted through online mode. Further, we could not find the prescribed EMD/Bid Security Bank Guarantee format in the bidding document. In view of the above, we kindly request the to allow us for furnishing the Bid Security of ₹64,35,312.00 in the form of an unconditional Bank Guarantee, in accordance with ITB Clause No. 1.3.9.2. We also request you to kindly share the prescribed format for the EMD/Bid Security Bank Guarantee to enable us to arrange and submit the same in accordance with the bidding requirements.	The ITB Clause 1.3.9.1 to be modified as " The Bidder shall furnish a bid security amounting to ₹64,35,312.00(through Online mode) or in the forms of an unconditional bank guarantee (BG) from a Scheduled or Nationalized Bank.
			Clause No.2.29 of PGCIL tender :Technical Qualification Requirement for supplier of core of any special material for High temperature low sag conductor (HTLS) : The Conductor manufacturer shall use core of any special material (if used) such as Invar steel or composite core supplied from the qualified manufacture(s) meeting the following requirements: - The Qualified Manufacturer should have manufactured, tested and supplied at least two hundred (200) km of the same type of core material as used in the HTLS conductor being offered in the package. Further, conductor manufactured from the supplied core of such manufacturers should have been in satisfactory operation\$ for a period of at least two years as on date of NOA.	As per BID Volume I & II

Reply To Queries Received
BID Identification No: AEGCL/MD/CAR/HTLS/Sonabil-Depota-Ghoramari/2026/BID/1

Sl. No	Queries By	Existing Bid Clause	Change requested by Prospective Bidders	AEGCL Remarks
4	Singhi Infra Power Projects Pvt Ltd	Clause 2.4.1(c) The bidder, not meeting the qualification requirements stipulated at para 2.4.1(a) or 2.4.1(b) above, can also submit bid as a Licensee of a Licensor meeting the requirement stipulated at para 2.4.1(a), provided that: (i) The Bidder/Licensee has manufactured, tested and supplied at least cumulative one thousand (1000) km of ACSR/AAAC/ACAR/AACSR/AL59 conductor having at least same or more number of strands as that of the conductor being offered in the package during the last seven (7) years as on the originally scheduled last date of bid submission (soft copy) mentioned above and (ii) The Bidder/Licensee should have established manufacturing facility & developed HTLS conductor of the same technology as that of the conductor being offered in the package having minimum thirty three (33) numbers of strands or 150 sq mm aluminium cross section area and should have successfully carried out following tests as on the originally scheduled last date of bid submission (soft copy) mentioned above: (Page 18 of BID Volume -I)	Kindly clarify the applicability of Clause 2.4.1(c) in case of a Joint Venture comprising (i) Licensee (Lead Partner), (ii) Licensor / HTLS Conductor Manufacturer, and (iii) Erection Partner. Specifically, where the Licensee fully complies with Clause 2.4.1(c)(i) & (ii), and the Licensor has successfully manufactured and supplied at least Fifty (50) km of HTLS conductor of any HTLS technology having minimum 33 strands or 150 sq.mm aluminium cross-sectional area during the last seven (7) years with satisfactory operation for a minimum period of one (1) year, will such Licensor be considered compliant for the purpose of Clause 2.4.1(c), irrespective of whether the offered HTLS conductor technology is different from the HTLS technology on which the Licensor has one-year satisfactory operational experience? Kindly confirm whether the requirement of one-year satisfactory operational experience under Clause 2.4.1(a) is intended to be technology-specific to the offered conductor, or whether satisfactory operational experience on any HTLS conductor technology meeting the minimum strand/cross-sectional criteria is acceptable when the Licensee/Licensor satisfies all manufacturing facility, development and testing requirements under Clause 2.4.1(c).	The satisfactory operation experience of the HTLS Conductor shall be of the same technology as that of the conductor which will be offered in this package and will be as per BID Clause 2.4.1(a) of BID Volume -I
5	JSK Industries Pvt. Ltd		Clause No.2.29 of PGCIL tender :Technical Qualification Requirement for supplier of core of any special material for High temperature low sag conductor (HTLS) : The Conductor manufacturer shall use core of any special material (if used) such as Invar steel or composite core supplied from the qualified manufacture(s) meeting the following requirements: - The Qualified Manufacturer should have manufactured, tested and supplied at least two hundred (200) km of the same type of core material as used in the HTLS conductor being offered in the package. Further, conductor manufactured from the supplied core of such manufacturers should have been in satisfactory operation\$ for a period of at least two years as on date of NOA.	As per BID Volume I & II

Bank Guarantee

(To be stamped in accordance with Stamp Act)

(The non-Judicial Stamp Paper should be in the name of issuing Bank)

Bank's Name:**Address of Issuing Branch or Office:****Email id and phone no for correspondence:****Beneficiary: Managing Director, AEGCL****Name and Address of Purchaser****Bid Security No.:**

We have been informed that **name of the Bidder** (Hereinafter called "the Bidder") intends to submit to you its bid against **Identification No of Bid** under Invitation for Bids No. ("the IFB no") for the following work:

Furthermore, we understand that, according to your conditions, bids must be supported by a bid guarantee.

At the request of the Bidder, we **name of Bank** hereby irrevocably undertake to pay you any sum or sums not exceeding in total an amount of **amount in figures** (**amount in words**) upon receipt by us of your first demand in writing accompanied by a written statement stating that the Bidder is in breach of its obligation(s) under the bid conditions, because the Bidder:

- (a) has withdrawn its Bid during the period of bid validity specified by the Bidder in the Form of Bid; or
- (b) does not accept the correction of errors in accordance with the Instructions to Bidders (hereinafter "the ITB"); or
- (c) having been notified of the acceptance of its Bid by the Purchaser during the period of bid validity, (i) fails or refuses to execute the Contract Agreement, or (ii) fails or refuses to furnish the Performance Security, in accordance with the ITB.

This guarantee will expire: (a) if the Bidder is the successful Bidder, upon our receipt of copies of the Contract Agreement signed by the Bidder and the performance security issued to you upon the instruction of the Bidder; and (b) if the Bidder is not the successful Bidder, upon the earlier of (i) our receipt of a copy your notification to the Bidder of the name of the successful Bidder; or (ii) twenty-eight days after the expiration of the Bidder's bid.

Consequently, any demand for payment under this guarantee must be received by us at the office on or before that date.

BG expiry date:

BG clam date:

Bank's seal and authorized signature(s)**NOTE**

1. All italicized text is for use in preparing this form and shall be deleted from the final document. An amount is to be inserted by the Guarantor, representing EMD value.
2. This guarantee shall be valid up to 30 days beyond the bid validity.
3. For BG amount equal to or more than 50,000.00, BG should be signed by two bank officers to be valid.
4. Address of the banker with email and phone number for correspondence with banker should be clearly mentioned. Any correspondence related to the BG with the banker shall be made to the address mentioned in the BG.