



Corrigendum-I

BID IDENTIFICATION NO: AEGCL/MD/O&M(LAR)/SAS Upgrade Bilasipara GSS/2025/BID

With reference to the above bid document for the work namely "Upgradation/Replacement of existing Substation Automation System at 132KV Bilasipara GSS (receiving end) and at 132KV Kokrajhar GSS (sending end), AEGCL" against Bid Identification No. mentioned above, the following points may be noted related to the spare items in the BoQ: -

Sl No	Equipment	Description
1	Ethernet Switch	Dual Aux Supply: 88-300V DC, 85-264V AC Ports: 6 Nos RJ45 and 6 Nos ST FO Multimode:1300 nm
2	BI/BO requirement for BCU	BI= 48 Nos and BO=30 Nos

All other terms and conditions of the bidding document remain same.

Chief General Manager (O&M), LAR
Assam Electricity Grid Corporation Ltd

Memo No. - Note/AEGCL/MD/O&M (LAR)/SAS UPGRADE BILASIPARA GSS/2/January/2025/35,
Date:10.10.2025

Copy to:

1. The DGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website.
(Soft copy enclosed)
2. Ref. file.

Chief General Manager (O&M), LAR
Assam Electricity Grid Corporation Ltd