



CORRIGENDUM-I

NIT NO. AEGCL/DGM/TTC/TEZ/T-20/2026/321 Date: 11.05.2026

Name of work: Supply, Erection, Testing and Commissioning of 33kV CT (for 33kV Amoni feeder) under deposit scheme at 220/132/33kV Samaguri GSS, AEGCL.

(1) This is for general information that some items of the table under Clause no. 25.11 mentioning the **Type and Rating** for "33kV CT" against the above mentioned NIT for the said bid are mistyped. The same may be read as follows:


SL No.	A. Item	Ratings and Particulars
I	II	III
A	Nominal system voltage	33 kV
B	Highest system voltage, kV	36
C	Rated frequency, HZ	50
D	System earthing	Solidly earth
E	Insulation level	
a)	Impulse withstand voltage: kVp	170
b)	One-minute p.f. Withstand voltage, kV (r.m.s.)	70
F	Short time current for 3 seconds, kA	31.5
G	Minimum creepage distance, mm	1116
H	Temperature rise	As per ISS
I	FEEDER C.T.	
	(i) No. of Cores	3
	(ii) Transformation ratio	600-300/1-1-1 A
	(iii) Rated out put	
	(a) Core-1	30 VA
	(b) Core-2	15 VA
	(c) Core-3	-
	(d) Core-4	N.A.
	(e) Core-5	N.A.
	(iv) Accuracy class	
	(a) Core-1	0.2S
	(b) Core-2	5P
	(c) Core-3	P S
	(d) Core-4	N.A.
	(e) Core-5	N.A.
	(v) Accuracy limit factor	
	(a) Core-1	-
	(b) Core-2	20
	(c) Core-3	-
	(d) Core-4	N.A.

	(vi) Instrument security factor	
	(a) Core-1	<5
	(b) Core-2	-
	(c) Core-3	-
	(d) Core-4	N.A.
	(e) Core-5	N.A.
	(vii) Minimum Knee point voltage, Volts	
	(a) Core-1	-
	(b) Core-2	-
	(c) Core-3	-
	(d) Core-4	N.A.
	(e) Core-5	N.A.
	(viii) Maximum secondary resistance, ohm	
	(a) Core-1	-
	(b) Core-2	-
	(c) Core-3	-
	(d) Core-4	N.A.
	(e) Core-5	N.A.
	(ix) Maximum exciting current, at $V_k/4$ mA	
	(a) Core-1	-
	(b) Core-2	-
	(c) Core-3	-
	(d) Core-4	N.A.
	(e) Core-5	N.A.

The mistake may kindly be ignored.

All other terms and conditions shall remain the same.

Yours faithfully,


Deputy General Manager
Tezpur T&T Circle, AEGCL,
Tezpur

Memo No. AEGCL/DGM/TTC/TEZ/T-20/2026/ ১৩৩ - ১১

Date- 14.05.2026

Copy to:

1. The CGM (O&M), CAR, AEGCL, Bijulee Bhawan, Guwahati-01 for favour of his kind information.
2. The General Manager, CA T&T Zone, Samaguri for favour of his kind information.
3. The Assistant General Manager (IT), AEGCL, Bijulee Bhawan, Guwahati-01 for information and necessary action.
4. The Assistant General Manager, 220/132/33kV Samaguri GSS, AEGCL for information and necessary action.
5. The Public Relation Officer, AEGCL, Bijulee Bhawan, Guwahati-01 for information and necessary action.


Deputy General Manager

OFFICE OF THE DEPUTY GENERAL MANAGER, TEZPUR T&T CIRCLE
Kunderbari, Tezpur-784154, Email-dgmttc.tezpur@aegcl.co.in