

ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE DEPUTY GENERAL MANAGER

T&T CIRCLE, DIBRUGARH



TENDER DOCUMENT

NOTICE INVITING TENDER NO: AEGCL/DGM/TTC/DBR/O&M/TC-02/2023/1448; dtd. 13/07/23

Name of work

Repairing/renovation of CRB at 132KV GSS, AEGCL, Rupai.

Work Site


132KV GSS, AEGCL, Rupai.

Tender cost amounting to Rs 1000.00
Deposited in the form of

Issued to

Address

Signature of Contractor/Firm


Deputy General Manager,
T&T Circle, AEGCL,
Dibrugarh

Signature of the Bidder

(A) **INFORMATION TO BIDDER:**

1. **NAME OF WORK: - Repairing/renovation of CRB at 132KV GSS, AEGCL, Rupai.**

2. **ESTIMATED AMOUNT:- Rs. 8,92,838.00 (Rupees Eight Lakhs Ninety Two Thousand Eight Hundred and Thirty Eight only) (inclusive of GST).**

3. **LOCATION OF WORK: - 132KV GSS, AEGCL, Rupai.**

4. **TENDER ADDRESS: - Office of the Deputy General Manager, T&T Circle, AEGCL, Dibrugarh.**

5. **BIDDING PROCEDURE:-**

a) All tenders shall have to be submitted in prescribed forms attached herewith eventually to be drawn up in the rules of AEGCL.

b) Two different envelopes to be used as follows.

Envelope-1: Bid document signed by bidder on all pages, Tender Document cost, Earnest Money, Techno-commercial data of the Bidder and other necessary documents must be enclosed.

Envelope-2: Price Bid

6. **KEY DATES:-**

a) Bid Submission Start Time & date:- 12.00 Hrs. of **18/07/23**

b) Bid Submission End Time & date:- 14.00 Hrs. of **04/08/23**

c) Techno-Commercial Bid Opening Time & date:- 14.30 Hrs. of **04/08/23**

7. **TENDER PAPER COST AND MODE OF PAYMENT:-**

Bidder has to pay Non-Refundable tender document cost @**Rs. 1,000.00 (Rupees One Thousand)** only in the form of DD in favour of the Managing Director, AEGCL, Bijulee-Bhawan, Paltanbazar, Guwahati-1, payable at Guwahati. The original copy of the DD/Banker's Cheque must be submitted along with relevant documents in the Envelope-1.

8. **BID SECURITY/EARNEST MONEY AND MODE OF PAYMENT:-**

a) For participation in bidding procedure, participants must compulsorily pay the Bid Security of **Rs 17,857.00(Rupees Seventeen Thousand Eight Hundred and Fifty Seven)** only in the form of Fixed Deposit in favour of the Managing Director, AEGCL, Bijulee-Bhawan, Paltanbazar, Guwahati-1, payable at Guwahati. The original copy of the Bid Security must be submitted along with relevant documents in the Envelope-1.

b) The bid security of the successful Bidder shall be returned as promptly as possible once the successful Bidder has signed the Contract and furnished the required performance security.

c) The bid security of unsuccessful Bidders shall be returned as promptly as possible upon the successful Bidder's furnishing of the performance security.

d) The bid security may be forfeited:-

(i) If a Bidder withdraws its bid during the period of bid validity period.

(ii) If the successful Bidder fails to sign the Contract within the specified period.

9. **VALIDITY OF BID:-**

Bid shall remain valid for the period of 180 days from the date of bid submission end date.

10. **TIME OF COMPLETION:-**

a) The allotted time of completion for the work is 90 days from the handing over of the site.

11. **DISCLAIMER:-**

- a) The purchaser is not committed contractually in any way to those Bidders whose Bid are accepted. The issue of this Bid does not commit or otherwise oblige the purchaser to proceed with any part or steps of the process.

12. **LANGUAGE OF BID:-**

The Bid, as well as all correspondence and documents relating to the bid exchanged by the Bidder and purchaser, shall be written in the English and / or Assamese language.

13. **NEGOTIATION WITH BIDDER:-**

The purchaser reserves the right to hold negotiations with lowest bidder if AEGCL feels the quoted rates of particular item(s) are unreasonably high. The bid must be valid, eligible and technically acceptable and considered for award of contract. Cost quoted by bidder shall be inclusive of all scope of work as specified in the bidding document including any related services that is implicit to carry out the work successfully. Price will be firm and no price variation will be allowed within the completion period given in the work order.

(B) ELIGIBILITY CRITERIA.

1. **EXPERIENCE**

- a) A Bidder may be a private entity or a government-owned entity or any combination of such entity with the intent to enter into an agreement supported by a letter of intent or under an existing agreement in the form of a joint venture, consortium or association.
- b) A Bidder, and all partners constituting the Bidder, shall have Indian nationality.
- c) To be qualified for the bid, the bidder must compulsorily meet the following minimum criteria: bidder must establish the experience as single contractor.
- i) Bidder must have valid work experience of similar work like construction, repairing and maintenance of building, executed within the last 3 years at any Govt. Deptt., PSU, etc. conforming either of the following requirements and submit supporting documents(Copy of Work Orders and Completion Certificate) to establish work experience. The purchaser holds the authority to verify the documents provided in support of work experience.

SI No	Description	Amount not less than (Rs)
1	3 (three) similar completed works	3,60,000.00
2	2 (two) similar completed works	4,50,000.00
3.	1 (one) similar completed work	7,20,000.00

If the nature of work and value differs from the above stated conditions, it will not be considered while evaluation of technical qualification.

- * The purchaser holds the authority to verify the documents provided in support of work experience.

2. **FINANCIAL QUALIFICATION**

- a) Minimum average annual turnover of **Rs. 3,00,000.00. (Rupees Three Lakhs)** only calculated as total certified payments received for contracts in progress or completed, within the last 3 (Three) Years, ending 31st March of the previous financial year. Audited Balance sheet must be furnished as a proof of annual turnover. Any other form of supporting documents instead of Audited balance sheet will not be accepted. The bidder should be financially sound.
Current bank solvency certificate must be submitted to show the bidder's financial position.

- b) The contractor shall make good at his own cost and to the satisfaction of the purchaser all defects, or other faults which may appear during the defect liability period.
In default, the purchaser may employ and pay other agency or persons to amend and make good such damages. Losses and expenses consequent thereon or incidental there to shall be made good and borne by the contractor, failing which the same shall be recoverable from the payment due to the contractor.

3. **SITE VISIT**

The bidders are advised to visit the site of work and obtain for itself on its own responsibility all the information for necessary for preparing the bid.

4. **QUERY ON THE BIDDING DOCUMENT**

Prospective Bidder may submit queries, if felt necessary, requesting clarification of any bid clause. Such queries must be submitted in the O/o the DGM, T&T Circle, AEGCL, Dibrugarh by the Tender Clarification end date and time mentioned in the Bid Data Sheet. Purchaser shall clarify to the extent felt necessary. Any query outside the mail or in physical letters after due date shall not be entertained.

5. **DEADLINE FOR SUBMISSION OF BIDS**

Bids shall be received only on or before the date and time indicated in the Bid Data Sheet. The Purchaser may, at its discretion, extend the deadline for the submission of bids by amending the Bidding Document, in which case all rights and obligations of the Purchaser and Bidders previously subject to the deadline shall thereafter be subject to the deadline as extended.

6. **OPENING OF TECHNO-COMMERCIAL BIDS:-**

The opening of the techno-commercial bid shall be conducted at the address as per the date and time specified in the bid document on the basis of technical qualification, Financial qualifications and fulfilment of the legal conditions.

Price Bids of those bidders shall only be opened whose techno-commercial bids are found to be responsive to the requirement of the bidding document and intimation will be issued in due course.

- * Any interrelations, erasures, or overwriting shall be valid only if they are signed or initialised by the person signing the bid.

7. **PRILIMINARY EXAMINATION OF TECHNICAL BIDS:-**

The purchaser shall examine the Techno-Commercial Bid to confirm that all the documents and technical documentation requested in this bidding document have been provided and to determine the completeness of each document submitted. If any of these documents or information is missing, **the Bid may be rejected**. The purchaser shall confirm the following documents and information have been provided in the Technical Bid. If any of the following document or information is missing or found incorrect, **the offer shall be rejected**.

1. Original copy of tender document cost payment receipt.
2. Original copy of EMD BG or Online EMD payment receipt and
3. Duly Filled and signed Tender Submission Form.

Bidders should submit hard copies of the documents mentioned above in (1), (2) and (3) in a physical envelope prior to the deadline for technical bid submission. Techno-commercial bids shall be summarily rejected if these three documents are not submitted in hard copy or via email by the deadline for technical bid submission.

8. **RESPONSIVENESS OF TECHNO-COMMERCIAL BID:-**

The purchaser shall examine the Techno-commercial Proposal, to confirm that the requirement of the bidding document have been met without any material deviation or reservation. If the bid is not substantially responsive to the requirements of the Bidding Document, it shall be rejected by the Purchaser and may not subsequently be made responsive by correction of the material deviation, reservation, or omission.

9. CORRECTION OF ARITHMETICAL ERRORS

1. Where there are errors between the total of the amounts given under the column for the price breakdown and the amount given under the Total Price, the former shall prevail and the latter will be corrected accordingly.
 2. Where there are errors between the total (sum) of the amounts of the different Schedule(s) and the amount given in terms of a Grand Total or Grand Summary, as the case may be the former shall prevail and the latter will be corrected accordingly.
 3. If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetical error, in which case the amount in figures shall prevail subject to (1) and (2) above.
- * If the Bidder that submitted the lowest evaluated bid does not accept the correction of errors, its bid shall be disqualified and its bid security may be forfeited.

10. EVALUATION OF PRICE BIDS

To evaluate a Price Bid, the Purchaser shall consider the following:

1. The bid price including GST as quoted in the Price Schedule.
2. Price adjustment for correction of arithmetical errors in accordance with Clause (B)9.
3. The Purchaser shall use the criteria and methodologies listed in this Clause. No other evaluation criteria or methodologies shall be used.

11. AWARD CRITERIA

The purchaser shall in general award the contract to the lowest substantially responsive bidder. However, the purchaser reserves the right to not award contract to the lowest substantially responsive bidder without thereby incurring any liabilities to bidders.

12. RIGHT TO REJECT

The purchaser reserves the right to reject any or all the bids without assigning any reason thereof and the purchaser further reserves the right to split up the work order in favour of more than one Contractor. The purchaser also reserves the right to reject the lowest or any other price without assigning any reason. The clauses which are not appearing in this Bid document will be as per The General Condition of Supply and Erection 2009 of AEGCL. The General Condition of Supply and Erection 2009 of AEGCL is available in the AEGCL's website www.aegcl.co.in.

(C)

1. ACCEPTANCE OF BID AND CONTRACT AGREEMENT:-

- a) An agreement shall have to be drawn on non-judicial stamp of appropriate value with AEGCL by the selected Contractor in AEGCL's General Conditions of Supply and Erection 2009 of contract within 15 (ten) days from the date of issue of the LOI.
Wherever there is any variation in between the conditions of AEGCL's General Conditions of Supply and Erection 2009 and the above terms & conditions, this bid conditions will supersede the conditions of AEGCL's General Conditions of Supply and Erection 2009.

2. PAYMENT TERMS:-

- a) No advance/Mobilization advance shall be made in this contract.
b) No claim for interest shall be entertained by AEGCL.
c) Final bill must contain the original site register.
d) Final payment shall be released to the contractor only after completion of the work in all respect and final acceptance by AEGCL.
e) Payment is subject to availability of specific fund.
f) The Bidder / Firm will have to be submitted the following Net Banking details.
- Banker's Name & Branch
 - Account No
 - Banker's address
 - Banker's IFSC Code
 - Banker's RTGS Code

3. RETENTION MONEY:-

- a) 10% retention money will be deducted from running bill, which will be released along with the final bill on completion of the work in all respect.

4. WARRANTY:-

- a) The contractor warrants that all the Goods are new, unused and of the most recent or current models, and that they incorporate all recent improvements in design and materials, unless provided otherwise in the Contract.
b) The term period of warranty shall mean the period of 12 months from the date of Taking Over of the Work by AEGCL. A Taking over Certificate (TOC) will be issued by the appropriate authority.
c) If during the period of warranty any defect should be found, the purchaser shall give Notice to the contractor stating the nature of any such defects together with all available evidence

5. EXTENSION OF TIME FOR COMPLETION

- a) Time is the essence of the contract. No extension of time shall normally be allowed except on valid and genuine ground.

6.

CONTRACTUAL FAILURE, LIQUIDATED DAMAGE AND PENALTY:-

- a) Liquidity Damages 1.0% (one percent) of the amount of delayed work per week subjected to the maximum 10 % of the contract value.

7. TERMINATION OF CONTRACT:-

- a) If the performance of the contract is not satisfactory and not corrected within 15 days of receiving notice, then employer shall be at liberty to terminate the contract and get the work executed through other means at the risk and cost of the Contractor.

8. FORCE MAJEURE CONDITION

- a) Force Majeure condition shall be considered as any circumstances beyond reasonable control of the party claiming relief, including but not limited to strikes, lockout, civil commotion, riot insurrection, hostilities, mobilization, war, fire, flood, earthquake, malicious damage or accidents could entitle contractor to extension time. Any such delay should intimated within 10 (ten) days from the beginning of such delay to consider/approved, any claim without prior information may not be considered under force Majeure.

9. SETTLEMENT OF DISPUTE AND ARBITRATION:-

- a) Any dispute arising out of the contract will be first settled bilaterally between AEGCL and Contractor. In case, dispute cannot be settled bilaterally, it will be referred to arbitration. The contractor shall not stop the work during settlement of any dispute. All disputes shall be subjected to the jurisdiction of District Court of respective District of work.

10. DEVIATION/ERROR IN DRAWING AND SPECIFICATIONS:-

- a) In case of non-suitability of drawing or specifications, the matter to be brought to the notice of Competent Authority without any delay. Any modification or deviation should only be done after approval of Competent Authority.
- b) In case of any omission and error in the drawing and specification the same procedure as above should be followed.

11.

VARIATION AND DEVIATION OF QUANTITY: -

- (a) The Tendered rates shall hold good for any variations in the Tendered quantities for completion of work on account of any modification in the bill of quantities or design or specification.
- (b) **Deletion of work:**
AEGCL and its representative have the right to delete or decrease any item or quantity from schedule of quantity at its discretion if deemed necessary. No claim by the contractor will be admissible for this deletion or deduction of Item/quantity from schedule of quantity.

12.

ENGINEER AT LIBERTY TO OBJECT: -

- (a) AEGCL's Site in-charge shall have right to remove any person provided by the Contractor who, in the opinion of the Site in-charge, misconducts himself, or is incompetent or negligent in the proper performance of his duties, or whose presence on Site is otherwise considered by the Engineer to be undesirable, and such person shall not be again allowed upon the Works without consent of the Engineer. Any person so removed from the Works shall be replaced immediately without hampering the work.

13.

TAXES: -

- (a) Any taxes, royalties and duties as per Govt. Law should be responsible of the contractor and must be included in their quoted rate.

14.

INSURANCE: -

The bidder shall arrange for any pay/cost of personnel accident insurance, medical treatment etc. in respect of their employees assigned to the works for all time and shall govern by Law of the land.

15.

DAMAGE TO PERSON AND PROPERTY: -

- (a) The Contractor shall be responsible for all injury to the work or to workmen, to persons, animals or things and for all damages to the structural and/or decorative part of property which may arise from the operations or neglect of contractor or its employees, against whether such injury or damage arise from carelessness, accident or any other cause whatsoever in any way connected with the carrying out of this Contract. The Contractor shall at his cost effect the insurance necessary and indemnify AEGCL entirely from all responsibility in this respect. The scope of insurance is to include loss or damage to the work and workmen due to carelessness, accident including fire, earthquake, floods, all medical expenses, compensation to be borne in the event of accident etc., damage or loss to the Contract itself

till this is made over a complete state. Insurance is compulsory and must be affected from the very initial stage and should cover the entire contract period till handing over of complete works. The Contractor shall also be responsible for anything which may be excluded from damage to any property arising out of incidents, negligence or defective carrying out of this Contract. AEGCL shall be at liberty and is hereby empowered to deduct the amount of any damages, compensations, costs, charges and expenses arising or occurring from or in respect of any such claim or damages from any sums due or to become due to the Contractor.

STATUTORY AND SAFETY REQUIREMENT: -

- 16.
- (a) Each and every safety measure for MAN and MACHINE will be the sole responsibility of the Contractor without any prejudice. Compensation claim if any will also be the responsibility of the contractor without any prejudice.
 - (b) During the execution of the work, the contractor shall have to mark the site with banner warning/indicating precautions.
 - (c) The Contractor shall, throughout the execution and completion of the Works and the remedying of any defects therein.
 - (d) Have full regard for the safety of all persons entitled to be upon the Site and keep the Site So far as the same is under his control) and the Works in an orderly state appropriate to the avoidance of danger to such persons.
 - (e) Provided and maintain at his own cost all lights, guards, fencing, warning signs and watching, when and where necessary or required by the Engineer or by any duly constituted authority for the protection of the Works or for the safety and convenience of the public or others, and Take all reasonable steps to protect the environment on and off the Site and to avoid damage or nuisance to persons or to property of the public or others resulting from pollution, noise or other causes arising as a consequence of his methods.

(D)

SCOPE OF WORK

1.

SITE PREPARATION:-

All works required for site preparation will have to be carried out by the contractor at his own expense, whenever directed by the Site In-charge.

- a) The Contractor shall clear the site of unnecessary vegetation to prepare the site for work only as per directions given by the Site In-charge.
- b) Any unnecessary structures are to be demolished and serviceable materials to be stacked and stored as directed by AEGCL.

2.

a) **REINFORCEMENT:-**

All reinforcement shall be cleaned thoroughly by removing loose scales, oil, grease or other deleterious materials. The contractor shall obtain the approval of the Engineer-in-charge or his representative to the reinforcement when fixed in position before any concrete is deposited in the forms.

b) **SHUTTERING AND CENTERING:-**

Shuttering for concrete shall be made of either metal or timber suitably lined and of substantial and rigid construction true to shape, alignment and dimensions as shown on the approved drawings

c) **REINFORCED CEMENT CONCRETE:-**

- 1. Optimum quantity of water shall be mixed to produce the design mix/nominal mix concrete of required workability.
- 2. Workability shall be such that the concrete surrounds and properly grips all reinforcement.
- 3. The degree of consistency, which shall depend upon nature of work and method of vibration of concrete, shall be determined by regular slump tests to be carried out by the contractor at his cost.
- 4. Usually for mass concrete in RCC works where vibrations are used the slumps shall be within 10mm to 25mm.

d) **BRICK MASONRY:-**
Brick work in cement mortar with 1st class brick including racking out joints and dewatering if necessary, and curing complete as directed in sub-structure up to plinth level. Cement Mortar used should be in 1:4 proportion.

e) **CONSTRUCTION JOINT:-**

All construction joints horizontal or vertical shall be at predetermined position according to approved drawing or as directed by the Engineer-in-charge. Prior to commencement of fresh concreting over any construction joint which has set but hardened, the removal of laitance and roughening shall be done by wire brushing and washing and care shall be taken to avoid dislodgement of coarse aggregates.

f) **PLASTERING:-**

Surfaces to be rendered must be cleaned and made free from all dust, loose materials, grease, etc, and be well wetted for a few hours (the wall should not be soaked but only damped evenly); but the wall should not be too wet.

g) **CURING:-**

Curing should be done as soon as possible after concrete is placed and when initial set has occurred and before it has hardened. It should be continued for a minimum period of 7 to 12 days when normal (Portland) cement is used, 4 to 7 days when rapid hardening cement is used, and should be kept thoroughly wet for 24 hours when high alumina cement is used.

h) **PRIMING AND PAINTING:-**

As per specifications in the schedule of quantity.

3. **SUPPLY OF MATERIALS:-**

- a) The supply of materials should be as per ISI standard.
- b) The purchaser reserves the right to carry out quality Audit/inspection of all the supply materials and if found not in accordance with scope of contract, supplied materials shall be rejected.

(C) **WORK SCHEDULE.**

1. **SITE HANDOVER:-**

- a) Handing over of the work site will be done in presence of Project Manager or its authorized representative, Resident Engineer, site engineer and contractor or its authorized representative.
- b) The contractor has to submit the list of manpower along with contact numbers to be engaged for the work to the Project Manager.
- c) The date of site handing over to be noted on the Site register duly signed by the Project Manager or its authorized representative, Resident Engineer, site engineer and contractor or its authorized representative.

2. **WORK COMMENCEMENT:-**

The work should be started only after having the following documents.

- a) Work order
- b) Site Register
- c) Measurement Book
- d) Drawings
- e) Specifications of item & schedule of quantity

BILL OF QUANTITY

Price Bid (To be provided in separate envelope & should be inclusive of GST)

Name of the work:- Repairing/renovation of CRB at 132KV GSS, AEGCL, Rupai.

Sl. No	Description	Unit	Qty	Rate	Amount
1.	Removing dry or oil bound distemper, water proofing cement paint and the like by scrapping, sand papering and preparing the surface smooth including necessary repairs to scratches etc. complete.	Sqm	948.91		
2.	Providing and applying white cement based putty of average thickness 1 mm, of approved brand and manufacturer, over the plastered wall surface to prepare the surface even and smooth complete.	Sqm	948.91		
3.	Applying priming coats with primer of approved brand and manufacture, having low VOC (Volatile Organic Compound) content. With water thinnable cement primer on wall surface having VOC content less than 50 grams/litre.	Sqm	948.91		
4.	Wall painting with acrylic emulsion paint, having VOC (Volatile Organic Compound) content less than 50 grams/ litre, of approved brand and manufacture, including applying additional coats wherever required, to achieve even shade and colour. Two coats	Sqm	948.91		
5.	Painting with synthetic enamel paint of approved brand and manufacture of required colour to give an even shade :One or more coats on old work	Sqm	40.57		
6.	Providing and laying vitrified floor tiles in different sizes (thickness to be specified by the manufacturer) with water absorption less than 0.08% and conforming to IS: 15622, of approved make, in all colours and shades, laid on 20mm thick cement mortar 1:4 (1 cement : 4 coarse sand), jointing with grey cement slurry @ 3.3 kg/ sqm including grouting the joints with white cement and matching pigments etc., complete. Size of Tile 600x600 mm	Sqm	274.75		
7.	Steel work in built up tubular (round, square or rectangular hollow tubes etc.) trusses etc., including cutting, hoisting, fixing in position and	Kg	305.54		

	applying a priming coat of approved steel primer, including welding and bolted with special shaped washers etc. complete. Hot finished welded type tubes				
8.	Providing and fixing precoated galvanised iron profile sheets (size, shape and pitch of corrugation as approved by Engineer-in-charge) 0.50 mm (+ 0.05 %) total coated thickness with zinc coating 120 grams per sqm as per IS: 277, in 240 mpa steel grade, 5-7 microns epoxy primer on both side of the sheet and polyester top coat 15-18 microns. Sheet should have protective guard film of 25 microns minimum to avoid scratches during transportation and should be supplied in single length upto 12 metre or as desired by Engineerin-charge. The sheet shall be fixed using self drilling /self tapping screws of size (5.5x 55 mm) with EPDM seal, complete upto any pitch in horizontal/ vertical or curved surfaces, excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required.	Sqm	44.56		
9.	Dismantling tile work in floors and roofs laid in cement mortar including stacking material within 50 metres lead. For thickness of tiles 10 mm to 25 mm	Sqm	22.57		
10.	Painting with aluminium paint of approved brand and manufacture to give an even shade . Two or more coats on new work.	Sqm	6.66		
11.	Providing Antiskid Tiles of approved quality size, shape not less than 8mm on floor, skirting over a cement mortar bed 15mm thick of 1:3 (1 cement: 3 coarse sand) approved make fix with Fix-A-Tile (Choksey/Sika/Pedelite/Rouf)/ white cement complete at all level as specified and directed. (A) CERAMIC i)Normal range (Sizes 300 mm x 300mm and above) (a)Orient made: Galaxy Brown, Galaxy creama, Galaxy Pink, Galaxy Green, Pulsar Beige, Pulsar Blue, Pulsar Dove, Pulsar Pink, Burj Brown, Burj Green, Burj Slate.	Sqm	5.37		
12.	Providing polished ceramic wall tiles of approved quality, size, shape and thickness not less than 8mm on walls and skirtings over cement mortar bed 10 mm thick in prop. 1:3 (1 cement : 3 coarse sand) including cutting where necessary finished with flush pointing with Fix-A-Tile (Choksey / Sika /	Sqm	17.20		

	<p>Pedelite / Rouf) /white cement slurry mixed with approved pigment to match shade of tiles complete at all levels as specified and directed. (Cement plastering to be measured and paid separately). (Coloured pigment should be in conformity with colour of tiles and as approved and directed by the Department). (Walls means both interior and exterior walls).</p> <p>b) Executive range Somany/ Orient/Nitco/Asian Make i) Of size 200mmx300mm and above</p>				
13.	<p>Providing fitting and fixing vitreous china pedestal type water closet (European type W.C pan 400mm high) with seat and lead ,CP brass hinges and rubber buffers , CI/MS brackets , 40 mm dia flush band with fittings including painting of fittings and brackets, required. (Flushing Cistern to be paid separately)</p> <p>A) Parryware make a) White (i) Universal Closet S Trap (Cat No.C0271) (Anglo Indian) (inclusive of seat cover).</p>	Each	1		
14.	<p>Supplying, fitting and fixing PVC flushing cistern with all internal fittings with CI brackets including fitting and fixing standard size CP flush pipe, union clamps etc. complete as directed and specified (pipes will be measured separately)</p> <p>i) Parryware make a) White (iii) Economy Dual Flush (Cat No.C8109).</p>	Each	1		
15.	<p>Supplying fitting and fixing C.P. bib cock 15mm dia of approved brand directed and specified. (G.I. & C.P pipes will be measured separately)</p> <p>(VI) Sona brand (i) Bib Cock (Code.No.RG-5015)</p>	Each	2		
	(iv) Bib Cock 2 in 1,Code.No.RG-5027	Each	1		
	(ii) Bib Cock Long Body,Code.No.	Each	1		
16.	<p>Supplying fitting and fixing approved uPVC Pipes of different sizes, with all necessary 'R' brand or similar approved P.V.C. Fittings such as bend, tee, elbow, reducer, nipple, plug, long screw fitting, clamps etc. complete at all levels including below G.L. as directed and specified.</p> <p>(A) Exposed or in trenches</p>	Rm	3		

	SUPREME/ PRINCE/ SFMC BRAND or other equivalent approved brand (High pressure pipe Sch-40) a) 50 mm dia e)20 mm dia				
		Rm	20		
17.	Providing, fitting and fixing CP towel rail complete as directed and specified. (a) Jaquar make (i) Continental 300mm for wash basin (Cat.No. ACN-1101N).	Each	1		
18.	Providing fitting and fixing Glass Shelf complete as directed and specified. 1.20.1 Glass shelf with C.P. guard rail (b) Legend (Cat. No.LD-00104)	Each	1		
19.	Providing, fitting and fixing CP soap tray / soap dish complete as directed and specified. (a) Continental (Cat.No.ACN-1331N)	Each	1		
20.	Providing fitting and fixing Mirror with plastic frame of size 500x400mm complete as directed and specified.	Each	1		
21.	Providing vitreous China wash basin with CI/MS brackets, C.P brass chain with plug,PVC waste pipe including painting of fittings and brackets, cutting and making good the walls wherever required. (Pillar cock, stop cocks, waste coupling are to be paid separately) 1.13.1 PEDESTAL BASIN (with pedestal) (A) Parryware Make (a) White (ii) Vanice 620 x 485 x 850 (Cat. No.C841 P/R) (white/coloured)	Each	1		
				Total Amount=	



Dy. General Manager,
T&T Circle, AEGCL, Dibrugarh

Appendix-1

COVERING LETTER (ON THE BIDDERS LETTER HEAD)

To,
The Deputy General Manager,
T&T Circle, AEGCL,
Dibrugarh.

Sub: Submission of Tender.

Ref: -

1. NIT No:
2. Name of work:-

Sir,

Having examined the terms & conditions, technical specifications, detailed items of work etc. as well as acquainting myself/ourselves with site of work, surroundings to get the required materials etc. I am/we are to submit herewith my/our tender for the above mentioned work. My/our rates are quoted as per the specification laid down in the schedule of items of work.

I /We clearly understand that all materials, tools and plants, machineries, labours, testing of material, storage, haulage etc. required in the work shall have to be arranged by me/us from my/our own resources in the events of allotment of the work to me/us.

I /We also clearly understand that in the event of acceptance/approved of my/our tender, the work shall have to be executed strictly as per specifications and the same shall have to be completed in all respects within the stipulated time failing which I am/We are liable to be penalized as per rules laid down in Tender document as well as agreement thereof.

Appendix-2

PROFILE OF THE BIDDER

Hard copy of the following documents to be submitted with Techno-Commercial Bid.

Sl. No.	Particulars	To be filled by Bidder
a)	Name of the Bidder	:-
b)	Registration with Memorandum of Association	:-
c)	PAN	:-
d)	GST Registration number	:-
e)	EPF	
f)	IT Returns (last 3 Years)	
g)	ESI	
h)	Solvency	
i)	Audited Balance Sheet	
j)	Labour License registration	:-
k)	Date of Establishment/ Incorporation	:-
l)	Postal Address	:-
	House No.	:-
	Lane	:-
	Street	:-
	Town/Village	:-
	Post Office	:-
	P.S.	:-
	District	:-
	Pin code	:-
m)	Telephone Number	:-
	Mobile No.	:-
	E-Mail Address	:-
	Website	:-

n)	Name(s) of the Owners / Directors/Partners	:-
o)	Name of the Banker with Address and Telephone Number	:-

	Contact Person Details <i>(Furnish here name of that person with whom AEGCL may get in touch for more information or clarifications)</i>	Name: - Designation: - Mobile Number: - Email Address:-
--	--	--

Appendix-3

WORK EXPERIENCE OF THE BIDDER

Following documents to be submitted with Techno-Commercial Bid (Envelope-1)

In order to techno-commercially qualify for this Bid, the bidders have to submit work orders along with Completion certificate for similar nature of work like construction of building, renovation of building along with roof works etc, executed within last 3 (three) years at any Govt. Deptt., PSU etc. As per guidelines laid down in the technical qualifications clause. The work completion certificate must be duly signed by the officers not below the rank of Executive Engineer/Assistant General Manager.

If the nature of work and value differs from the above stated conditions, it will not be considered while evaluation of technical qualification.

Sl. No.	Name of work	Nature of Work	Executed Amount	Starting Date	Completion Date
a)					
b)					
c)					

NB:- The Bidder may prepare extra sheet if required

Appendix-4

FINANCIAL QUALIFICATIONS

Following documents to be submitted with Techno-Commercial Bid (Envelope-1)

In order to techno-commercially qualify for this Bid, the bidders have to submit annual audit report for last 3 (Three) years. As per the guidelines laid down in clause no (A) i.e. (ELIGIBILITY QUALIFICATION) 4. i.e. (FINANCIAL QUALIFICATION).

1.	Financial Qualifications:
a)	Minimum average annual turnover of ₹ _____ calculated as total certified payments received for contracts in progress or completed.
b)	Minimum cash flow of ₹ _____ showing financial resources such as liquid assets unencumbered real assets, line of credit and other financial means. Bank solvency certificate to be submitted.

NB:- The Bidder may prepare extra sheet if required