ASSAM ELECTRICITY GRID CORPORATION LIMITED
OFFICE OF THE MANAGING DIRECTOR
Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3
PHONE: 0361-2739520 Web: www.aegcl.co.in

Addendum-II

REF. NOS.:

1. **NIT No.: AEGCL/MD/Tech-32/400kV Umrangshu/2026/NIT Dated: 08.09.2026**
2. **Bid Identification No.: AEGCL/MD/Tech-32/400kV Umrangshu/2026/BID Dated: 16.09.2026**
3. **Name of the Work: Construction of new 400/132kV Umrangshu Grid Substation along with Associated Transmission System at Dima Hasao District, Assam**
4. **Addendum-I No.: AEGCL/MD/Tech-32/400kV Umrangshu/2026/09 Date: 27.09.2026**
5. **Pre-bid meeting dated 05.10.2026**

With reference to the above-mentioned NIT and Bid/Tender Documents, the following clause has been amende/added.

Sl. No.	Clause of Tender Data Sheet	As Existing	As Amended
1.	**Volume-I Section VIII - SCC - Clause No. 8.2**	The Time for Completion of the whole of the Facilities shall be **36 (Thirty-Six) months** from the Effective Date as described in the Contract Agreement. Contractor shall have to complete the part of the facilities within the Work finalized as per the Appendix-4, Section-9 (Contract Form). The employer has the right to award the uncompleted part of the facilities which by the contractor at the scheduled timeline to next lowest quoted tenderer by pre-closing of the contract.	The Time for Completion of the whole of the Facilities shall be **24 (Twenty-Four) months** from the Effective Date as described in the Contract Agreement. Contractor shall have to complete the part of the facilities within the Work finalized as per the Appendix-4, Section-9 (Contract Form). The employer has the right to award the uncompleted part of the facilities which by the contractor at the scheduled timeline to next lowest quoted tenderer by pre-closing of the contract.
2	**Volume-II CHAPTER 17: TECHNICAL SPECIFICATIONS FOR TRANSFORMER (UPTO 400kV CLASS) Clause No. 17.4.0. SPECIFIC REQUIREME**	For 400 kV Class Auto transformer: Bidder/Manufacturer should have successfully carried out Dynamic Short Circuit test on 315MVA or above rating 400/132/33kV, 3- Phase Auto transformer as on the originally scheduled date of bid opening and shall enclose the relevant Test Report/certificate along with	For 400 kV Class Auto transformer **The** Bidder/Manufacturer **shall** have successfully **conducted a dynamic short-circuit test on a three-phase, 400 kV class auto-transformer rated 315 MVA or above**, on or before the originally scheduled date of bid opening. The relevant test report/certificate shall be

	NT Point No. (ii) Dynamic Effect of Short Circuit:	bid. In case bidder/manufacturer has not successfully tested 315MVA or above rating 400/132/33kV, 3-Phase Auto transformer for Dynamic Short Circuit test, their bid shall be considered technically non responsive. The offered transformer should comply the requirement of similarity clause specified in IS 2026 (PART 5) / IEC 60076-5 with respect to short circuit tested transformer. Further, design review of offered 400kV Class Auto transformer shall be carried out based on the design of short circuit tested 315MVA or above rating 400/132/33kV, 3-Phase Auto transformer.	submitted with the bid. The offered transformer shall meet the similarity requirements of IS 2026 (Part 5)/IEC 60076-5 with respect to the short-circuit-tested transformer. During detailed engineering, the design of the offered transformer shall be reviewed against the design of the tested transformer to verify compliance with these requirements.
3	**Additional Documents**	**NA**	Additional drawings and documents are attached separately in a compressed (RAR) folder titled **"Additional Documents-II"** for reference and necessary action.

Sd/-
Chief General Manager (PP&D)
Assam Electricity Grid Corporation Ltd

Memo No. AEGCL/MD/Tech-32/400kV Umrangshu/2026/13(a-b) Date: 15.10.2026

Copy to:

1. PS to the Managing Director, AEGCL, Bijulee Bhawan, 1st Floor, Paltan Bazar, Ghy-01, for kind appraisal of the Managing Director, AEGCL.
2. The AGM - IT, O/o the MD, AEGCL for publication in the AEGCL's website.

Sd/-
Chief General Manager (PP&D)
Assam Electricity Grid Corporation Ltd