



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Office : 1st Floor Bijulee Bhawan, Paltan Bazar, Guwahati-781001

CIN : U40101AS2003SGC007238

Phone No. 0361-2739520/ Fax : 0361-2739513 Web : www.aegcl.co.in



No.: AEGCL / DGM/LAC/TT/TLS-69/2026/1163.

Date: 16-01-26.

ADDENDUM - I

NIQ No. AEGCL/DGM/LAC/TT/TLS-69/2026/839; Dated: 02-01-2026

Name of work: Procurement of Inverter with battery bank and Fiber Optic Patch cords against implemented scheme 'SAS Upgradation at 220/132KV Rangia GSS, AEGCL' under SOPD.

This is for the general information and clarification that the technical specifications of the following items are as given below and this addendum is to be read, interpreted and coordinated with all other parts of the bid document.

1. Inverter:

DC Input: 96 V (8 Batteries of 12 V each)

Input/output: (208-240) VAC,

1-φ Capacity : 3000 VA/ 2400 W

2. Battery bank:

Lead Acid Battery of 12 V, 100Ah Capacity,

Total no. of Battery: 08

In view of the above, the bid submission end date and techno-commercial bid opening date is amended as below:

Tender submission end date and time: 12:00 Hrs., 02.02.2026

Techno-commercial bid opening date and time: 14:00 Hrs., 03.02.2026

All other terms and conditions of the bid document shall remain same.


Deputy General Manager
Lower Assam T&T Circle,
AEGCL, Narengi, Guwahati-26

Memo No AEGCL/DGM/LAC/TT/TLS-69/2026/ 1163. (a-f)

Dated: 16-01-26

Copy to :

1. PS to the MD, AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01 – for kind appraisal to the MD, AEGCL.
2. The CGM, O&M, LAR, AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01 - for kind information.
3. The GM, Lower Assam T&T Zone, AEGCL, Narengi, Guwahati-26 - for kind information
4. The AGM (IT), AEGCL, Bijulee Bhawan, Paltan Bazar, Guwahati-01 – for information & necessary publication in AEGCL's website.
5. The AGM, 132/33kV Rangia GSS, AEGCL, Chirakhundi - for information
6. Notice Board

o/c


Deputy General Manager