



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

CORRIGENDUM-I

Ref:

BID IDENTIFICATION NO.: AEGCL/MD/Tech-1219/Thermal-Assam/MP&RS/2026/06, dated – 10.06.2026.

("Conducting Route Alignment, Detailed Survey, and Soil investigation for BOQ Preparation of Proposed 400kV Double Circuit Chapar - Rangia Transmission Line for Evacuation of Power from 3200 MW Chapar Thermal Power Plant").

In reference to the bid identified against the above Bid identification no., please find the clarification as mentioned below.

Sl. No.	Clause no. of Specification	Item description as per tender document	Queries on Specification	Clarification from AEGCL
1	Clause no. 3.6.1.d (Section 3, Employer's Requirement)	Integrating and superimposing the selected route on the digitized land survey maps of Govt. of Assam.	As per our Suggestion this work is to be carried out at the time of construction/check survey work, and this item is not included in BOQ as a separate item. Please omit this clause as it's a long procedure.	Integrating and superimposing the selected route on the digitized land survey maps of Government of Assam is not required under the present scope of work. Accordingly, bidders are not required to consider this activity while quoting.
2	Clause no. 3.8.7.e & f (Section 3, Employer's	e) The Contractor shall also identify the forest/non-forest areas involved duly authenticated by Concerned	This item is not included in BOQ as a separate item. Forest proposal preparation is a difficult and time-consuming	Preparation of the Forest Clearance (FC) Proposal is not included in the scope of the survey work and is therefore not required. However, the Surveyor shall prepare and submit the following as part of the Route



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

	Requirement)	<p>authorities.</p> <p>i) A statement of forest areas with survey/compartment Number (all type of forest RF/PF/ Acquired Forest/Revenue Forest/Private Forest /Forest as per dictionary meaning forest etc.)</p> <p>ii) A statement of non-forest areas with survey/compartment nos.</p> <p>iii) Tree cutting of details (Girth wish & specie wise)</p> <p>iv) Marking of Forest areas with category on topo sheets 1:2,50,000 showing complete line route, boundaries of various forest divisions and their areas involved.</p> <p>v) Village forest maps of affected line and affected forest area and marking of</p>	<p>task. It requires extensive field surveys, data collection, stakeholder consultations, environmental assessments, mapping, and compliance with legal and regulatory requirements. Please omit this clause.</p>	<p>Alignment and Detail Survey scope:</p> <ul style="list-style-type: none"> • Tree Enumeration Report for the entire approved transmission line route, indicating species-wise and girth-wise details. • Location-wise Soil Resistivity Reports for all proposed tower locations along the approved route. • Reconnaissance Survey Report covering the complete surveyed route, including details of all major crossings and sensitive features such as forest land crossings, railway crossings, power line crossings, river crossings, National Highway (NH) crossings, State Highway (SH) crossings, and other significant obstacles. • Geo-referenced Survey of India (Sol) Toposheet maps showing the proposed transmission line alignment and its proximity to environmentally sensitive areas. Maps and reports must clearly identify whether the alignment passes through or affects any Reserved Forest (RF), Protected Forest, Eco-Sensitive Zone (ESZ), National Park, Wildlife Sanctuary, etc., and determine the corresponding route length falling within forest areas. <p>The cost of all the above activities shall be deemed to be included in the rates quoted under the relevant BoQ</p>
--	--------------	---	---	--



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

		<p>the same</p> <p>vi) Forest division map showing line and affected forest area.</p> <p>f) The Contractor shall finalize the forest clearance proposal on the prescribed forest, as per requirements of the state/MOE & F. duly completed in all respects for submission by the Employer to the Forest Department.</p>		<p>items for "Route Alignment" and "Detail Survey". No separate payment shall be admissible or made for carrying out these activities.</p>
--	--	---	--	--

The above Corrigendum-I shall form an integral part of the above-referred Bid Identification Numbers. Except to the extent expressly stated herein, all other clauses, terms, and conditions of the bid documents shall remain unchanged. Bidders are requested to regularly visit the website <https://assamtenders.gov.in/nicgep/app> to keep themselves updated regarding the above tenders. **Bidders who have already submitted their bids are also requested to suitably modify their bids, if required, in accordance with this Corrigendum-I.**

Sd/-
Chief General Manager, (PP&D)
Assam Electricity Grid Corporation Limited



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office:(FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

Memo No. AEGCL/MD/Tech-1219/Thermal-Assam/MP&RS/2026/21

Date: 18.06.2026

Copy to:

1. PS to the Managing Director, AEGCL for kind appraisal to the MD, AEGCL.
2. The AGM - IT, O/o the MD, AEGCL for publication in the AEGCL's website.

Sd/-
Chief General Manager, (PP&D)
Assam Electricity Grid Corporation Limited