

ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Office: 1st Floor, Bijulee Bhawan, Paltan Bazar, Guwahati – 781001
CIN: U40101AS2003SGC007238
Ph:- 0361-2739520/Fax:-0361-2739513 Web: www.aegcl.co.in



BID IDENTIFICATION NO: AEGCL/DGM/LAC/TT/TLS-69/2026/859; Dated: 18-02-2026

Bidding Document **For**

Procurement of 132 kV Bus Isolator for replacement of existing 2 sets of Bus Coupler Isolator with higher current rating capacity at the 132/33kV Kahilipara GSS, AEGCL.

**DEPUTY GENERAL MANAGER,
LOWER ASSAM T&T CIRCLE, AEGCL
NARENGI, GUWAHATI-26.**

SECTION - 1
INSTRUCTION TO BIDDER

1.1.0 INTRODUCTION :-

1.1.1. The **Deputy General Manager, Lower Assam, T&T Circle, AEGCL** on behalf of **Assam Electricity Grid Corporation Ltd**, hereinafter referred to as **AEGCL** or Purchaser invites sealed tenders in prescribed form, from reputed firms/ contractors/ manufacturers with sound technical and financial capabilities for the following work. A single-stage two envelope procedure (**Techno-Commercial and Price Bid**) will be adopted for this tender.

- a) **Name of Work :- Procurement of 132 kV Bus Isolator for replacement of existing 2 sets of Bus Coupler Isolator with higher current rating capacity at the 132/33kV Kahilipara GSS, AEGCL.**
- b) **Delivery Destination :- 132/33kV Kahilipara GSS, AEGCL, Guwahati-19.**
- c) **Estimated Value for Work :- Rs. 14,51,400.00 (Rupees Fourteen Lakh Fifty One Thousand Four Hundred) only including taxes and F&I.**
- d) **Fund: O&M HQ (LAR) for FY 2025-26**
- e) **Key Dates: Refer to NIT.**
- f) Bidders may obtain further information from the office of the Deputy General Manager, Lower Assam T&T Circle, AEGCL, Narengi, Guwahati - 781026, Assam.

1.2.0 BIDDING PROCEDURE :-

1.2.1 Two envelope bidding procedure will be adopted. Bidders are to submit two sealed envelopes simultaneously, one containing the technical & Commercial proposal, Part-I (Technical & Commercial Bid) and the other containing the price proposal Part-II (Price Bid), enclosed together in one sealed envelope. Initially, only the Part-I bids shall be opened. Part-I proposals submitted by bidders, which do not conform to the specified requirement, may be rejected as deficient bids. The Part-II (Price Bid) proposals of technically qualified bidders will be opened at a date and time, which will be informed to all the qualified bidders of Part-I.

1.3.0 TENDER PAPER COST AND MODE OF PAYMENT:-

- 1.3.1 The Bidder shall bear all costs associated with the preparation and submission of its Bid, AEGCL shall not be responsible or liable for those costs, regardless of the conduct or outcome of the bidding process.
- 1.3.2 The tender document can be downloaded from AEGCL website (www.aegcl.co.in). For tender documents downloaded from AEGCL website, tender paper cost (in the form of A/C payee DD/Bankers Cheque) has to be submitted along with tender quotation. The cost of the tender paper is **Rs. 1000/- (Rupees One Thousand) only** to be pledged in favour of the **"AEGCL, Guwahati"**.

1.4.0 SCOPE OF WORK :-

- 1.4.1 The brief description of the scope of work covered under this bidding document is furnished below:
 - a. Design, manufacture, supply of reputed make 145kV, 2500A, 40KA for 3 sec horizontal central break type isolator without earth switch complete with manual and motor driven mechanisms along with support insulators, pipe structures, clamps & connectors and hardware fittings complete as per the technical parameters given below and Bill of Quantity.
 - b. Loading at manufacturer's works, transportation and delivery at the substation site, including unloading at destination site.
 - c. Freight & Transit Insurance, storage at site and site insurance of all materials at site shall be in the scope of the contractor.
 - d. Arrangements of any permits required for transportation and movement of supplied materials. However, AEGCL shall assist as far as practicable in the process.
- 1.4.2 The Bill of Quantities for indicative purposes is furnished in Price Schedules.
- 1.4.3 The bidder on its own responsibility may visit and examine the Site of Works and its surroundings and obtain information that may be necessary for preparing the bid. Any permits or licenses that may be required to execute the works should also be obtained by the contractor.

1.5.0 TIME SCHEDULE:

The successful bidder will be expected to complete the works within **4 (four) months from the date of drawing approval.**

1.6.0 ELIGIBILITY CRITERIA OF THE BIDDER:

1.6.1 A Bidder may be a private entity or a government-owned entity or any combination of such entity with the intent to enter into an agreement supported by a letter of intent or under an existing agreement in the form of a joint venture, consortium or association.

1.6.2 Joint venture bid will not be accepted

1.6.3 A Bidder shall have Indian nationality. A Bidder shall be deemed to have the nationality of a country if the Bidder is a national or is constituted, incorporated, or registered and operates in conformity with the provisions of the laws of Republic Of India.

1.6.4 AEGCL considers a **conflict of interest** to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations, and that such conflict of interest may contribute to or constitute a prohibited practice under Anticorruption Policy of Government of India and Government Of Assam. In pursuance Anticorruption Policy's requirement that Employer as well as bidders, suppliers, and contractors observe the highest standard of ethics. AEGCL will take appropriate actions if it determines that a conflict of interest has flawed the integrity of any procurement process.

1.6.5 A firm that is under a declaration of ineligibility by the AEGCL or any Government Entity or PSU at the date of the deadline for bid submission or thereafter i.e. on or before contract signing date shall be disqualified. Bidders shall provide such evidence of their continued eligibility satisfactory to the AEGCL, as the Employer shall reasonably request.

1.7.0 FINANCIAL CAPABILITY

1.7.1 Bidder will require to submit along with the bid the audited balance sheets and other legal financial statements acceptable to AEGCL, for the last 3 (three) years to demonstrate the current soundness of the Bidders financial position and its prospective long term profitability. As a minimum, an Applicant's net worth calculated as the difference between total assets and total liabilities should be positive. Wherever necessary the Employer may make enquiries with Bidder's bankers.

1.7.2 Average Annual Turnover : Minimum average annual turnover 50% of total work value calculated as total certified payments received for contracts in progress or completed, within the last 3 (Three) Years.

1.7.3 Financial Resources: Bidder need to demonstrate access to, or availability of, financial resources such as liquid assets, unencumbered real assets, lines of credit, and other financial means, other than any contractual advance payments to meet:

- (1) the cash-flow requirement of atleast 50% of the work value and
- (2) the overall cash flow requirements for this contract and its current works commitment.

1.7.4 Bidder must keep GST liabilities up to date and non-payment of GST liabilities and non-filing of relevant GST return more than 3 (three) months shall be reckoned as GST defaulter and this may be considered a cause for disqualification of a bidder and the bid may be rejected.

1.7.5 The Contractor must furnish their Bank Solvency Certificate to show the bidder's financial position indicating the amount by concerned authority in necessary format as per their banks

1.8.0 EXPERIENCE:

1.8.1 Experience in similar nature of works under contracts in the role of manufacturer, contractor, subcontractor, or management contractor for at least the last 7 (seven) years prior to the bid submission deadline.

1.8.2 Participation as manufacturer/ contractor with Experience of having successfully completed similar works during last 7 years ending last day of the month previous to the one in which applications are invited should be either of the following:

- (a) Three (3) similar completed works costing not less than 40% of total estimated cost.
- (b) Two (2) similar completed works costing not less than 50% of total estimated cost.
- (c) One (1) similar completed works costing not less than 80% of total estimated cost.

1.8.3 **Bidder may be manufacturer of the offered products or a firm/company having authorisation from a manufacturer. In case the bidder is not a manufacturer of the offered products, bidder must submit manufacturer's authorisation using for that purpose Form-MA provided in Section-3 Bidding forms.** Offered product's manufacturer must have least Five years of experience in design, manufacture and supply of 33kV or above rating equipment as specified in this bid. The offered product's manufacturer must have supplied such equipment which are in successful operation for atleast three years.

1.8.4 The Bidder must have experience executing work of similar nature previously in any Govt. organization/ PSU. The bidder must submit experience and completion certificate for scrutiny by AEGCL. Each of such project/ works should consist of completion certificate.

1.9.0 LITIGATION HISTORY

Bidders shall submit details of all litigation, arbitration or other claims, whether pending, threatened or resolved in the last five years, with the exception of immaterial claims with a cumulative impact of not more than 10% of their total assets. The Employer may disqualify bidders in the event that the total amount of pending or threatened litigation or other claims represent more than 50% of their total assets.

1.10.0 DOCUMENTS COMPRISING THE BID

1.10.1 The bid submitted by the bidder shall comprise two envelopes submitted simultaneously, one containing only the technical proposal and the other the price proposal.

1.10.2 The Technical Bid submitted by bidders shall contain the following:

- a) Bid Submission Sheet
- b) Documentary evidence to establish that the Bidder meet the qualifying requirements in accordance with Clause 1.5.0.
- c) Documents to be furnished as per Clause 1.9.3
- d) The Bid Guarantee (Bid Security) in accordance with Clause 1.20.0 & its sub clauses of this Section.
- e) All Bidding Schedules properly filled up including Price Bid Schedules.
- f) All other information and documents such as MA, Guaranteed and Technical Particulars, drawings, technical leaflets etc, as required in the Technical Specification

1.10.3 To establish its eligibility and qualifications to perform the contract, the bidder shall provide along with the above mentioned documents the following additional documents (mandatory) on qualifying requirements such as:

- a) *Copies of original documents defining the constitution or legal status, place of registration, and principal place of business, written power of attorney of the signatory of the Bid to commit the Bidder.*
- b) *Copies of valid Trade License issued by competent authority in the State of Assam or in the State where the bidder's business is registered.*
- c) *Copies of PAN, GST Registration Certificate as per Goods & Services Tax laws.*
- d) *Total monetary value of similar work performed by the bidder in each of the last three years.*
- e) *Experience in works of a similar nature and volume of work, and details of works under way or contractually committed in AEGCL or any other Govt. entity/PSU who may be contacted for further information on those contracts.*
- f) *Qualifications and experience of key site management and technical personnel proposed for the Contract.*
- g) *Reports on the financial standing of the Bidder, such as profit and loss statements and audited annual accounts certified by CA of the company for the last three years including IT return duly acknowledged by the tax department for the last three years.*
- h) *Evidence of adequacy of working capital for this contract (access to line (s) of credit and availability of other financial resources).*
- i) *Information regarding any litigation, current or during the last five years, in which the Bidder is involved, the parties concerned, and disputed amount.*

1.10.2 Even though the bidders meet the above qualifying criteria, they are subject to be disqualified if they have made misleading or false representations in the forms, statements and attachments submitted in proof of the qualification requirements.

1.10.3 Notwithstanding anything stated herein above, AEGCL reserves the right to assess the capacity and capability of the bidder to execute the work, should the circumstance warrant such assessment in the overall interest of AEGCL.

1.11.0 DOCUMENTS ESTABLISHING CONFORMITY OF THE GOODS AND SERVICES

1.11.1 The documentary evidence of the conformity of the goods and services to the Bidding Document may be in the form of literature, drawings and data, and shall furnish:

- a) A detailed description of the essential technical and performance characteristics of the goods and services, including the functional guarantees of the Goods, in response to the Specification;
- b) A commentary on the Purchaser's Specification and adequate evidence demonstrating the substantial responsiveness of the plant and services to those specifications. Bidders shall note that standards for workmanship, materials and equipment designated by the Purchaser in the Bidding Document are intended to be descriptive (establishing standards of quality and performance) only and not restrictive. The Bidder may substitute alternative standards, brand names and/or catalog numbers in its bid, provided that it demonstrates to the Purchaser's satisfaction that the substitutions are substantially equivalent or superior to the standards designated in the Specification.

1.12.0 SITE VISIT

The interested bidders are advised to visit any grid substation of AEGCL and examine the site of works and its surroundings and obtain for itself on its own responsibility all information that may be necessary for preparing the bid. The costs of visiting the Site shall be at the bidder's own expense.

1.13.0 AMENDMENT OF BIDDING DOCUMENTS

1.13.1 At any time prior to the deadline for submission of bids, the AEGCL may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, modify the bidding documents by issuing addenda.

1.13.2 Any addendum thus issued shall be part of the bidding documents pursuant to Sub-Clause, and shall be communicated in writing or by fax to all purchasers of the bidding documents. Prospective bidders shall acknowledge receipt of each addendum by fax to AEGCL.

1.14.0 LANGUAGE OF BID

1.14.1 The bid, and all correspondence and documents related to the bid, exchanged between the bidder and AEGCL shall be written in the English language. Supporting documents and printed literature furnished by the bidder shall also be in English language.

1.15.0 BID PRICES

1.15.1 Bidders shall give a breakdown of the prices in the manner and detail called for in the **Schedules of Prices**.

1.15.2 In the Schedules, Bidders shall give the required details and a breakdown of their prices, including all taxes, duties, levies, and charges payable as of twenty eight (28) days prior to the deadline for submission of bids, as follows:

(a) Plant and equipment (**Schedules of Prices**) shall be quoted on an EXW (ex-factory, ex-works, ex-warehouse or off-the-shelf, as applicable). All taxes and duties taxes as applicable and freight and insurance shall be indicated separately.

1.15.3 Price Adjustment: Prices quoted by the Bidder shall be FIRM during performance of the contract. Duties and Taxes shall be adjusted, except there is variation due to changes in legislation of the Country.

1.16.0 INSURANCE

The Bidder shall insure the Works/Materials (in transit and at the site) in accordance with the requirements of General Conditions of Contract. The Bidder shall provide details of the policies that he intends to take out as part of his Bid submission. **The bid price shall include all costs in pursuance of fulfilling insurance liabilities under the contract.**

1.17.0 BID VALIDITY

1.17.1 Bids shall remain valid for a period of **180 (One Eighty)** days after the date of opening of Technical Bids.

1.17.2 In exceptional circumstances, prior to expiry of the original bid validity period, AEGCL may request that the bidders extend the period of validity for a specified additional period. The request and the responses thereto shall be made in writing. A bidder may refuse the request without forfeiting its bid security. A bidder agreeing to the request will not be required or permitted to modify its bid, but will be required to extend the validity of its bid security for the period of the extension, and in compliance with Clause 1.19.0 in all respects.

1.18.0 CLARIFICATION OF BIDS

To assist in the examination, evaluation, and comparison of the Technical and Price Bids, and qualification of the Bidders, the Purchaser may, at its discretion, ask any Bidder for a clarification of its bid. Any clarification submitted by a Bidder that is not in response to a request by the Purchaser shall not be considered. The Purchaser's request for clarification and the response shall be in writing. No change in the substance of the Technical Bid or prices in the Price Bid shall be sought, offered, or permitted, except to confirm the correction of arithmetic errors discovered

1.19.0 BID SECURITY (EARNEST MONEY)

1.19.1 **The Bidder shall furnish, as part of its bid with the Technical Proposal, a bid security in the amount of Rs. 29,000.00 (Rupees Twenty Nine Thousand) only.**

1.19.2 For participation in the bidding procedure, participants must compulsorily pay the Bid Security / Earnest Money Deposit in the form of DD/Fixed Deposit/bank Guarantee/Banker's Cheque in favour of "AEGCL, Guwahati". The bid security shall remain valid for 30 days beyond the original validity period for the bid, and beyond any period of extension subsequently requested.

1.19.3 Any bid not accompanied by an acceptable bid security shall be rejected as non-responsive.

1.19.4 The bid securities of unsuccessful bidders will be returned as promptly as possible, against written request from the unsuccessful bidders.

1.19.5 The bid security of the successful bidder will be returned when the bidder has signed the Contract Agreement and furnished the required performance security.

1.19.6 The bid security may be forfeited

- (a) if the bidder withdraws its bid, except as provided in Sub-Clause 1.24.1;
- (b) if the bidder does not accept the correction of its bid price, pursuant to Sub-Clause 1.24. or
- (c) in the case of a successful bidder, if it fails within the specified time limit to
 - (i) sign the Contract Agreement,
 - (ii) furnish the required performance security.

1.19.7 No interest shall be payable by AEGCL on the above bid guarantee.

1.20.0 ALTERNATIVE PROPOSALS BY BIDDERS

1.20.1 Bidders shall submit offers, which comply with the Bidding Documents, including the basic AEGCL's Requirements as indicated in the bidding documents. Alternatives will not be considered. The attention of bidders is drawn to the provisions of Clause 1.29.0 regarding the rejection of bids which are not substantially responsive to the requirements of the bidding documents.

1.21.0 FORMAT AND SIGNING OF BID

1.21.1 The bidder shall prepare one original and two copies of the bid proposal, clearly marking each one as: "ORIGINAL- BID PROPOSAL, etc as appropriate. In the event of discrepancy between the original and any copy, the original shall prevail.

1.21.2 The original and all copies of the bid shall be typed or written in indelible ink (in the case of copies, Photostats are also acceptable) and shall be signed by a person or persons duly authorized to sign on behalf of the bidder. All pages of the bid where entries or amendments have been made shall be initialed by the person or persons signing the bid.

1.21.3 The bid shall contain no alterations, omissions or additions, except those to comply with instructions issued by AEGCL, or as necessary to correct errors made by the bidder, in which case such corrections shall be initialed by the person or persons signing the bid.

1.21.4 The Bidders must submit the Bid Guarantee in separate sealed envelope, super-scribed as under:

"BID GUARANTEE (Name of the Package)"

1.21.5 The Bid must contain the name, residence and place of business of the person or persons making the Bid and must be signed and sealed by the Bidder with his usual signature. The names of all persons signing should also be typed or printed below the signature.

1.21.6 Bids by Corporation / Company must be signed with the legal name of the Corporation/Company by the President, Managing Director or by the Secretary or other person or persons authorized to Bid on behalf of such Corporation/Company in the matter.

1.21.7 A Bid by a person who affixes to his signature the word 'President', 'Managing Director', 'Secretary', 'Agent', or other designation without disclosing his principal will be rejected.

1.21.8 Satisfactory evidence of authority of the person signing on behalf of the Bidder shall be furnished with the Bid.

1.21.9 The Bidder's name stated on the proposal shall be exact legal name of the firm

1.21.10 Bids not conforming to the above requirements of signing may be disqualified.

1.21.11 If the outer envelope is not sealed and not marked as above, AEGCL will assume no responsibility for the misplacement or premature opening of the bid.

1.21.12 The Bid must be accompanied with requisite BID SECURITY in a separate sealed cover.

1.21.13 The Bidders have the option of sending the Bids by post/courier or in person. Bids submitted by Telex/ Telegram/Fax will not be accepted. No request from any Bidder to AEGCL to collect the proposal from Airlines/Cargo Agents etc shall be entertained by AEGCL.

1.22.0 DEADLINE FOR SUBMISSION OF BIDS

1.22.1 Bids must be received by AEGCL at the address specified above no later than refer to NIT.

1.22.2 AEGCL may, at its discretion, extend the deadline for submission of bids by issuing an addendum in accordance with Clause 1.13.0, in which case all rights and obligations of AEGCL and the bidders previously subject to the original deadline will thereafter be subject to the deadlines extended.

1.23.0 LATE BIDS

1.23.1 Any bid received by AEGCL after the deadline for submission of bids prescribed in Clause 1.22.0 will be rejected and returned unopened to the bidder.

1.24.0 WITHDRAWAL OF BIDS

1.24.1 The bidder may withdraw its bid after bid submission, provided that written notice of the withdrawal is received by AEGCL prior to the deadline for submission of bids.

- 1.24.2 The bidder's withdrawal notice shall be prepared, sealed, marked and delivered with the envelopes additionally marked "WITHDRAWAL".
- 1.24.3 Withdrawal of a bid during the interval between the deadline for submission of bids and the expiration of the period of bid validity specified in Sub-Clause 1.18.0 may result in the forfeiture of the bid security pursuant to Sub-Clause 1.19.6.
- 1.25.0 OPENING OF BIDS**
- 1.25.1 The Purchaser shall conduct the opening of Technical Bids through online process at the address, date and time specified in the BDS. Bidders at their discretion may attend the techno-commercial bid opening. Price bid of those bidders shall only be opened whose techno-commercial bids are found to be responsive to the requirement of the bidding document.
- 1.26.0 PROCESS TO BE CONFIDENTIAL**
- 1.26.1 Information relating to the examination, clarification, evaluation and comparison of bids and recommendations for the award of a contract shall not be disclosed to bidders or any other persons not officially concerned with such process. Any effort by a bidder to influence AEGCL's processing of bids or award decisions may result in the rejection of the bidder's bid.
- 1.27.0 PRELIMINARY EXAMINATION OF BIDS AND DETERMINATION OF RESPONSIVENESS**
- 1.27.1 The Purchaser shall examine the Techno-commercial Bid to confirm that all documents and technical documentation requested in this bidding document have been provided, and to determine the completeness of each document submitted. If any of these documents or information is missing, the Bid may be rejected.
- 1.27.2 The Purchaser's determination of a bid's responsiveness is to be based on the contents of the bid itself. A substantially responsive Techno-commercial Bid is one that meets the requirements of the Bidding Document without material deviation, reservation, or omission. A material deviation, reservation, or omission is one that, a) if accepted, would: (i). Affect in any substantial way the scope, quality, or performance of the plant and services specified in the Contract; or (ii). Limit in any substantial way, inconsistent with the Bidding Document, the Purchaser's rights or the Bidder's obligations under the proposed Contract; or b) If rectified, would unfairly affect the competitive position of other Bidders presenting substantially responsive bids. The Purchaser shall examine the Techno-commercial Proposal, to confirm that the requirement of the bidding document have been met without any material deviation or reservation. If a bid is not substantially responsive to the requirements of the Bidding Document, it shall be rejected by the Purchaser and may not subsequently be made responsive by correction of the material deviation, reservation, or omission
- 1.28.0 CLARIFICATION OF BID PROPOSALS AND CONTACTING AEGCL**
- 1.28.1 To assist in the examination, evaluation and comparison of Bids, AEGCL may, at its discretion, ask any bidder for clarification of its bid. The request for clarification and the response shall be in writing or by mail, but no change in the price or substance of the bid shall be sought, offered or permitted except as required to confirm the correction of arithmetic errors discovered by AEGCL in the evaluation of the bids.
- 1.28.2 Subject to Sub-Clause 1.28.1, no bidder shall contact AEGCL on any matter relating to its bid from the time of opening Bids to the time the contract is awarded. If the bidder wishes to bring additional information to the notice of AEGCL, it should do so in writing.
- 1.28.3 Any effort by the bidder to influence AEGCL in AEGCL's evaluation of price proposals, bid comparison or contract award decisions may result in the rejection of the bidder's bid.
- 1.29.0 CORRECTION OF ERRORS**
- 1.29.1 Price Proposals determined to be substantially responsive will be checked by AEGCL for any arithmetic errors. Arithmetic errors will be rectified on the following basis. If there is a discrepancy between the unit rate and the total cost that is obtained by multiplying the unit rate and quantity, the unit rate shall prevail and the total cost will be corrected unless in the opinion of AEGCL there is an obvious misplacement of the decimal point in the unit rate, in which case the total cost as quoted will govern and the unit rate corrected. If there is a discrepancy between the total bid amount and the sum of total costs, the sum of the total costs shall prevail and the total bid amount will be corrected.
- 1.29.2 The amount stated in the Form of Bid for Price Proposal will be adjusted by AEGCL in accordance with the above procedure for the correction of errors and, shall be considered as binding upon the bidder. If the bidder does not accept the corrected amount of bid, its bid will be rejected, and the bid security may be forfeited in accordance with Sub-Clause 1.19.6 (b).
- 1.30.0 EVALUATION AND COMPARISON OF BID PROPOSALS**
- 1.30.1 AEGCL will evaluate and compare only the bids determined to be substantially responsive in accordance with Clause 1.27.0.
- 1.30.2 AEGCL will carry out a detailed evaluation of the bids in order to determine whether the bidders are qualified and whether the technical aspects are substantially responsive to the requirements set forth in the bidding documents. In order to reach such a determination, AEGCL will examine the information supplied by the Bidders and other requirements in the bidding documents, taking into account the following factors:

- (a) Qualification
 - (i) the determination will take into account the Bidder's financial and technical capabilities and past performance; it will be based upon an examination of the documentary evidence of the Bidder's qualifications submitted by the Bidder, well as such other information as AEGCL deems necessary and appropriate; and
 - (ii) an affirmative determination will be a prerequisite for AEGCL to continue with the evaluation of the proposal; a negative determination will result in rejection of the Bidder's bid.
- (b) Technical
 - (i) overall completeness and compliance with AEGCL's Requirements; the technical merits of materials and equipment offered and deviations from AEGCL's Requirements; suitability of the facilities offered in relation to the environmental and climatic conditions prevailing at the site; quality, function and operation of any process control concept included in the bid;
- (c) Commercial
 - (i) Deviations and omissions from the contractual and commercial conditions as identified in the Bid.
 - (ii) compliance with the time schedule called for in the Bidding Document and evidenced as needed in a milestone schedule provided in the bid; and
 - (iii) the functional guarantees of the facilities offered against the specified performance criteria of the plant and equipment.

1.30.3 The Purchaser shall use the criteria and methodologies listed in this Clause. No other evaluation criteria or methodologies shall be used. To evaluate a Price Bid, the Purchaser shall consider the following:

- a) The bid price excluding taxes as quoted in the Price Schedules;
- b) Price adjustment for correction of arithmetical errors.
- c) The following methodology will be practiced for identification and treatment of the Abnormally Low Bids (ALB) in this tender process of AEGCL:

(a) Identification:

For the identification of the Abnormally Low Bids, two approaches as applicable shall be adopted:

- i. **Absolute Approach** when there is fewer than five substantially responsive bidders and if the bid price is 20% or more below AEGCL's cost estimate then AEGCL's tender evaluation committee should clarify the Bid price with the bidder to determine whether the Bid is abnormally low.
- ii. **Relative Approach** is a statistical comparison method which will be applied when there are more than five nos. of substantially responsive bids. A potential ALB is identified where the low Bid is more than one standard deviation below the average of substantially responsive bids received.
In this approach first the Average bid price is determined and then by deducting the standard deviation from the average bid price, potentially ALB may be determined.

(b) In case of ALB, the tender evaluation committee of the respective tenders shall undertake the following three stage review which are as follows:

- i. Identify ALB as per the step mentioned in Clause No.(a).(i) and 10.b).(ii) whichever is applicable.
- ii. Clarify and analyse the bidders resource inputs and pricing, including overheads, contingencies and profit margins. In that respect committee may seek the reference of the guidelines of World Bank, AIIB, ADB etc.
- iii. Decide whether to accept or reject the tender.

(c) Additional Performance Security in case of acceptance of ALB:

- i. If any abnormally low bid is accepted under point no. (b) (iii), after taking of additional performance security as per the assessment of the committee, however the total performance security should not have to exceed 20% of the total contract value.
- ii. The additional performance security shall be treated as part of the original performance security and shall be valid for a period coextensive with the applicable defect liability period of the contract.
- iii. Non submission of the additional performance security shall constitute sufficient ground to rejection of the bid and similar assessment shall be initiated for the next ranked bidder identified as ALB.

1.30.6 AEGCL reserves the right to accept or reject any variation or deviation. Variations, deviations, and other factors which are in excess of the requirements of the bidding documents or otherwise result in the accrual of unsolicited benefits to AEGCL shall not be taken into account in bid evaluation.

1.31.0 AWARD CRITERIA

1.31.1 AEGCL will award the Contract to the bidder whose bid has been determined to be the lowest substantially responsive bid provided that such bidder has been determined to be qualified in accordance with the provisions of the Bid. However, the AEGCL reserves the right to not award contract to the lowest substantially responsive bidder without thereby incurring any liability to Bidders

1.32.0 EMPLOYER'S RIGHT TO ACCEPT ANY BID AND TO REJECT ANY OR ALL BIDS

1.32.1 Notwithstanding Clause 1.31,0, AEGCL reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders of the grounds for AEGCL's action. AEGCL is not bound to accept the offer of the lowest bidder.

1.33.0 NOTIFICATION OF AWARD

1.33.1 Prior to expiration of the period of bid validity prescribed by AEGCL, AEGCL will notify the successful bidder by fax, confirmed by letter, that its bid has been accepted. This letter (hereinafter and in the Conditions of Contract called the "Letter of Acceptance") shall name the sum which AEGCL will pay the Contractor in consideration of the execution, completion and maintenance of the Works by the Contractor as prescribed by the Contract (hereinafter and in the Conditions of Contract called "the Contract Price").

1.33.2 The notification of award will constitute the formation of the Contract.

1.34.0 SIGNING OF CONTRACT AGREEMENT

1.34.1 At the same time that it notifies the successful bidder that its bid has been accepted, AEGCL will send the bidder the Form of Contract Agreement incorporating all agreements between the parties.

1.34.2 Within **15 (fifteen) days** of receipt of the Form of Agreement, the successful bidder shall sign the Form and return it to AEGCL.

1.35.0 WARRANTY

1.35.1 The contractor warrants that all goods are new, unused and of the most recent or current models, and that they incorporate all recent improvements in design and materials, unless provided otherwise in the Contract. The term period of warranty shall mean the period of **18 months** from the date of the materials are received at site in good and acceptable condition. If during the period of warranty, any defect is found, the Contractor shall rectify all defects in design, materials and workmanship that may develop under normal use of the equipment upon written notice from the Purchaser who shall indicate in what respects the equipment is faulty. The rectification / free replacement must be carried out within a reasonable time period and at free of cost.

1.35.2 In the event of any emergency, where in the judgment of AEGCL, delay would cause serious loss or damages, repairs or adjustment may be made by the engineer or a third party chosen by the engineer without advance notice to the contractor and the cost of such work shall be paid by the contractor. In the event such action is taken by the engineer, the contractor will be notified promptly and he shall assist wherever possible in making necessary corrections. This shall not relieve the contractor of his liabilities under the terms and conditions of the contract.

1.35.3 If it becomes necessary for the contractor to replace or renew any defective portions of the works, the provision of this clause shall apply to portion of the works so replaced or renewed until the expiry of eighteen (18) months from the date of such replacement or renewal.

1.35.4 The repaired or new parts will be furnished and erected free of cost by the contractor. If any repair is carried out on his behalf at the site, the contractor shall bear the cost of such repairs.

1.35.5 The acceptance of the equipment by the Employer shall in no way relieve the contractor of his obligation under this clause.

1.35.6 In the case of those defective parts, which are not repairable at site but are essential for the commercial operation of the equipment, the contractor and the engineer shall mutually agree to a programme of replacement or renewal, which will minimize interruption to the maximum extent in the operation of the equipment.

1.36.0 PERFORMANCE SECURITY (Contract Performance Guarantee)

1.36.1 As a Contract Performance Security, the successful Bidder, to whom the work is awarded, shall be required to furnish a Performance Guarantee from a Nationalized Bank, in the form attached with the Bidding Document (Section -5) in favour of the AEGCL. The guarantee amount shall be equal to ten percent (10%) of the Contract Price and it shall guarantee the faithful performance of the contract in accordance with the terms and conditions specified in these documents and specifications. The guarantee shall be valid up to 90 (ninety) days after the end of Warranty Period.

1.36.2 In case the bidder fails to submit the Performance Security in the form of Bank Guarantee, an amount equivalent to 10% of the Contract Price shall be retained as Security Deposits which shall be retained up to 90 (ninety) days after the end of Warranty Period

1.36.3 The performance guarantee shall cover additionally the following guarantees to the owner:

- a) The successful Bidder guarantees the successful and satisfactory operation of the equipment furnished and erected under the contract, as per the specifications and documents.
- b) The successful Bidder further guarantees that the equipment/material provided and installed by him shall be free from all defects in design, material and workmanship and shall upon written notice from the Owner fully remedy must be guaranteed.

1.36.4. The Contract performance Guarantee will be returned to the Contractor without any interest at the end of warranty period and written request from the contractor.

1.37.0 TERMS OF PAYMENT

The terms of payment for the supply and erection work shall be as follows

- i. No advance payment shall be made in this contract.
- ii. No claim for interest shall be entertained by AEGCL
- iii. The price is firm and no price variation shall be applicable.
- iv. Final bill must contain the original site register.
- v. Payment shall be made from the O/o the DGM. Lower Assam T&T Circle, AEGCL on delivery of the items in full and good condition and duly verified by the Site Engineer.
- vi. Payment shall be released subject to receipt of specific fund. The Bidder / Firm will have to be submitted the following Net Banking details.
 - a) Banker's Name & Branch
 - b) Account No
 - c) Banker's address
 - d) Banker's IFSC Code
 - e) Banker's RTGS Code

1.38.0 CORRUPT OR FRAUDULENT PRACTICES

1.38.1 It is required that bidders/suppliers/contractors observe the highest standard of ethics during the procurement and execution of the contracts. In Pursuance of this Clause AEGCL;

- (a) defines, for the purposes of this provision, the terms set forth below as follows:
 - (i) "corrupt practice" means behavior on the part of officials in the public or private sectors by which they improperly and unlawfully enrich themselves and/or those close to them, or induce others to do so, by misusing the position in which they are placed, and it includes the offering, giving, receiving or soliciting of anything of value to influence the action of any such official in the procurement process or in contract execution; and
 - (ii) "fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the Borrower, and includes collusive practice among bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the Borrower of the benefits of free and open competition;
- (b) will reject a proposal for award if it determines that the bidder recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question;
- (c) will declare a firm ineligible, either indefinitely or for a stated period of time, to be awarded a contract by AEGCL if it at any time determines that the firm has engaged in corrupt or fraudulent practices in competing for, or in executing, a contract.

1.39.0 PENALTY FOR DELAYED EXECUTION

In the event of delay in completing the work extending beyond the date of completion or beyond the extended date, if any, permitted by the Board, the contractor shall pay as agreed liquidated damage and not as a penalty a sum equal to 1% of the contract price under this contract for each week of delay or part thereof subject to a maximum of 10% of the contract price.

1.40.0 FORCE MAJEURE

Force Majeure shall be considered as any circumstances beyond the reasonable control of the party claiming relief, including but not limited to strikes lockout, civil commotion, riot, insurrection, hostilities, war, fire, flood, earthquake, delay in delivery of equipments or part thereof by AEGCL, would entitle contractor to extension of time.

1.41.0 SETTLEMENT OF THE DISPUTE & ARBITRATION

Any dispute arising out of the contract will first be discussed and settled bilaterally between the Assam Electricity Grid Corporation Limited and firms/ contractors. In case, the dispute cannot be settled bilaterally, it will be referred to arbitration by an arbitrator to be appointed by the AEGCL, The contractor shall not stop the work during settlement of any arbitration case. All disputes arising out of the agreement so made shall be subjected to the jurisdiction of district court of Kamrup District.

SECTION-2

PURCHASER'S REQUIREMENTS

2.1.0 SCOPE OF WORK:

- 2.1.1 This section of the specification deals with the technical information & criteria for "Procurement of 145kV, 2500A isolators along with all necessary hardware fittings/ accessories".
- 2.1.2 Arrangements of any permits required for transportation and movement of supplied materials. However, AEGCL shall assist as far as practicable in the process.
- 2.1.3 It is not the intent to specify completely herein all details of design and construction of the equipment and accessories. However, the equipment and accessories shall conform in all respects to high standards of engineering, design and workmanship and be capable of performing in continuous operation up to the bidder's guarantees in a manner acceptable to the Purchaser. The Purchaser will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material, which in his judgment is not in full accordance therewith.
- 2.1.4 The various items of supply are described very briefly in the schedule of Bid Form, Prices & Other Schedules and annexure. The various items as defined in these schedules shall be read in conjunction with the corresponding section in the technical specifications including amendments and, additions if any.

2.2.0 STANDARDS

- 2.2.1 The equipment covered under this bidding document shall, unless otherwise stated be designed, constructed and tested in accordance with the latest revisions of relevant Indian Standards and shall conform to the regulations of local statutory authorities. In case of any conflict between the standards and this specification, this specification shall govern.
- 2.2.2 Equipment conforming to other international or authoritative Standards which ensure equivalent or better performance than that specified under clause above shall also be accepted. In that case relevant extracts of the same shall be forwarded with the bid.

2.3.0 SERVICE CONDITIONS

The materials supplied shall be suitable for operation under the following climatic and other conditions:

- a) Peak ambient day temperature in still air: 45 °C
- b) Minimum night temperatures : 0 °C
- c) Ground temperatures: 40 °C
- d) Reference ambient day temperature : 45 °C
- e) Relative Humidity i). Maximum : 100 % ii). Minimum : 10 %
- f) Altitude : Below 1000 M above MSL
- g) Maximum wind pressure : As per IS: 802
- h) Seismic Intensity: ZONE-V as per IS 1893.

2.4.0 TESTS

- 2.4.1 The materials to be supplied shall be subjected to the tests before dispatch, in accordance with the relevant standards. Materials which have never been tested for critical performance, shall not be accepted

2.5.0 GUARANTEED TECHNICAL PARTICULARS

- 2.5.1 The Guaranteed Technical Particulars of the various items shall be furnished by the Bidders with the Technical Bid in the prescribed Schedules of the bidding document. The Bidder shall also furnish any other information's as in their opinion is needed to give full description and details to judge the item(s) offered by them.
- 2.5.2 The data furnished in Guaranteed Technical Particulars should be the minimum or maximum value (as per the requirement of the specification) required. A Bidder may guarantee a value more stringent than the specification requirement. However, for testing purpose or from performance point of view, the material shall be considered performed successfully if it achieves the minimum/maximum value required as per the technical specification. No preference what so ever shall be given to the bidder offering better/more stringent values than those required as per specification except where stated otherwise.

2.6.0 TECHNICAL PARTICULARS OF 132 kV ISOLATOR

2.6.1 SCOPE

This specification provides for design, manufacturer, testing at manufacturer's Works and delivery, supervision of erection, commissioning (if required) of outdoor station type 132KV Isolator with/ without earth switches, with electrical/ **mechanical** interlock, insulators and complete in all respect with bimetallic connectors arcing horns operating mechanism, auxiliary switches, indicating devices, fixing detail etc. as described hereinafter.

2.6.2 STANDARDS

Disconnecting switches covered by this specification shall conform to latest edition IEC-129/IEC 62271-102 I.S.1813 and IS: 9921, IS-325 and unless specifically stated otherwise in this specification.

2.6.3 TYPE

The 132 KV Isolators shall be outdoor type with centre break type/Pantograph type as required [Single(SI)/ Double(DI)] Isolators suitable for electrical as well as manual operation and local/ remote operation. They shall have crank and reduction gear mechanism.

All Isolators offered shall be suitable for horizontal upright mounting on steel structures. Each pole unit of the multiple Isolators shall be of identical construction and mechanically linked for gang operation.

Each pole of the Isolator shall be provided with two sets of contacts to be operated in series and the moving contact blades shall rotate in horizontal plane.

The design shall be such that the operating mechanism with the linkages shall be suitable for mounting on any of the outer pole ends without much difficulty and with minimum shifting of parts.

Moving contacts of all isolators shall rotate through 90 deg. from their "fully closed position" to "fully open position" so that the break is distinct and clearly visible from ground level.

The Isolators offered by the Bidder shall be designed for Normal rating current for Isolator as follows:

132kV
2500A

It should be suitable for continuous service at the system voltages specified herein. The Isolators shall be suitable to carry the rated current continuously and full short circuit current of 40 KA for 132KV respectively for 3 second at site condition without any appreciable rise in temperature. These shall also be suitable for operation at 110% rated (normal) voltage. The Isolators shall be suitable for Isolating low capacitive / inductive currents of 0.7amp at 0.15 power factor. The isolators shall be so constructed that they don't open under the influence of short circuit conditions.

The Isolators and earthing switches are required to be used on electrically exposed installation and this should be taken into account while fixing the clearance between phases and between phase and earth. so that de-energized isolator and earth switch also can be manually operated when the parallel circuit is energized.

2.6.4 MAIN CONTACTS

All Isolators shall have heavy duty, self-aligning and high-pressure line type **dust-free jaw** contacts made of high conductivity, corrosion resistant, hard-drawn electrolytic copper strips of proper thickness and contact area. Fixed contact should consist of loops of above copper strips suitable for 2000 Amps ratings for 132KV Isolators respectively. The hard drawn electrolytic copper strips should be silver plated 25micron thickness and fixed contacts should be backed by powerful phosphor bronze/stainless steel springs of suitable numbers. The main contacts should be preferably of tulip type design. However, the thickness and contact area of the contact should conform to the drawing approved during type test. Moving contact with moving arm should be of hard- drawn electrolytic copper of proper thickness and contact area.

These fixed and moving contacts shall be able to carry the rated current continuously and the maximum fault current of 40 KA for 132KV respectively for **3 seconds** without any appreciable rise in temperature. The Isolator blades shall retain their form and straightness under all conditions of operation including all mechanical stress arising out of operation as well as under rated short circuit condition.

Fixed guides shall be provided so that even when the blades are out of alignment, closing of the switches, proper seating of the blades in between contacts and adequate pressure to give enough contact surface is ensured. The contact shall be self-cleaning by the wiping action created by the movements of the blades.

The Isolator shall be self-cleaning type so that when isolators remain closed for long periods in a heavily polluted atmosphere, binding does not occur. No undue wear or scuffing shall be evident during the mechanical endurance tests, contacts and springs shall be designed so that adjustment of contact pressure shall not be necessary throughout the life of the isolator. Each contact or part of contacts shall be independently sprung so that full pressure is maintained on all contact at all times.

2.6.5 ARCING HORN AND GRADING HORN

Suitable arcing horn made of tinned electrolytic copper which are required for guiding contacts shall be provided on the fixed and moving contacts of all Isolators. The contacts shall be of "make before and break after" type. Aluminium alloy grading ring are to be provided for 132kV voltage level.

2.6.6 ELECTRICAL INTERLOCK / MECHANICAL INTERLOCK

The disconnecting switches whenever required shall be with an approved type electrical interlock for interlocking with the associated circuit breakers and earth switch.

Electrical interlock shall ensure reliable operation. The design should be such that the electrical circuit for the interlocking mechanism **will remain energised as per operation of the isolator with integrated earth switches.**

2.6.7 AUXILIARY SWITCHES

All isolators and earthing switches shall be provided with 110/220VDC auxiliary switches for their remote position indication on the control board and for electrical locking with other equipment. The auxiliary switch shall be provided with a minimum of six auxiliary contacts- 10 normally open and 10 normally closed and 10 normally open and 10 normally closed for earth switch. Separate auxiliary switches shall be provided for isolating and earth switches. 6 additional NO and NC contact to be provided as spare in each case.

The auxiliary switches and auxiliary circuits shall have a continuous current carrying capacity of at least 10 Amps. Auxiliary switches shall not be used as limit switches. Details of make, rating and type of limit switch shall be furnished in the offer.

2.6.8 EARTH SWITCH

Line earth switch shall consist of three earthing blades for Isolator which normally rest against the frame when the connected Isolator is in closed position. The earthing blades for three phases shall be mechanically linked to a coupling shaft which shall be capable of being fitted on either side of the Isolator. The earthing blades shall match and be similar to the main switch blades and shall be provided at the hinge; with suitable flexible conductors with terminal lugs for connecting to the station ground bus. The earthing blades shall be operated by a separate mechanism but shall be mechanically interlocked with the main switch so that the earthing blades can be closed only when the main switches are in open position and vice-versa. The earthing blades shall be gang operated and all the three blades will operate simultaneously.

2.6.9 OPERATING MACHANISM

The operating mechanism shall be simple and shall ensure quick and effective **10000** mechanical operation. The design shall be such as to enable one man to operate it with nominal effort. The operating mechanism box shall be made out of aluminium extruded (Aluminium alloy) sections of minimum 3.0 mm thickness. The operating mechanism shall be strong rigid and not subject to rebound.

The Isolator blades shall be in positive continuous control throughout the entire cycles of operation. The operating rods and pipes shall be rigid enough to maintain positive control under most adverse conditions and to withstand all torsional and bending stresses arising from operation. Operation of the switches at any speed should not result in improper functioning, in displacement of parts / machines after final adjustment has been made. All holes in cranks, linkages etc. having moving pins shall be fitted accurately so as to prevent slackness and lost motion.

Provision shall be made for padlocking the operating mechanism of disconnecting and earth switches in both open and closed positions.

Bearings shall be ball and roller type shall be protected from weather and dust by means of cover and grease retainers. Bearings pressures shall be kept low to ensure long life and care of operation.

Each power operated isolator shall be motor driven as well as manually operated and shall be complete with local / remote selector switch and open /close push buttons.

Provision shall be made in the control cabinet to disconnect power supply to prevent local / remote power operation. **Limit switches shall be provided with required number of contacts for isolators and earth switches.**

All the terminal blocks to be used in the operating mechanism should of **Ring type** of Poly-amide/Melamine material of make like Elmex/ Connect well.

2.6.10 DESIGN, MATERIALS AND WORKMANSHIP

The live parts shall be designed to eliminate sharp points, edges and corona producing surfaces. Where this is impracticable, adequate shields to be provided. All ferrous metal parts shall be hot dip galvanized, as per IS 2629. All metal parts shall be of such materials or treated in such a way so as to avoid rust, corrosion and deterioration due to continued exposure to atmosphere and rain. All current carrying parts shall be made from high conductivity electrolytic copper .

Bolts, screws and pins shall be provided with standard locking device viz. Locknuts, spring washers, keys etc. and when used with current carrying parts, they shall be made of copper silicon or other high conductivity and wear resistant alloys.

The **isolators** should not need lubrication of any parts except at very long interval of five year minimum.

2.6.11 PROTECTIVE COATINGS

All ferrous parts including bolts, nuts and washers of the switches assembly shall be galvanized to withstand at least six one minute dips in copper sulphate solution of requisite strength (Prece tests) except the threaded portions which should withstand four dips.

2.6.12 INSULATORS

Support insulators for all type of isolators shall be of solid core type. The insulator shall be made of homogeneous and vitreous porcelain of high mechanical and dielectric strength. It shall have sufficient mechanical strength to sustain electrical and mechanical loading on account of wind load, short circuit, **seismic** forces etc. Glazing of the porcelains shall be of uniform dark brown colour with a smooth surface arranged to shed away raise water. The porcelain shall be free from laminations and other flaws or imperfections that might affect the mechanical or dielectric quality. It shall be thoroughly vitrified, tough and impervious to moisture. The porcelain and metal ports shall be assembled in such a manner and with such material that any thermal differential expansion between the metal and porcelain parts throughout the range of temperature specified in this specification shall not loosen the parts or create under internal stresses which may affect the mechanical or

electrical strength or rigidity. The assembly shall not have excessive concentration of electrical stresses in any section or across leakage surfaces. The cement used shall not give rise to chemical reaction with metal fittings. The insulator shall be suitable for water washing by rain or artificial means in service condition. Profile of the insulator shall also conform to IEC-815. Caps to be provided on top of the insulator shall be of high-grade cast iron or malleable steel casting. It shall be machine faced and hot dip galvanized. The cap shall have four numbers of tapped holes spaced on a pitch circle diameter of 127mm. The holes shall be suitable for bolts with threads having anti corrosive protection. The effective depth of threads shall not be less than the nominal diameter of the bolt. The cap shall be so designed that it shall be free from visible corona and shall have radio interference level **as specified in table below** of Casing shall be free from blow holes cracks and such other defects.

2.6.13 CONTROL CABINET:

The control cabinet of the operating mechanism shall be made out of minimum 3mm thick aluminium alloy sheet. Hinged door shall be provided with pad locking arrangement. Sloping rain hood shall be provided to cover all sides. 15 mm thick neoprene or better type of gaskets shall be provided to ensure degree of protections of at least IP 55 as per IS 2147/IS-3947. The cabinet shall be suitable for mounting on support structure with adjustment for vertical, horizontal and longitudinal alignment. Details of these arrangements shall be furnished along with the offer.

2.6.14 MOTOR:

Motors rated 0.5 KW and above shall be **provided with** suitable for operation on 3 phase, 415 V, 50 Hz supply. Motors of lower rating shall be single phase type suitable for 240V, 50Hz system. It shall be totally enclosed type if mounted outside the control cabinet. The motor shall withstand without damage stalled torque for at least 3 times the time lag of the tripping device. The motor shall, in all other respects, conform to the requirement of I.S. 325. **Suitable relay/device shall be provided to prevent over loading of the motor. Single phase preventer (for 3 phase meter) shall be provided to operate on open circuiting of any phase and shall trip off the motor. Complete details of the devices shall be furnished in the offer.**

2.6.15 GEAR:

The dis-connector / isolator may be required to operate occasionally, with considerably long idle intervals. Special care shall be taken for selection of material for gear and lubrication of gears to meet this requirement. The gear shall be made out of aluminium bronze or any other better material lubricated for life with graphite or better-quality non-drawing and non-hardening type grease. Wherever necessary automatic relieving mechanism shall be provided.

2.6.16 SPACE HEATERS:

Space heaters suitable for 1 phase 240V AC supply shall be provided for each motor operated operating mechanism to prevent condensation and shall be operated by MCB.

2.6.17 TERMINAL BLOCK AND WIRINGS

Each operating mechanism shall be provided with 1100V grade **ring** type terminal block. All auxiliary switches, **spare contact of the contactors**, interlocks and other terminals shall be wired up to terminal block. The terminal block shall have at least 20% extra terminals. All wiring shall be carried out with 1.1KV grade **PVC** insulated 2.5 sq.mm. copper wires.

2.6.18 INTERIOR ILLUMINATION:

A holder suitable for a 240 V lamp shall be provided in each of the motor operated mechanism of three poles & shall be door operated type.

2.6.19 CONTROL AND AUXILIARY SUPPLY:

A 3-phase switch with MCB for phases and link for neutral, shall be provided for power supply and a 2 pole MCB shall be provided for control supply.

2.6.20 POSITION INDICATOR:

A position indicator to show the isolator is in ON or OFF position to be provided.

2.6.21 NAME PLATE:

Isolator, earthing switches and their operating devices shall be provided with name plate. The name plate shall be weatherproof and corrosion proof. It shall be mounted in such a position that it shall be visible in the position of normal service and installation. It shall carry the following information duly engraved or punched on it.

A. Isolator Base

Name: AEGCL

Name of manufacturer –

Order No. –

Type Designation –

Manufacturers serial No. –

Rated voltage –

Rated normal current –

Rated short time current (rms) and duration –

Rated short time peak current (KAP)
 Weight-
 Manufacturing Standard-

B. Earthing Switch

Name: AEGCL
 Name of manufacturer –
 Order No. –
 Type Designation –
 Manufacturers serial No. –
 Rated voltage –
 Rated normal current –
 Rated short time current (rms) and duration
 Rated short time peak current (KAP)
 Weight

C. Operating Device

Name – AEGCL
 Name of manufacturer –
 Order No.
 Type Designation –
 Reduction gear ratio –
 AC motor
 i) Rated auxiliary voltage
 ii) Starting current
 iii) Designation of AC motor as per IS 4722/325
 iv) Starting torque at 80% of supply voltage
 v) Over travel in degrees after cutting off supply
 Total operating time in seconds
 i) Close operation – Electrical
 ii) Open operation – electrical
 iii) Open operation – manual

2.6.21 PAINTING GALVANIZING AND CLIMATE PROOFING:

At interiors and exteriors of enclosures, cabinets and other metal parts (other than made up of aluminium) shall be thoroughly cleaned to remove all rust, scales, corrosion, grease and other adhering foreign matter and the surfaces treated by phosphating (e.g. seven tank phosphating sequence). After such preparation of surfaces, two coats of zinc oxide primer shall be given by suitable stoving and air drying before final painting **with epoxy paint**. Colour of the final paints shall be of shade no. 697 of IS:5. The finally painted cubicle shall present aesthetically pleasing appearance free from any dent or uneven surface.

Paint inside the metallic housing shall be of anti-condensation type and the paint on outside surfaces shall be suitable for outdoor installation.

All components shall be given adequate treatment of climate proofing as per IS:3202 so as to withstand corrosive and severe service conditions.

All metal parts not suitable for painting such as structural steel, pipes, rods, levers, linkages, nuts and bolts used in other than current path etc. shall be hot dip galvanized as per IS –2629. Galvanization test will be carried out during routine test.

Complete details of painting, galvanizing and climate proofing of the equipment shall be furnished in the offer.

2.6.22 TYPE AND RATING:

Sl no	Type:	132 kV
I	II	III
1	Main switch	Horizontal Centre Break
2	Service	Outdoor
3	Applicable standard	IS : 9921 / IEC-62271-102
4	No. of Phases	3 phase
5	Design Ambient temperature	50°C
6	Type of operation	Mechanically Ganged
7	Rated voltage (kV)	In KV
	a) Nominal	132
	b) Maximum	145
8	Rated current (Amps)	2500
9	Short time current for 3 sec.(kA)	40

Sl no	Type:	132 kV
I	II	III
10	Rated frequency	50 HZ + 5%
11	System earthing	Effectively earthed
12	Temperature rise	As per relevant IS/IEC standards
13	Lightening Impulse withstand voltage (kVp)	
	(a) Across Isolating distance	750
	(b) To earth	650
14	1-minute power frequency withstand voltage	
	a) Across Isolating distance	315
	b) To earth	275
15	Switching Impulse withstand voltage (kVp)	
	a) Across Isolating distance	-
	b) To earth	-
16	Max. RIV for frequency between 0.5MHz and 2MHz (micro-volt)	500 at 92kV
17	Corona Extinction Voltage (kV)	-
18	Operating mechanism	
	a) Isolator	Motor
	b) Earth switch	Motor
19	Auxiliary voltage	
	a) Control & Interlock	110/ 220V DC 80% to 110%
	b) Motor voltage	3 phase 415V AC 50Hz
	c) Heater, lamp & socket	Single phase 240V AC 50Hz
20	Safe duration of overload	
	150% of rated current	5 minute
	120% of rated current	30 minute
21	Minimum creepage distance of insulator (mm)	31mm/kV
22	Mounting structure	Tubular/ Lattice
23	Operating time	Less than 12 secs
24	Insulator Data	
	a) Bending Strength (kgf)	800
	b) Height (mm)	1500
	c) Bottom PCD (mm)	184
	d) No. of holes & hole dia.	4x18
	e) Top PCD	127
	f) No. of holes & hole dia.	4xM16
	g) Minimum creepage distance (mm) 31mm/kV	4495
25	Working clearance (live part to ground) (in mm)	4900
26	Phase Spacing (mm.)	3000
27	Minimum clearances (mm.)	
	a) Phase to Phase	1300
	b) Phase to earth	1300
	c) Sectional clearance	4000

2.6.23 TESTS:

Type Tests:

Isolators offered, shall be fully type tested as per the relevant standards. The Bidder shall furnish Three sets of the following valid type test reports for their different type of offered Isolators along with the offer. The AEGCL reserves the right to demand repetition of some or all the type tests in the presence of AEGCL's representative. For this purpose, the Bidder may quote unit rates for carrying out each type test and this will be taken during bid price evaluation, if required.

- a) short time withstand & peak withstand current test for Isolator & Earth Switch.
- b) power frequency (Dry & Wet), Lightening Impulse dry withstand Test
- c) Mechanical endurance Test
- d) IP-55 test
- e) **Seismic test**
- f) **Temperature Rise test**

During type tests the isolator shall be mounted on its own support structure or equivalent support structure and installed with its own operating mechanism to make the type tests representative. Drawing of equivalent support structure and mounting arrangements shall be furnished for Purchaser's approval before conducting the type tests.

The type tests shall be conducted on the isolator along with approved insulators and terminal connectors. Mechanical endurance test shall be conducted on the main switch as well as earth switch of one isolator of each type.

Acceptance and Routine Test:

All acceptance and routine test as stipulated in the relevant standards shall be carried out by the supplier in presence of Purchaser's representative.

Mechanical operation test (routine test) shall be conducted on isolator (main switch and earth switch) at the supplier's works as well as purchaser's substation site.

Immediately after finalization of the programme of type / acceptance, routine testing the supplier shall give sufficient advance intimation (clear 20 days advance intimation), along with shop routine test certificates, valid calibration reports from Govt. approved (**NABL**) test house for the equipment, instruments to be used during testing for scrutiny by the AEGCL to enable him to depute his representative for witnessing the tests. If there will be any discrepancies in the shop routine test certificates and calibration reports furnished by the firm then after settlement of the discrepancies only, purchaser's representative will be deputed for witnessing the tests. Special tests proposed to be conducted (if decided to conduct) as type test on isolators, are given at Annexure- II. These special type test charges shall be quoted along with all other type tests as per relevant IEC standard and these charges shall be included in the total bid price

Test certificates of various items including but not limited to the following shall be furnished at the time of routine tests.

- a) Chemical analysis of copper along with a copy of excise certificate indicating genuine source of procurement of electrolytic grade copper.
- b) Bearings
- c) Fasteners
- d) Universal / swivel joint coupling
- e) Insulators
- f) Motor
- g) Gears
- h) Auxillary switch
- i) Limit switch
- j) Timer
- k) Overload / single phase preventer relay
- l) Interlocking devices
- m) Terminal block
- n) Any other item

2.6.24 INSPECTION:

- i) The Purchaser shall have access at all times to the works and all other places of manufacture, where the disconnectors, earth switches and associated equipment are being manufactured and the supplier shall provide all facilities for unrestricted inspection of the works raw materials manufacture of all the accessories and for conducting necessary tests as detailed herein.
 - ii) The supplier shall keep the purchaser informed in advance of the time of starting of the progress of manufacture of equipment in its various stages so that arrangements could be made for inspection.
 - iii) No material shall be dispatched from its point of manufacture unless the material has been satisfactorily inspected and tested.
- b) The acceptance of any quantity of the equipment shall in no way relieve the supplier of his responsibility for meeting all the requirements of this specification and shall not prevent subsequent rejection if such equipment is later found to be defective.

2.6.25 QUALITY ASSURANCE PLAN:

The Bidder shall invariably furnish following information along with his offer, failing which his offer shall be liable for rejection.

- (i) Names of sub suppliers for raw materials, list of standards according to which the raw materials are tested, list of tests normally carried out on raw materials in presence of Supplier's representative, copies of test certificate
- (ii) Information and copies of test certificates as in (i) and (ii) above in respect of bought out accessories.
- (iii) List of manufacturing facilities available
- (iv) Level of automation achieved and lists of areas where manual processing still exists.
- (v) List of areas in manufacturing process, where stage inspections are normally carried out for quality control and details of such tests and inspections.
- (vi) List of testing equipment with calibration certificates from Govt. approved (**NABL**) test house available with supplier for final testing equipment and test plant limitation if any, vis-à-vis the type, special acceptance and routine test specified in the relevant standards. These limitations shall be very clearly brought out in the specified test requirements.
- (vii) QAP shall include acceptance criteria mentioning clause no. of applicable standard against each parameter.

The supplier shall within 30 days of placement of order, submit following information to the purchaser.

- i) List of raw material as well as bought out accessories and the names of sub-suppliers selected from the lists furnished along with offer.
- ii) Type test certificates of the raw material and both bought out accessories.
- iii) Quality Assurance Plan (QAP) withhold points for purchaser's inspection.

The supplier shall submit the routine test certificates of bought out accessories and raw material viz. Copper, aluminum conductors, lubricating material, gear material etc. at the time of routine testing of the fully assembled isolator.

2.6.26 DOCUMENTATION:

All drawings shall conform to relevant international standards organization (ISO). All dimensions and data shall be in S.I. Units.

List of Drawings and Documents

The Bidder shall furnish **four** sets of following drawings / documents along with his offer.

- a) General outline and assembly drawings of the dis-connector operating mechanism, structure, insulator and terminal connector.
- b) Sectional views and descriptive details of items such as moving blades, contacts, arms contact pressure, contact support bearing housing of bearings, balancing of heights, phase coupling pipes, base plate, operating shaft, guides, swivel joint operating mechanism and its components etc.
- c) Loading diagram
- d) Drawings with structure for the purpose of type tests.
- e) Name plate.
- f) Schematic drawing.
- g) Type test reports.
- h) Test reports, literature, pamphlets of the bought-out items and raw material.
- i) Deviation sheet/compliance sheet if applicable

Six sets of the type test report, duly approved by the Purchaser shall be submitted by the supplier for distribution, before commencement of supply Adequate copies of acceptance and routine test certificates, duly approved by the Purchaser shall accompany the dispatched consignment.

The manufacturing of the equipment shall be strictly in accordance with the approved drawings and no deviation shall be permitted without the written approval of the purchaser. All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawing shall be at the supplier risk.

The supplier shall within 2 weeks of placement of order submit four sets of final versions of all the above said drawings for AEGCL's approval. The purchaser shall communicate his comments / approval on the drawings to the supplier. The supplier shall, if necessary, modify the drawings and resubmit four copies of the modified drawings for AEGCL's approval within two weeks from the date of comments.

2.6.26 INSTRUCTION MANUALS:

Fifteen copies of the erection, operation and maintenance manuals in English to be supplied for each type of disconnector one month prior to dispatch of the equipment. The manual shall be bound volumes and shall contain all drawings and information required for erection, operation and maintenance of the disconnector including but not limited to the following particulars.

- (a) Marked erection prints identifying the component parts of the disconnector as shipped with assembly drawings.
- (b) Detailed dimensions and description of all auxiliaries.
- (c) Detailed views of the insulator stacks, metallics, operating mechanism, structure, interlocks, spare parts etc.

2.6.27 PACKING AND FORWARDING:

The equipment shall be packed in crates suitable for vertical / horizontal transport, as the case may be and suitable to withstand handling during transport and outdoor storage during transit. The supplier shall be responsible for any damage to the equipment during transit, due to improper and inadequate packing. The easily damageable material shall be carefully packed and marked with the appropriate caution symbols.

Wherever necessary, proper arrangement for lifting, such as lifting hooks etc. shall be provided. Any material found short inside the packing cases shall be supplied by supplier without any extra cost.

Each consignment shall be accompanied by a detailed packing list containing the following information:

- (a) Name of the consignee.
- (b) Details of consignment.
- (c) Destination.
- (d) Total weight of consignment.
- (e) Handling and unpacking instructions.
- (f) Bill of material indicating contents of each package.

The supplier shall ensure that the bill of material is approved by the purchaser before dispatch.

2.6.28 SUPERVISION OF ERECTION TESTING AND COMMISSIONING (ET&C):

Purchaser proposes to utilize the services of the supplier for supervision of testing and commissioning of the equipment being supplied by him, if it is required. For this purpose, the supplier should make available the services of trained personnel (Engineers) who shall correct in the field, any errors or omissions in order to make the equipment and material properly perform in accordance with the intent of this specification. The Engineer shall also instruct the plant operators in the operation and maintenance of the commissioned equipment. The supplier shall be responsible for any damage to the equipment on commissioning the same, if such damage results for the faulty or improper ET&C. Purchaser shall provide adequate number of skilled / semi-skilled workers as well as ordinary tools and equipment and cranes required for equipment erection, at his own expenses. Apart from the above, the Purchaser shall not be responsible for providing any other facilities to the supplier. Special tools if required for erection and commissioning shall be arranged by the supplier at his cost and on commissioning these shall be supplied to the purchaser free of cost for future use.

APPENDIX – I (Isolators)

LIST OF SPECIAL TESTS TO BE CARRIED OUT IF DECIDED BY THE PURCHASER

Sl.No.	Name of the Test	Standard to which it conforms.
1.	Test for visible Corona and Radio interference voltage (RIV) on disconnectors and terminal connector	NEMA Pub No. 107-1964 ISRI Pub No. 1-1972
2.	Tests on insulators	IS-2544 IEC. 168
3.	Tests on terminal connectors	IS:5561
4.	Tests on galvanized components	IS:2633
5.	Stalled torque test on motor operating mechanism	At 110% of supply voltage

SECTION – 3

BID SUBMISSION SHEET, BID FORMS AND SCHEDULES

1. Bid Submission Sheet

(To be submitted in Bidder's Letterhead)

Name of contract:

To,

The Deputy General Manager,
Lower Assam, T&T Circle, AEGCL,
Narengi. Guwahati-26

Sir:

We have examined the General Conditions of Contract, Technical Specification, Schedules, and Addenda Nos _____(if any). We have understood and checked these documents and have not found any errors in them. We accordingly offer to execute and complete the said Works and remedy any defects fit for purpose in conformity with these documents and the enclosed Proposal (Price Offer)

We accept your suggestions for the appointment of the Dispute Adjudication Board, as set out in the Bidding Document.

We agree to abide by this Bid until _____ and it shall remain binding upon us and may be accepted at any time before that date.

If our bid is accepted, we will provide the specified performance security, commence the Works as soon as reasonably possible after receiving the notice to commence, and complete the Works in accordance with the above-named documents within the time stated in the Bidding Document.

Unless and until a formal Agreement is prepared and executed this Bid, together with your written acceptance thereof, shall constitute a binding contract between us.

We understand that you are not bound to accept the lowest or any bid you may receive.

Commissions or gratuities, if any, paid or to be paid by us to agents relating to this Bid, and to contract execution if we are awarded the contract, are listed below:

Yours faithfully

Signature _____ in the capacity of _____ duly authorized to sign bids for and on behalf of

Address

2. Form-BG

Form of Bid Security (Bank Guarantee)

WHEREAS, _____ [Name of Bidder] (hereinafter called "the Bidder") has submitted his bid dated _____ [Date] for the construction of _____ [Name of Contract] (hereinafter called "the Bid").

KNOW ALL MEN by these presents that We _____ [Name of Bank] of _____ [Name of Country] having our registered office at _____ (hereinafter called "the Bank") are bound unto _____ [Name of Employer] (hereinafter called "the Employer") in the sum of _____ for which payment will and truly to be made to the said Employer the Bank binds himself, his successors and assigns by these presents. SEALED with the Common Seal of the said Bank this ___ day of _____ 20__.

THE CONDITIONS of this obligation are:

- (1) If the bidder withdraws his Bid during the period of bid validity specified in the Form of Bid:
Or
- (2) If the Bidder refuses to accept the correction of errors in his Bid;
Or
- (3) if the Bidder, having been notified of the acceptance of his Bid by the Employer during the period of Bid validity;
 - (a) fails or refuses to execute the Form of Contract Agreement in accordance with the Instructions to Bidders, if required; or
 - (b) fails or refuses to furnish the Performance Security, in accordance with the Instructions to Bidders;

we undertake to pay to the Employer up to the above amount upon receipt of its first written demand, without the Employer having to substantiate its demand, provided that in its demand the Employer will note that the amount claimed by it is due to it owing to the occurrence of one or all of the three conditions, specifying the occurred condition or conditions.

This Guarantee will remain in force up to and including the date 180 days after the deadline for submission of bids as such deadline is stated in the Instructions to Bidders or as it may be extended by the Employer, notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank not later than the above date.

DATE _____ SIGNATURE OF THE BANK _____

WITNESS _____ SEAL _____

(Signature, Name, and Address)

3. Form-MA

Form of Manufacturer's Authorization
(To be submitted in Manufacturer's Letterhead)

Bid No.:

To,
The Deputy General Manager,
Lower Assam, T&T Circle, AEGCL,
Narengi, Guwahati-26

WE *[insert: name of Manufacturer]* who are established and reputable manufacturers of *[insert: name and/or description of the Goods]* having production facilities at *[insert: address of factory]* do hereby authorize *[insert: name & address of Bidder]* (hereinafter, the "Bidder") to submit a bid the purpose of which is to provide the following goods, manufactured by us, and to subsequently negotiate and sign the Contract:

1. -----
2. -----
-

We hereby extend our full guarantee and warranty in accordance with **Clause 1.35.0** of the Special Conditions of Contract, for the above specified Goods supporting the Supply of specified Goods and fulfilling the Related Services by the Bidder against this Bidding Documents, and duly authorize said Bidder to act on our behalf in fulfilling these guarantee and warranty obligations. We also hereby declare that, we will furnish the Performance Guarantee in accordance with **SCC Clause 1.36.0**.

Further, we also hereby declare that we and, *[insert: name of the Bidder]* have entered into a formal relationship in which, during the duration of the Contract (**including related services and warranty / defects liability**) we, the Manufacturer or Producer, will make our technical and engineering staff fully available to the technical and engineering staff of the successful Bidder to assist that Bidder, on a reasonable and best effort basis, in the performance of all its obligations to the Purchaser under the Contract.

For and on behalf of the Manufacturer

Common Seal and Signature of the authorised person: Name:

Designation:

NOTE:

This MA should be signed by a person having either of the following-

- 1) Valid Power of attorney
- 2) Authorised by Managing Director
- 3) Member of Board of Directors

4. Guarantee Declaration

We declare that the ratings, specifications and performance figures of the various plants and equipment /material furnished by us in the Bid are guaranteed. We further declare that in the event of any deficiencies in meeting the guarantees in respect of the characteristics mentioned in Guaranteed Technical Particulars, of Technical Bid as established after conducting the factory test, you may at your discretion, reject or accept the equipment/material after assessing the liquidated damages as specified in relevant clause of Bid Document.

Date: (Signature).....

Place: (Printed Name).....

(Designation).....

(Common Seal).....

5. Self-Undertaking for Payment of Statutory Taxes

(To be submitted by the bidder)

To,

The Deputy General Manager,
Lower Assam, T&T Circle, AEGCL,
Narengi, Guwahati-26

Subject: Self-Undertaking regarding payment of statutory taxes before applying for tender

Tender/ Bid Reference No & Date: _____

1. I/ We have duly paid and cleared all statutory taxes, cess, dues, and levies payable to Local Authorities, Panchayats, Municipalities, State Government, and the Central Government up to the date of this tender submission and undertake to promptly discharge any such dues that may arise during the tenure of the contract.
2. I/ We shall be solely responsible for payment of all applicable taxes, including GST, duties, license fees, cess, and any other statutory liabilities arising in connection with the performance of the contract.
3. I/ We undertake to immediately inform the Procuring Entity of any statutory revision, demand, or default and shall bear complete responsibility for settlement of such dues, keeping the Procuring Entity fully indemnified against any liability in this regard.
4. I/ We hereby confirm that all notices, demands, or proceedings issued by any Tax Authority up to the date of this submission have been duly complied with and settled. Any outstanding demand has been disclosed to the Procuring Entity, and I/We undertake to settle the same before award of contract, keeping the Procuring Entity indemnified against any liability.
5. In case of any reduction in the rate or amount of GST, taxes, duties, or levies after the Notification of Award, the corresponding benefit shall be duly passed on to the Procuring Entity without delay.
6. This undertaking shall remain valid and binding for the entire duration of the tender evaluation and, if awarded, for the full tenure of the contract including any extensions, until its closure.
7. I/ We understand that at any stage, if it is found that any statement or document submitted is false/forged/invalid, the Procuring Entity has discretion to terminate the contract and proceed with alternate arrangements as per the tender's risk purchase clause if any.

I/ We declare that the above statements are true to the best of my/our knowledge and belief.

Authorized Signatory

Name: _____

Designation: _____

Firm/Company Name: _____

Date: _____

Place: _____

Company Seal: _____