



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520

Web: www.aegcl.co.in




## Corrigendum-II

**BID IDENTIFICATION NO:  
AEGCL/MD/CGM(O&M)/SS/Salakati/2020/BID**

As per queries received from prospective bidders for the work namely "Supply, erection, testing and commissioning of 145kV Isolators at 220kV Salakati Grid Substation, AEGCL" against Bid Identification No. mentioned above, the following clarifications/modification may be noted: -

SI No.	Queries	Clarification/Modification
1	Technical Specification, Clause No.3.3	The Moving Blade Arm shall be of copper.
2	Technical Specification, Clause No.3.9	All current carrying parts shall be made from high conductivity electrolytic copper.
3	Technical Specification, Clause No.3.28	Along with the Erection, Testing and Commissioning, Supervision of the work shall also be in the scope of the bidder.
4	Technical specification, Appendix-I, SI. No. 1	The clause is omitted.

All other terms and conditions of the bidding document remain same.

  
12/8/22  
Chief General Manager (O&M), LAR  
AEGCL, Paltan Bazar, Guwahati-01

Memo No- AEGCL/MD/CGM(O&M)/SS/Salakati/2020/59

Dtd : 12 .08.2022

Copy to :

1. The DGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website.  
( Soft copy enclosed)
2. Ref. file.

  
12/8/22  
Chief General Manager (O&M), LAR  
AEGCL, Paltan Bazar, Guwahati-01