

## ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001 CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3



PHONE: 0361-2739520

Web: www.aegcl.co.in

#### Corrigendum-I

### BID IDENTIFICATION NO: AEGCL/MD/Tech-309/O&M(LAR)/NDCP/33KV Feeder Sishugram)/ Bid(R)

With reference to the above bid document for the work namely "Turnkey construction of 33kV Feeder Bay along with associated works at 132kV Sishugram GSS for power supply to National Data Centre" against Bid Identification No. mentioned above, standard drawings have been uploaded.

All other terms and conditions of the bidding document remain same.

Chief General Manager (O&M), LAR Assam Electricity Grid Corporation Ltd Bijulee Bhawan, Guwahati – 1

Memo No. – AEGCL/MD/Tech-309/O&M(LAR)/NDCP/33KV Feeder Sishugram)/ Part-I/9 Dtd: 19.03.2024

1

Copy to:

- The DGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website. (Soft copy enclosed)
- 2. Ref. file.

Chief General Manager (O&M), LAR Assam Electricity Grid Corporation Ltd Bijulee Bhawan, Guwahati – 1

# CABLE TRENCH



APPVD. BY



DRG. NO. :

NES/AEGCL/SISHUGRAM/CBT/01

DATE : 01.10.23

























_ /	Nestech Entern	rise				G	STIN: 18E	BJPK1159Q1ZY	nterprise		
	Nestech Enterprise							estechenterpri	se.com	com	
	House No 116,0pposite Relian Smart,Jayanagar, Guwahati	ce				r M	hatsapp:	6026801607	09331		
EART	HING MAT DESIGN FOR 33 K	BAYEXTEN	ISION AT 132/33	KV SISHUGRAM	SS						
As per ANSI/	EEE Std 80-1986 code	athed as mad	ified by Cuerry to in	-lude the effect of	a authing a si	d depths					
	$a\left[\frac{1}{1+\frac{1}$			icidde the effect of	earching grid	a depair.					
Whore B	$P \left[ L_T + \sqrt{20A} \left( \begin{array}{c} 1 + 1 + 1 \right) \right]$	$h\sqrt{20/A}$	]								
ρι Γ	s the soil resistivity $(\Omega,m)$	respect to re	mote earth (32)								
	is the total length of burled condi-	earthing grid (»	r²)								
rho	ohm-m			1	20		Grid Param	1st	2nd		
LT	Total Length buried grid (m)				245.00		L	25.0	0.0		
A	Area (sq.m.)				500		w	20.0	0.0		
n	Depth of grid (m)				0.6		spacing	245.00	- 0.0		
First Term			0.0041				Area	500	0	1	
Second term	minator		0.0100				L/R Patio	1.25			
Sid term denc			1.1200				No of Paral	lel grid Conductors	in Columns =	-	6.
Rg Prilim	ohm		0.4602				No of Paral	lel grid Conductors	in rows =		5.
Schwarz Equ	Jations $R_1 R_2 - R^2$										
Rg where	$= \frac{1}{R_1 + R_2 - 2R_m}$ $R_g \text{ is the earthing grid resist.}$	ance with res	pect to remote e	arth (53)							
	$R_1$ is the earth resistance of $R_2$ is the earth resistance of $R_m$ is the mutual earth respective earth resistance of $R_m$ is the mutual earth respective	the grid con the earthing tance betwe	electrodes (Ω) en the grid cond	uctors and earth	ing electro	des (Ω)					
Where											
P	$-\frac{\rho}{\ln\left(\frac{2L_c}{2L_c}\right)}$	$+ \frac{k_1}{k_1}$	$L_c = k_c$	1							
141	$\pi L_c [ a' ]$	/ ~	$A$ $^{n_2}$			_					
$R_2$	$= -\frac{\rho}{\ln(4)}$	$\left(\frac{L_r}{L_r}\right)$ –	$1 + \frac{2k_1L}{2k_1L}$	$\frac{1}{2}\left( \sqrt{n_{T}} - \right)$	$(1)^2$						
	$2\pi n_r L_r \lfloor ($	0 /	$\sqrt{A}$	7	<u> </u>						
$R_{\eta}$	$n = \frac{\rho}{-L} \ln \left( \frac{2L_c}{L} \right)$	$) + \frac{k_1}{k_1}$	$\frac{L_c}{L_c} - k_2 + $	- 1							
	$\pi L_c \downarrow \downarrow L_\tau$		A	:							
rho	soil Peristivity ( Ohm -meter)			20		GLEIat	L (mm)	65			
LC	Length of buried earthing electrode			245.00			B (mm)	12	• •		
<i>c</i> ′	is sqrt(r 2h) for conductors of										
u	radius r buried at depth h r for conductors on surface			0.138		Grid conduct	or size (mm	2)	/80		
h	Conductors Buried at depth (m)			0.6		Effective Rad	lius (mm)		15.8		
r	Cross Sectional radius of earth conduct	or (m)		0.016		Effective rad	ius (m)		0.016		
Lr	Length of each earthing Electrode ( M	ts)		3		Required Gri	l d Conductor	Size(Sq mm)	204.0047		
nr	Number of Earthing Electrodes in Are	a		9							
b K1	Cross Sectional radius of earthing Electr	ode (m) id		0.02		sart(A)/10	2.24				
KI	For $h = 0$	k1 = -0.04L/R + 1	.41	1.36		sqrt(A)/6	3.73				
	For $h = sqrt(A)/10$	k1 = -0.05L/R + 1	.2	1.1375							
k2	Constant Cofficienct Depending on Gr	id	.15	4.805							
	For h = 0	k2 = 5.5 + 0.15L/	R	5.6875							
	For h = sqrt(A)/10 For h = sqrt(A)/6	$k^2 = 4.68 + .10 L/$ $k^2 = 4.4 + 0.05 L/$	rR R	4.805							
	i or in square we	112 111 01052									
R1 is earth gri	d resistance (ohm)										
Rm is mutual	earth resistance (ohm)										
								Ω			
04	1st Term	2nd Term	3rd Term	4th Term	5th Term		0.442				
R2	0.026	6.397	- 12.463	- 4.805	4.000		0.412				
Rm	0.026	2.590	12.463	- 3.805			0.292				
			Nr	Dr							
		Rg	0.236	0.607		0.388	L				
	0.00(1 P)						+				
$C_s = 1 -$	$-\frac{0.09\left(1-\frac{1}{\rho_s}\right)}{0l}$						+				
	$2h_s + 0.09$			1			E				
rho is soil rosi	stivity (ohm-m)					20	┢				
rho-s is resitiv	ity of surface layer material (ohm-m)			<u> </u>		3000			_		
hs is thickness	of surface layer (m)					0.18	<b> </b>	For Tend	ler Refei	rence P	urpose on
Cs is surface la	aver derating factor					0.801	F				
Numerator	Denominator						F				
0.0894	4 0.45	ļ	ļ	ļ	0	116	F				
= 50k	g person: $E_{touch}$	5,50 =	(1000 +	$-1.5C_{s\rho}$	$(s) \frac{0}{1}$	110					
= 704	a person: E.		(1000 -	1.5C	0.	157					
	- Diouci	2,70	(1000 +	1.00 sp	s) v	$t_s$					
Fault Clearing	time	Ts				0.15	F				
Etouch 50		First Term	2nd Term			1 270 5	+				
Etouch,70		4,606	0.405372257	7		1,867.1					
Maximum Fau	It Current (Amps)					25000			Ι	Τ	_
Current Divisi	on Factor (Sf)					0.52					
						0.52					
		L									

	Decrement Fact	tor for 30 Cycles i.e. 0.5 Sec As per IEEE					1.00		As per IEEE Std 80			
	Stad 80 Clause	15.10	16				42002				I	
	symmetrical gr	id current ( Amps )	If x Sf x Df				13082		As per IEEE Std 80	( 1 transmissi	ion line , 1	feeders )
	GPR						5077.1		Sf	0.91+j0.485	As per Tab	le C.1
	If GPR > Etouch	then detailed verification is required							Nr	1.0311765		
		then detailed vernied for is required							Dr	1.9706154		
	Mesh Volta	ge Calculation :							-			
	The mesh volta	age is the maximum touch voltage with	nin a mesh of an	earthing grid and is deri	ved from IEEE Std 8	0 Equation 80:			St	0.523		
	ρ	$K_m K_i I_G$			-							
	$E_m = \frac{r}{2}$	$L_M$	Em ( v )		715.29							
	rho-s	soil Resistivity ( Ohm -meter)			20							
	I <sub>G</sub>	is the maximum grid current found ea	rlier in Step 4 (A)	)	13081.9							
	Km V.	geometric spacing factor			0.508							
	L <sub>M</sub>	effective buried length of the grid			289.937							
	Geometric Sp	acing Factor						1st term	2nd term			
	D	spacing between parallel grid conduct	ors (m)		5			5.000	5.000			
	h	depth of buried grid conductors (m)	ductor (m)		0.600							
	u Kh	weighting factor for depth of burial			1.265							
	Kii	weighting factor for earth electrodes /	ods on the corne	r mesh	1.000							
		Kii=lfor grids with earth elec	trodes along th	e grid perimeter or	corners							
		$K_{ii} = rac{1}{2n^{n/2}}$	for grids with no	earth electrodes on the	e corners or on the pe	erimeter						
	The cose	netric spacing factor V	s calculated	from IEEE Std 9	0 Equation 94							
	me geon					1		1st term	2st term	3st term	4st term	5st term
	$K_m =$	$=\frac{1}{2\pi}\left(\ln\left \frac{D^2}{16h\times d}+\frac{D^2}{16h\times d}\right +\frac{D^2}{16h\times d}\right)$	$\frac{(D+2n)^2}{8D \times d}$	$-\frac{h}{Ad} + \frac{K_{ii}}{K_{ii}}$	$-\ln \frac{8}{\pi(2n-1)}$	<u>.                                    </u>		82.63545	1.602	-4.76	0.79	-1.497606455
	_		OD × a	Ha An	L #(2 <i>n</i> - )	·///		4.375472		-1.1839619		
								1075172		1.1005015		
	Km	0.5079										
	Geometric Fa	ctor (n)	C 102									
	$n = n_a$	$\times n_b \times n_c \times n_d$	6.193									
	Na	2Lc/Lp	7.00									
	Nb Nc	1 for Sqaure, Sqrt(Lp/4*Sqrt(A)) 1 for Sqaure and Rectangular Grid	0.88									
	Nd	1 for Sqaure and Rectangular Grid	1									
	total length of l	horizontal grid conductors (m)		10	245							
	length of grid c	conductors on the perimeter (m)		Lp	70							
	maximum leng	th of the grids in the x direction (m)		Lx	25							
	Maximum leng	ance b/w any two points		Ly Dm	7.071			ļ	I	l	I	I I
	Irregularity Fa	actor										
	The irregularity	/ factor is calculated from IEEE Std 80	Equation 89:									
	K i	0 644+0 148n	1 560508039									
	N1								For Tende	r Refere	nce Pu	rpose only
	Effective Buri	ed Length (Lm) ith few or no earthing electrodes (and r		or along the perimeter):								
		and in the caluling electrodes (and i	IONE ON COMPLEX (									
	LM	Lc+LR	272									
	vvnere LC	total length of horizontal grid conducto	rs (m)		245							
	LR	the total length of earthing electrodes	/ rods (m)		27			]				
	For grids wi	th earthing electrodes on the corners	and along the per	imeter:								
	L	[ /	<u>\</u> ]									
	$L_M =$	$L_c + 1.55 + 1.22$		R								
		$\int \sqrt{L_x^2}$	$+L_y^2$									
	LM	289.9			1st term	2nd term						
	Otor: M. H	ne Oslaulation			1.22	0.09						
	The maximum	allowable step voltage is calculated fro	Dm IEEE Std 80 F	Equation 92:								
		K.K.Ic		,								
	$E_s = \frac{P}{2}$	Ls	Es	755.106								
	I <sub>G</sub>	is the maximum grid current found ea	I Irlier in Step 4 (A)	)								
	Ks	geometric spacing factor										
	Geometric Sp	acing Factor	Equation 91 is		botwoor 0.05m	d 2 5m-						
	The geometric	apacing racion based on IEEE Std 80	⊑quau011 o 1 ls ap		is between 0.25m an	a 2.011.						
	'	$K_s = \frac{1}{1} \left[ \frac{1}{1} + \frac{1}{1} + \frac{1}{1} \right]$	$+\frac{1}{n}(1-0.1)$	$5^{n-2})$								
		$\pi \lfloor 2h  D+h$	D	· · · · · ·								
		Ks	0.3823		1st term	2nd term	3rd term	4rd term				
I					0.318309886	0.833333333	0.17857143	0.18906				

Effective Buried Length       Image: constraint of the second seco																
The effective buried length Ls for all cases can be calculated by IEEE Std 80 Equation 93:         1.s       0.75 LC + 0.85 LR       206.7         • 50Kg person: $E_{step,50} = (1000 + 6C_s \rho_s)$ $\frac{0.116}{\sqrt{t_s}}$ 0.157         • 70Kg person: $E_{step,70} = (1000 + 6C_s \rho_s)$ $\frac{0.157}{\sqrt{t_s}}$ 0.157         • 1       Estep,70       6252.46       0.299510712       0.40537226         • Estep,70       6252.46       0.299510712       0.40537226       0.157         • Allowable Touch Voltage Limit (Estep,50) · V       1379.55       0.157       0.157         • Allowable Step Voltage Limit (Estep,70) · V       1379.55       0.157       0.157         • Estep,70       6252.46       0.197       0.197       0.197         • Allowable Step Voltage Limit (Estep,70) · V       1379.55       0.100000000000000000000000000000000000		Effective Buri	ied Length													
$\begin{array}{ c c c c c c c c c c c c c c c c c c c$		The effective b	ouried length Ls for all cases can b	e calculated by IEEE	Std 80 Equation 93:											
I.s       0.75 LC + 0.85 LR       206.7         • 50kg person: $E_{step,50} = (1000 + 6C_s \rho_s) \frac{0.116}{\sqrt{t_s}}$																
$\begin{array}{ c c c c c c } \hline & & & & & & & & & & & & & & & & & & $		İs	0.75 LC + 0.85 LR	206.7												
• 50kg person: $E_{stcp,50} = (1000 + 6C_s \rho_s) \frac{0.116}{\sqrt{t_s}}$ • 70kg person: $E_{stcp,70} = (1000 + 6C_s \rho_s) \frac{0.157}{\sqrt{t_s}}$ • 70kg person: $E_{stcp,70} = (1000 + 6C_s \rho_s) \frac{0.157}{\sqrt{t_s}}$ • 1st term 2nd term 1st te		25														
• 50kg person: $E_{step,70} = (1000 + 6C_s \rho_s) \frac{1}{\sqrt{t_s}}$ • 70kg person: $E_{step,70} = (1000 + 6C_s \rho_s) \frac{0.157}{\sqrt{t_s}}$ • 70kg person: $E_{step,70} = (1000 + 6C_s \rho_s) \frac{0.157}{\sqrt{t_s}}$ • 1st term 2nd term 1st term 2		_	F (1000	0.116												
$\begin{array}{                                    $		- 50Kg	g person: $E_{step,50} = (1000 -$	$+ 6C_s \rho_s) \frac{1}{\sqrt{t_s}}$												
• 70kg person: $E_{step,70} = (1000 + 6C_s\rho_s) \sqrt{t_s}$ • 1st term 2nd term 1 Estep.50 4619.65 0.299510712 0.40537226 0.299510712 0.4053726 0.299510712 0.29751000000000000000000000000000000000000		_		0.157												
IntervalInterv		– • 70kg	g person: $E_{step,70}=(1000$ –	$+6C_s\rho_s)$ $-/t$												
Ist termIst termInt te				Ves												
Estep,504619.650.2995107120.40537226Estep,706252.46000Results0000Allowable Touch Voltage Limit (Etouch,50) · V1379.5500Allowable Touch Voltage Limit (Etouch,70) · V1379.5500Allowable Step Voltage Limit (Etouch,70) · V1379.5500Allowable Step Voltage Limit (Etouch,70) · V1367.1400Allowable Step Voltage Limit (Estep,70) · V4619.6500Allowable Step Voltage (Em)715.28700Tolerable Step Voltage (Em)755.10600• $E_m < E_{touch}$ , andA < B							1st term	2nd term								
InterpolInterpolEstep,706252.46ResultsInterpolAllowable Touch Voltage Limit (Etouch,50) - V1379.55Allowable Touch Voltage Limit (Etouch,70) - V1867.14Allowable Step Voltage Limit (Estep,50) - V4619.65Allowable Step Voltage Limit (Estep,50) - V6252.46Tolerable Step Voltage (Em)715.287Allowable Step Voltage (Em)715.287CInterpolInterpole Step Voltage (Es)755.106Interpole Step Voltage (Es)C < D			Esten 50	4619.65			0 299510712	0 40537226								
Results       Image: Construct of the second			Estep 70	6252.46			0.255510712	0.10557220								
Results       Image: constraint of the second			25(25)/0	0202.10												
Allowable Touch Voltage Limit (Etouch,50) · V       1379.55       Image: Constraint of the second s		Results														
Allowable Touch Voltage Limit ( Etouch, 70) - V       1379,55         Allowable Touch Voltage Limit ( Etouch, 70) - V       1867,14         Allowable Step Voltage Limit ( Estep, 50) - V       4619,65         Allowable Step Voltage Limit ( Estep, 70) - V       6252,46         Tolerable Touch Voltage (Es)       715,287         Tolerable Step Voltage (Es)       755,106 $\bullet$ $E_m < E_{touch, \cdot}$ and $\bullet$ $E_s < E_{step}$ C < D																
Allowable Touch Voltage Limit (Etouch, 70) · V       1867.14         Allowable Step Voltage Limit (Estep, 50) · V       4619.65         Allowable Step Voltage Limit (Estep, 70) · V       6252.46         Tolerable Touch Voltage (Em)       715.287         Tolerable Step Voltage (Es)       755.106         • $E_m < E_{touch}$ , and         • $E_s < E_{step}$ C < D		Allowable Tou	h Voltage Limit ( Etouch.50) - V	1379.55				l		4						
Allowbale Step Voltage Limit (Estep, 50) · V       4619.65         Allowable Step Voltage Limit (Estep, 70) · V       6252.46         Tolerable Touch Voltage (Em)       715.287         Tolerable Step Voltage (Es)       755.106         • $E_m < E_{touch}$ · and       A< <b< td="">         • <math>E_s &lt; E_{step}</math>       C &lt; D</b<>		Allowable Touc	ch Voltage Limit ( Etouch,70 ) - V	1867.14												
Allowable Step Voltage Limit (EStep, 70) - V       6252.46         Tolerable Touch Voltage (Em)       715.287 A         Tolerable Step Voltage (Es)       755.106 C         • $E_m < E_{touch}$ , and       A < B		Allowbale Step	Voltage Limit (EStep,50) - V	4619.65												
Tolerable Touch Voltage (Em)       715.287       A         Tolerable Step Voltage (Es)       755.106       C         • $E_m < E_{touch.}$ and       A < B		Allowable Step Voltage Limit (EStep.70) - V			6252.46											
Tolerable Step Voltage (Es)       755.106       C         • $E_m < E_{touch}$ , and       A < B		Tolerable Touch Voltage (Em)			A											
• $E_{m} < E_{touch, \cdot}$ and       A < B		Tolerable Step Voltage (Es)			С											
• $E_m < E_{touchand}$ A < B	1															
		• $E_m < E_{touch}$ , and A														
Allowable Step Voltage (Estep), 50 kg     1379.55     B       Allowable Touch Voltage (Etouch), 50 kg     4619.65     D       then the earthing grid design is safe.     Image: Comparison of the same set of the sa		• <i>E<sub>s</sub></i> < <i>E<sub>step</sub></i> C<						FO	riend	er Reference	Purpos	e only				
Allowable Step Voltage (Estep), 50 kg     1379.55     B       Allowable Touch Voltage (Etouch), 50 kg     4619.65     D       then the earthing grid design is safe.     Image: Constraint of the same safe.     Image: Constraint of the same safe.       For Step     Hence Earthing Design is Safe     Image: Constraint of the same safe.       For Touch     Prepared and Submitted by:																
Allowable Touch Voltage (Etouch), 50 kg 4619.65 D		Allowable Step Voltage (Estep), 50 kg 137			В											
Image: the the earthing grid design is safe.     Image: the earthing grid design is safe.       For Step     Hence Earthing Design is Safe       For Touch     Image: the earthing grid design is safe.		Allowable Touc	ch Voltage (Etouch), 50 kg	4619.65	D											
Item the earthing grid design is safe.       For Step       Hence Earthing Design is Safe       Prepared and Submitted by:																
For Step     Hence Earthing Design is Safe       For Touch     Prepared and Submitted by:	1	then the earthi	ing grid design is safe.													
Prepared and Submitted by:	For Step		Jonco Earthing Dosign is	Safa												
Prepared and Submitted by:	For Touch		lence Latting Design is	Sale												
Hourde	Prepared and S	Submitted by:														
Mrityunjoy Buragohain NFKTECH ENTERDRISE	Mrityunjoy Bura	agohain														

### EARTHING LAYOUT OF 132/33 KV SISHUGRAM SS



