

Wall Mounted RTU Panel details for Gateway (if applicable)

1. Redundant RTU with redundant power supply to be provided:
 - ETH Port: 10 No.
 - RS-485 Port: 2 No.
 - RS-232 Port: 2 No.
2. PS SPD-2 Nos.
3. Required MCBs to be provided by the contractor
4. UPS Auxiliary power supply: 220V AC
5. Power supply: 110-220V DC for RTU
6. The system shall be mounted in wall mounting panel duly wired with required terminals.
7. CAT 6 to be provided by the contractor as per site condition
8. RJ45 Connector to be provided by the contractor as per site condition