



ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001
CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520

Web: www.aegcl.co.in

Corrigendum-I

BID IDENTIFICATION NO: AEGCL/MD/CGM(UAR)/132KV NZR-TEOK/Insulators/2026/BID

The following points may be noted for the work namely “**Replacement of tension disc insulator strings at the tension towers of 132KV Nazira-Teok S/C Transmission line from Nazira GSS gantry to Loc. No. 115**” against Bid Identification No. mentioned above –

1. Clarification:

The hardware fittings included with the supply of disc insulator strings are: D-shackles with clevis pin, Ball eye fitting, socket eye for disc fitting and W or R clips only. The tension clamps or dead-end clamps are not required, as the existing conductor, along with the tension clamps, will be fitted to the newly replaced disc insulator strings.

2. Amendment to Critical Dates:

The tender submission end date and techno-commercial bid opening date is amended as below:

Tender submission end date and time- 12:00 Hrs., 25th June, 2026

Techno-commercial bid opening date and time- 14:00 Hrs., 26th June, 2026

All other terms and conditions of the bidding document remain same.

Sd/-

Chief General Manager (O&M), UAR
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati – 1

Memo No.: AEGCL/MD/CGM(UAR)/132KV NZR-TEOK/Insulators/2026/08

Dtd: 20.06.2026

Copy to:

1. The DGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website.
2. Ref. file.

Sd/:

Chief General Manager (O&M), UAR
Assam Electricity Grid Corporation Ltd
Bijulee Bhawan, Paltanbazar, Guwahati – 1