



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN,

PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

Minutes of the Pre-Bid Meeting against "Procurement of one no. of 160MVA Transformer at 220 kV Salakati GSS, AEGCL alongwith associated works"

Minutes of the Pre-Bid Meeting held on:	21.07.2024 at the O/o the Managing Director, AEGCL, 1 st Floor, Bijulee Bhawan, Paltanbazar, Guwahati-01
BID No:	AEGCL/MD/Tech-1163/Salakati/160 MVA Transformer/2025/Bid
NIT No:	AEGCL/MD/Tech-1163/Salakati/160 MVA Transformer/2025/06 dated: 07/07/2025

Members present:

A. From Purchaser(AEGCL):

1. Chief General Manager (PP&D)
2. Deputy General Manager (NEAP)
3. Assistant General Manager -VI (NEAP, PP&D), AEGCL
4. Assistant Manager, HQ, AEGCL

B. From Prospective Bidders (Representatives of the following Bidders were present in the Pre-Bid Meeting):

1. M/s Techno Power Ltd.
2. M/s Hi-Tech Corporation

Opening Remarks in the Meeting:

CGM (PP&D), AEGCL extended a warm welcome to all the prospective bidders and introduced her team. CGM (PP&D), AEGCL explained the project's scope and requested the prospective bidders to table their queries. CGM (PP&D), AEGCL assured the prospective bidders that comprehensive reply/clarifications shall be prepared and uploaded in the AEGCL site as well as e-tender portal in response to their raised queries on the bid document.

MEMBERS OF THE PRE-BID COMMITTEE:

1. The Chief General Manager, PP&D
2. The Chief General Manager, (O&M), LAR
3. The General Manager, NEAP, PP&D
4. The General Manager, Civil
5. The Deputy General Manager, NEAP
6. The Deputy General Manager, F&A
7. The Assistant General Manager- VI, NEAP
8. The Deputy Manager, NEAP
9. The Assistant Manager, NEAP

The following queries raised by the prospective bidders were discussed by the Pre-Bid Committee and the observations/responses made are as follows:

1. The queries raised by M/s Hitech Corporation and the corresponding response of AEGCL are as follows:

Sl. No.	Tender/Clause Description	Bidder's Query	AEGCL's response
1	Form FCT 1	Please confirm whether required only for Transformer or all other equipments	The from FCT 1 is mandatory for Transformer and CT
2	Transformer Specifications	Transformer Specifications requires following Testing equipments Makes but not mentioned in the with respective BOQ a. BDV b. Oil Storage Tank c. Stainless Steel Oil Sampling Bottles	Shall be as per the BOQ

ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN,

PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

		d. Syringes for Sampling Oil Please confirm whether these equipments are required to be supplied	
3	Completion Time	Completion time as per Bid is 12 months Request AEGCL to amend it to 18 months considering the requirement of continuous shut down required to commence the work, delivery time of major equipments like Transformer, Circuit Breakers, CRP, Bus Post Insulators etc. as offered by all major manufacturers in the country	Accepted Addendum The APPENDIX TO ITB - 2, clause 1.2.2 is amended to be read as "Time to complete Works from the Commencement Date specified in Article 3 of the Contract Agreement for determining time for completion of the works is 18 months. Bids not meeting the above time schedule shall be rejected. However, no credit will be given for earlier completion."
4	Payment Terms	Request for Amendment of Payment Terms Request AGCL to amend the Supply Payment terms to 80% against supply instead of 60% as huge capital blockage is observed due to non-completion of the work due to availability of Shutdown at site	The payment terms shall be as per the bid document. However, any change of rules in AEGCL shall be effective.
5	Payment Terms	As per Clause 5.21.3 - No Bills will be passed and processes without valid Time Extension by MD, AEGCL We request AEGCL to remove this condition from the bid	
6	FIRM PRICE	We request AEGCL to allow Variable Price for 160 MVA Transformer considering the lead delivery time offered by various manufacturers and no one is willing to offer FIRM Price	Shall be as per bid document
7	Design Query	As per Bid	Vector group shall be Yna0d1, and the tapping range shall be +10% to -10% of HV variation in the step of 1.25%, 17 steps. Addendum: The voltage class of the new 160MVA transformer to be procured for Salakati GSS shall be 220/132/11kV in line with the existing transformers for safe parallel operation. SPECIAL NOTE: For parallel operation with the existing transformers at Salakati GSS, percentage impedance, OLTC connection and range, vector group and the winding configuration are to be matched. The same shall be determined during detailed engineering.
	Vector Group	YNA0d1	
	Tapping Range and Steps (%)	-10% to +10% @1.25% variation HV	
		Query	
		YNA0d11	
		-5% to 10% of HV variation in the step of 1.25%, 12 Steps	

ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN,

PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

2. The queries raised by M/s Techno Power and the corresponding response of AEGCL are as follows:

Sl. No.	Tender/Clause Description	Bidder's Query	AEGCL's response
1	EMD	Bidder shall furnish a bid security in the amount of Rs. 47,00,000/- (Rupees Forty Seven Lakhs only through online payment) Please allow EMD in form of Bank Guarantee.	Accepted Addendum The ITB Clause 1.4.10.1 is amended to be read as "The Bidder shall furnish as part of its bid, in original form, a Bid Security Bank Guarantee or through online payment mode"
2	Hard Copies to be submitted along with the tender	The bidding is through E-tendering portal and received online. However, bidder has to submit any documents in hard copy if asked by the purchaser. Beneficiary for Opening guarantee What the documents to be submitted in hard copy	Shall be as per clause 1.5.9.2 of the bid document.
3	Qualification of manufacturers as per clause 2.5 of bid document	Qualification of manufacturers of components listed from Item 1 to 17 is asked to provide in the bid. Getting qualification of individual component of transformer item sl no 1 to 13 is very difficult. However we shall provide qualification of transformer manufacturer meeting eligibility criteria kindly allow this.	Manufacturer's make and other details along with warranty certificates, manuals etc. shall be submitted by the OEM.