

ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001 CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3 आज़ादी_{का} अमृत महोत्सव

PHONE: 0361-2739520 Web: www.aegcl.co.in

Corrigendum-III

BID IDENTIFICATION NO: AEGCL/MD/O&M(LAR)/SAS Upgrade Bilasipara GSS/2025/BID

With reference to the above bid document for the work namely "Upgradation/Replacement of existing Substation Automation System at 132KV Bilasipara GSS (receiving end) and at 132KV Kokrajhar GSS (sending end), AEGCL" against Bid Identification No. mentioned above, the following may be noted: -

1. For BoQ item 1.02, bidders are required to submit a quote of zero (0). Any non-zero amount quoted for this item will be excluded from the financial evaluation. Additionally, it is clarified that the integration of existing substation energy meters into the upgraded SCADA system remains part of the bidder's scope of work.

SI No	Item Description	Quantity	Units	BASIC RATE In Figures To be entered by the Bidder	TOTAL AMOUNT Without Taxes
1.02	EMS software for metering for 132KV Bilasipara GSS and 132KV Kokrajhar GSS	2	Nos	0 - 1	0

- 2. The BCUs shall be of the latest firmware version.
- 3. The bidder may provide Single wall mounted panel for Redundant Gateway as per BoQ and bid specification. However, the power supply wirings, Protection Fuses/MCBs and any other Fibre Optic/Communication Network should be completely separate/independent of the Main Gateway.
- 4. The existing ethernet switch shall be used for the work of SAS upgradation at 132KV Bilasipara and 132KV Kokrajhar GSS. The spare ethernet switch shall be used by AEGCL as per site condition on need basis.
- 5. The Frequency of Vulnerability Audit and Penetration Testing shall be as per NCIIPC norms & standards.

All other terms and conditions of the bidding document remain same.

Chief General Manager (O&M), LAR Assam Electricity Grid Corporation Ltd Bijulee Bhawan, Paltanbazar, Guwahati – 01

Memo No. – Note/AEGCL/MD/O&M (LAR)/SAS UPGRADE BILASIPARA GSS/2/January/2025/38 Date :24.10.2025 Copy to:

1. The DGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website. (Soft copy enclosed)

2. Ref. file.

Chief General Manager (O&M), LAR Assam Electricity Grid Corporation Ltd Bijulee Bhawan, Paltanbazar, Guwahati – 1