



# ASSAM ELECTRICITY GRID CORPORATION LIMITED

Regd. Off.: BIJULEE BHAWAN (FIRST FLOOR) PALTANBAZAR; GUWAHATI - 781001  
CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520

Web: [www.aegcl.co.in](http://www.aegcl.co.in)



## Corrigendum-III

**BID IDENTIFICATION NO: AEGCL/MD/Tech-343/O&M(LAR)/2024/Battery Bank/Bid**

With reference to the above bid document for the work namely "Supply, erection and commissioning of battery bank and battery charger at substations under Lower Assam Region in AEGCL" against Bid Identification No. mentioned above, the following technical specification of battery charger may be noted: -

1. Input voltage for 48V chargers shall be 415V AC.
2. The 48V, 110V and 220V chargers shall be of Dual FCBC type which will have output connectivity to single battery bank and load.
3. The ratings of the charger shall be as under:
  - a. 110V DC System: 85A
  - b. 220V DC System: 110A
  - c. 48V DC System: 50A

Moreover, the battery chargers shall be suitable for the new battery banks to be supplied in the aforementioned Bid.

All other terms and conditions of the bidding document remain same.

*mk*  
*22/11/24*

Chief General Manager (O&M), LAR (i/c)  
Assam Electricity Grid Corporation Ltd  
Bijulee Bhawan, Paltanbazar, Guwahati - 01

Memo No. - AEGCL/MD/Tech-343/O&M(LAR)/2024/Battery Bank/II (a-b) Dtd- 22.11.24  
Copy to:

1. The DGM-IT, O/o the MD, AEGCL, for publication of the corrigendum notice in AEGCL website.  
(Soft copy enclosed)
2. Ref. file.

*mk*  
*22/11/24*

Chief General Manager (O&M), LAR (i/c)  
Assam Electricity Grid Corporation Ltd  
Bijulee Bhawan, Paltanbazar, Guwahati - 01