




**Corrigendum**

1. **NIT NO.** AEGCL/DGM/TTC/NLP/T-03/2023-24/44      DTD: 01.12.2023
2. **Name of Work:**
  1. Procurement of 18 Nos. of 33kV LAs for sub-stations under T&T Division, AEGCL, North Lakhimpur.
3. **Technical specification:**  
Rating: 30kV, 10kA, Class-2 Polymer Housed Metal Oxide (Gapless) LA with insulating base.

All other terms and conditions shall remain the same.

  
Deputy General Manager  
T&T Circle, AEGCL  
North Lakhimpur.