

ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE DEPUTY GENERAL MANAGER
UPPER ASSAM T&T CIRCLE, GARMUR, JORHAT-07



TENDER DOCUMENT

Name of work: Construction and installation of Water Supply and Filtration System for GSS and colony residents at 132 kV GSS, AEGCL, Sarupathar

NIT No: **AEGCL/DGM/UATTC/O&M/TC-010/2026/2404, date: 26.06.2026**

BID no: **AEGCL/DGM/UATTC/O&M/TC-010/2026/BID/02**

FUND: O&M,HQ, UAR, FY 2026-27

Tender cost amounting to	Rs. 1000.00
Deposited in the form of	
Vide	

Issued to	
Address	

Signature of Contractor/Firm

Deputy General Manager
UAT&T Circle, AEGCL,
Garmur, Jorhat-07

- (A) **INFORMATION TO BIDDER:**
1. **NAME OF WORK: - Construction and installation of Water Supply and Filtration System for GSS and colony residents at 132 kV GSS, AEGCL, Sarupathar**
 2. **LOCATION OF WORK:- 132kV GSS, AEGCL, Sarupathar**
 3. **TENDER ADDRESS:-Office of the DGM, UATTC, AEGCL, Garmur, Jorhat.**
 4. **BIDDING PROCEDURE:-**
 - a) All tenders shall have to be submitted in prescribed forms attached herewith eventually to be drawn up in the rules of AEGCL.
 - b) Two different envelopes to be used as follows.
Envelope-1: Bid document signed by bidder on all pages, Tender Document cost, Earnest Money, Techno-commercial data of the Bidder and other necessary documents must be enclosed.
Envelope-2: Price Bid
 5. **KEY DATES:-**
 - a) Bid Submission Start Time & date:- **12:00 hrs of 30.06.2026**
 - b) Bid Submission End Time & date:- **12:00 hrs of 20.07.2026**
 - c) Techno-Commercial Bid Opening Time & date:- **12:00hrs of 21.07.2026**
 6. **TENDER VALUE:**
The tender value *inclusive of all taxes* is **Rs.12,65,945.00** only
- TENDER PAPER COST AND MODE OF PAYMENT:-**
Bidder has to pay Non-Refundable tender document cost @**Rs. 1000.00 (Rupees One Thousand)** only in the form of DD in favour of the Managing Director, AEGCL, Bijulee-Bhawan, Paltanbazar, Guwahati-1, payable at Guwahati. The original copy of the DD/Banker's Cheque must be submitted along with relevant documents in the Envelope-1.
7. **BID SECURITY/EARNEST MONEY AND MODE OF PAYMENT:-**
 - a) For participation in bidding procedure, participants must compulsorily pay the Bid Security of **Rs.25,319.00(Rupees Twenty Five Thousand Three Hundred Nineteen)** only in the form of Fixed Deposit/Bank Guarantee/ in favour of the Managing Director, AEGCL, Bijulee-Bhawan, Paltanbazar, Guwahati-1, payable at Guwahati. The original copy of the Bid Security must be submitted along with relevant documents in the Envelope-1.
 - b) The bid security of the successful Bidder shall be returned as promptly as possible once the successful Bidder has signed the Contract and furnished the required performance security.
 - c) The bid security of unsuccessful Bidders shall be returned as promptly as possible upon the successful Bidder's furnishing of the performance security.
 - d) The bid security may be forfeited:-
 - (i) If a Bidder withdraws its bid during the period of bid validity period.
 - (ii) If the successful Bidder fails to sign the Contract within the specified period.
 - e) The successful Bidder shall have to deposit in the form of **"Bank Guarantee/Fixed deposit"** **MANDATORILY** from a Nationalized or scheduled Bank of RBI in AEGCL's standard proforma on non-judicial stamp of appropriate value for an amount equivalent to 10% (ten percent) of the total value of the order including GST as performance security within **15(Fifteen)** days from issue of LOA/WORK ORDER duly pledged in favour of the Purchaser concerned (AEGCL) and such security deposit shall be **valid up 60 days beyond the warranty period..** In case of Abnormally Low Bid the amount to be taken as performance guarantee will be as per bid document.
 8. **VALIDITY OF BID:-**
 - a) Bid shall remain valid for the period of 180 days after the submission deadline date prescribed by AEGCL. In exceptional circumstances, prior to the expiration of the Bid validity period, AEGCL may request Bidders to extend the period of validity of their bids. The request and the responses shall be made in writing.
 9. **TIME OF COMPLETION:-**
 - a) The allotted time of completion for the work is 120 days from the handing over of the site.
 10. **AMENDMENT OF TENDER DOCUMENT: -**
 - a) At any time prior to the deadline for submission of bids, the Employer may amend the Bidding Document by issuing addendum.

- b) To give prospective Bidders reasonable time in which to take an addendum into account in preparing their bids, AEGCL may, at its discretion, extend the deadline for the submission of bids.

11. LANGUAGE OF BID: -

- a) The Bid, as well as all correspondence and documents relating to the bid exchanged by the Bidder and AEGCL, shall be written in the English only.

12. NEGOTIATION WITH BIDDER: -

The AEGCL reserve the right to hold negotiations with lowest bidder if AEGCL feels the quoted rates of particular item(s) are unreasonably high. The bid must be valid, eligible and technically acceptable and considered for award of contract.

13. VERIFICATION OF DOCUMENTS: -

- a) AEGCL reserves the right to verify the documents submitted by the bidders with issuing authority and if any abnormalities are observed in the same, their bids will be rejected.

14. RIGHT TO REJECT: -

- a) The AEGCL reserves the right to reject any or all the bids without assigning any reason thereof and the AEGCL further reserves the right to split up the work order in favour of more than one Contractor. The AEGCL also reserves the right to reject the lowest or any other price without assigning any reason. The clauses which are not appearing in this Bid document will be as per The General Condition of Supply and Erection 2009 of AEGCL. The General Condition of Supply and Erection 2009 of AEGCL is available in the AEGCL's website www.aegcl.co.in

(B) ELIGIBILITY QUALIFICATION:

- i. The Techno-Commercial Evaluation will be done on the basis of technical qualification, financial qualifications and fulfilment of the legal conditions.
- ii. The Price Bid of only Responsive Techno-Commercial Bidders will be opened and intimation will be issued in due course.

1. ELIGIBLE BIDDERS: -

- a) A Bidder may be a person, partnership, private entity or a government-owned entity.
- b) A Bidder, and all partners constituting the Bidder, shall have Indian nationality.
- c) Joint Venture (JV): -
Joint Venture (JV) is not applicable.
- d) Consequently, all Bidders found to have a conflict of interest shall be disqualified. A Bidder may be considered to be in a conflict of interest with one or more parties in this bidding process if, including but not limited to:-
they have controlling partners in common; or
they receive or have received any direct or indirect subsidy from any of them; or
they have the same legal representative for purposes of this bid; or
they have a relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder, or influence the decisions of the Employer regarding this bidding process; or
- e) If a Bidder participates in more than one bid in this bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all Bids in which it is involved.
- f) A Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the plant and services that are the subject of the bid.
- g) A firm that is under a declaration of ineligibility by the AEGCL or any Government Entity or PSU at the date of the deadline for bid submission or thereafter i.e., on or before contract signing date shall be disqualified.
- h) Bidders shall provide such evidence of their continued eligibility satisfactory to the AEGCL, as the Employer shall reasonably request.
- i) In case a prequalification process has been conducted prior to the bidding process, this bidding is open only to prequalified Bidders.
- j) The bidder must have experience of execution of work of similar nature previously. The bidder must submit experience and Performance Certificate for scrutiny by AEGCL.
- k) **A person, Firm or any other prospective bidder who is involved in fraud, unethical practices or barred from submitting bids by AEGCL or any sister concerns of AEGCL i.e., APDCL & APGCL will not be allowed to participate in the bids. If such cases are detected after submission of the bids, in later stages of the bidding process, then such bids will be rejected outright.**

2. LEGAL ENTITY: -

- a) Verification may be undertaken to verify that an applicant is a bona-fide registered company or business. Bidders are required to provide evidence of the legal entity by providing a copy of an official document as mentioned in the appendix attached along with this bid document.

3. TECHNICAL QUALIFICATION: -

- a) Experience having completed similar works during the **last 7 years** ending last day of the month previous to the one in which applications are invited should be either of the following:
 - i. **Three similar completed works** each costing not less than the amount equal to **Rs.5,06,378.00** only.
 - or
 - ii. **Two similar completed works** each costing not less than the amount equal to **Rs.6,32,973.00** only.
 - or
 - iii. **One similar completed work** costing not less than the amount equal to **Rs.10,12,756.00** only.

Note: "Similar work" is defined as work of installation of deep tube well, construction of slow sand filter, installation of distribution pipeline, valves etc for govt Department or PSUs only.

- iv. **If the nature of work and value differs from the above stated conditions, it will not be considered while evaluation of technical qualification.**
- v. **Work orders along with completion certificate are to be attached.**

4. FINANCIAL QUALIFICATION: -

- a) Minimum average annual turnover of **Rs.4,17,762.00** only calculated as total certified payments received for contracts in progress or completed, **within the last 3 (Three) years. (Audited Balance Sheet)**
- b) The Contractor must furnish their **Bank Solvency Certificate indicating the amount by concerned authority in necessary format as per their banks.**

5. PRICE BID EVALUATION PROCESS:

Identification:

- A. The following methodology will be practiced for identification and treatment of the Abnormally Low Bids (ALB) in this tender process of AEGCL:
 - (i) **Absolute Approach** is to be considered when there is fewer than five substantially responsive bidders and if the bid price is 20% or more below AEGCL's cost estimate then AEGCL's tender evaluation committee should clarify the Bid price with the bidder to determine whether the Bid is abnormally low.
 - (ii) **Relative approach** is to be considered when there are at least 5(five) nos. of substantially responsive bids and the lowest bid price is 20% or more below AEGCL's cost estimate.
In this approach, first the Average bid price is determined and then by deducting the standard deviation from the Average bid price, potentially ALB may be determined.
- B. In case of an ALB, the tender evaluation committee/appropriate authority of the respective tenders shall undertake the following three stage review process which is as below:
 - (i) To identify ALB as per the steps mentioned in SI no. 5.A.(i) and 5.A.(ii) whichever is applicable.
 - (ii) To seek and analyse the clarifications from the abnormally low Bidder in terms of resource inputs and pricing, including overheads, contingencies and profit margins. In that respect, the committee may refer to guideline of World Bank, AIIB, ADB etc. prescribed for ALB.
 - (iii) To decide whether to accept or reject the bid.
 - (iv) On acceptance of the bid, whether Additional Performance Security is to be imposed on the bidder supplemented by adequate justification.
- C. **In case of acceptance of ALB with Additional Performance Security:**
 - (i) If any abnormally low bid is accepted under point 5.B.(iii) with additional performance security, it is to be noted that the total performance security should not exceed 20% of the total contract value.
 - (ii) The additional performance security shall be treated as part of the original performance security and shall be valid for a period similar to that applicable for defect liability period of the contract.

1. INSPECTION OF SITE: -

- a) The Bidder is advised to visit and examine the site where the work is to be carried out and its surroundings, nature of work, site conditions, area for storage of materials, etc. and obtain for itself on its own responsibility all information that may be necessary for preparing the bid and entering into a contract. The costs of visiting the site shall be at the Bidder's own expense. Non-familiarity with the site conditions will not be considered a reason either for extra claims or for not carrying out the work in strict conformity with the specifications & requirements.
For site visit and any clarification/information/assistance, the intending Bidder may contact in written to the Office of the DGM, T&T Circle, AEGCL, Garmur, Jorhat.

2. **PREPARATION OF BID: -**

- a) Cost of Bidding:
The Bidder shall bear all costs associated with the preparation and submission of its Bid, and AEGCL shall not be responsible or liable for those costs, regardless of the conduct or outcome of the bidding process.
- b) Documents Establishing Conformity of the Goods and Services: -The documentary evidence of the conformity of the goods and services to the Bidding Document may be in the form of letter, drawings and data, and shall furnish. A detailed description of the essential technical and performance characteristics of the goods and services, including the functional guarantees of the Goods, in response to the specification.
- c) Bidder should note clearly that department should not take any responsibility for issuing of any materials, equipment's and T&P's that may be required in the work.
- d) All materials, labours, equipment's, T&P and heavy vehicle etc. required in the work shall have to be arranged by the bidder/contractor from his own sources in the event of allotment of the said work to him/them.
- e) Water to be used in the work should be clean and free from all impurities; the bidder should note that no water will be provided to them for the execution of the work from the department
- f) The department is also not bound to supply power that may be required in the execution of the work. However, subject to the availability of the power source near the vicinity of the work site, the department on payment of tariff as applicable at the time of execution of work may arrange one point near the work site.
- g) The bidder should clearly understand that all materials to be utilized in the work must confirm to the specifications. No substandard materials will be allowed to utilize in the work. Samples of each and every material to be brought to the site of work shall have to be get approved by the competent authority of the department before use.
- h) The contract must not be sublet under any circumstances. If any contractor found in doing so, his work liable to be terminated.
- i) The specification for the work shall be as per specification laid down in the items of work contained in the enclosed schedule of items of work or as per the APWD schedule of rates for Building (civil works), Sanitary and Water supply and internal electrification respectively (whichever is applicable) but, certain modification in the specification and method of execution of work if required shall have to be carried out which shall be finalized with the contractor bilaterally through discussion

3. **PRICE BID: -**

- a) Unless otherwise specified in the Bid Document and/or AEGCL's Requirements, bidders shall quote for the entire plant and services on a single responsibility basis such that the total bid price covers all the Contractor's obligations mentioned in or to be reasonably inferred from the bidding document in respect of the including procurement, delivery, testing of materials, construction, installation and completion of the Work. The rate should also include the cost of testing of materials at the approved laboratory, carriage and transportation of sample, preparation of report, submission of report in all respect as required by AEGCL. This includes all requirements under the Contractor's responsibilities for completing the work and where so required by the bidding document, the acquisition of all permits, approvals and licenses, etc.; the operation, maintenance and training services and such other items and services as may be specified in the Bidding Document, all in accordance with the requirements of the General Conditions. Items against which no price is entered by the Bidder will not be paid for by the Employer when executed and shall be deemed to be covered by the prices for other items.
- b) Bidders are required to quote the price for the commercial, contractual and technical obligations outlined in the bidding document.
- c) **Bidders quoted price should include all cost of testing of materials, transportation of sample, storage, preparation and submission of report during approval period, construction period as well as after completion of the work.**
- d) Whenever forest produces like sand, stone, timbers etc are used in the work the contractor have to furnish documentary proof that requisite royalty on such produces has been paid to the concerned Department, otherwise will be deducted at source at applicable rate.
- e) Taxes like work contract, income tax etc. which need to be deducted at source as per the prevailing law, will be deducted at source.
- f) The Bided Price should on Fixed Price basis, prices quoted by the Bidder shall be fixed during the Bidder's performance of the contract and not subject to variation on any account.

4. **SITE FACILITIES: -**

- a) AEGCL will not provide any accommodation at the work site to the contractor and their field personnel. No claim shall be entertained from the bidder for making his own arrangement for providing accommodation to the labours and bidder will bear entire expense. The same has to be arranged by the contractor on their own. However, AEGCL may provide space for storage of the materials but responsibility of the material and their safety shall be taken care of by the Contractor. In case of non-availability of space under AEGCL the same should be arranged by the contractor outside AEGCL campus/work site at their own cost and responsibility.
- b) AEGCL shall not be responsible for the safety of the workers at site either on account of the works executed by

- the Contractor or on account of the works executed by any other agency involved at that time.
- c) AEGCL shall on no account be responsible for the expenses incurred by the Contractor during the progress of work at site, towards any incidental expenditure like medical amenities to the workers at site, security arrangements.
 - d) The quoted price shall be deemed to include charges for all site facilities for labour that are considered necessary for execution of the work.
 - e) No claim shall be entertained from the bidder for making his own arrangement for approach roads from outside PWD road to the site and bidder will bear entire expenses.
 - f) AEGCL on no account shall be responsible for storage of materials or loss or pilferage or theft either in respect of the material stored or material already billed and paid for by the AEGCL.
 - g) Any facilities available at site shall be utilized only with prior permission of AEGCL and it should not be taken as granted for availing such services.

5. DEFECT AFTER COMPLETION OF WORK: -

- a) The contractor shall make good at his own cost and to the satisfaction of AEGCL all defects, or other faults which may appear during the defect liability period.
In default, AEGCL may employ and pay other agency or persons to amend and make good such damages. Losses and expenses consequent thereon or incidental thereto shall be made good and borne by the contractor, failing which the same shall be recoverable from the payment due to the contractor and performance guarantee. In the event of amount due and performance guarantee being insufficient, the balance amount will be recovered from the contractor from the amount due or retained for other works executed in AEGCL.

6. VARIATION AND DEVIATION OF QUANTITY: -

- a) The Tendered rates shall hold good for any variations in the Tendered quantities for legitimate completion of works as per original design on account of any modification in the bill of quantities.
- b) **Deletion of work:**
AEGCL and its representative have the right to delete or decrease any item or quantity from schedule of quantity at its discretion if deemed necessary. No claim by the contractor will be admissible for this deletion or deduction of Item/quantity from schedule of quantity.

7. LABOUR LEGISLATION: -

- a) The Bidder shall comply with the provisions of the Apprentices Act 1961, payment of Wages Act 1936, Minimum Wages Act 1948, Employees Liability Act 1938, Workmen's Compensation Act 1923, Industrial Disputes Act 1947, Maternity Benefits Act 1961, and the Contract Labour (Regulation and Abolition) Act 1970, Provident Fund Act or the modifications thereof or any other laws relating thereto and the rules made there under from time to time.
- b) The Bidder shall indemnify and keep indemnified AEGCL against payments to be made under and for the observance of the laws aforesaid and the Contractors' Labour Regulations without prejudice to his right to claim. The laws aforesaid shall be deemed to be a part of this contract and any breach thereof shall be deemed to be a breach of this contract.
- c) The Bidder shall at his own expense arrange for all the safety provisions for the safety of all workers and employees directly or indirectly employed on the work by the Bidder.
- d) The Bidder shall be fully responsible at his own expenses for compliance all the labour regulations and rules to be observed by them. The Bidder shall fully indemnify AEGCL against any action by the state and/or Central Government for any default or alleged default by the Bidder for violation of any of such rules and regulations. If, due to any default of the Bidder, AEGCL has to incur any expenditure for compliance of the rules and regulations or for any other reason connected with such default, AEGCL shall be entitled to recover from the Bidder all such expenditure in full from any payment due to the Bidder.

8. GOVERNMENT AND LOCAL RULES: -

- a) The Contractor shall conform to the provisions of all local bye-laws and acts relating to the work and to the regulations etc. of the Government and Local Authorities and of any Company whose system and design is proposed to be connected/utilized. The cost, if any, shall be deemed to have been included in his quoted rates, taking into account all liabilities and shall indemnify AEGCL against such liabilities and shall defend all actions arising from.

9. ELIGIBILITY OF CONTRACTORS EMPLOYEES: -

- a) The Contractor shall employ in and about the Execution of the works only such persons as are skilled and experienced in their several trades. A list of such personal should be submitted in corresponding Appendix.

10. ENGINEER AT LIBERTY TO OBJECT:-

- a) AEGCL's Site in-charge shall have right to remove any person provided by the Contractor who, in the opinion of the Site in-charge, misconducts himself, or is incompetent or negligent in the proper performance of his duties, or whose presence on Site is otherwise considered by the Engineer to be undesirable, and such person shall not be again allowed upon the Works without consent of the Engineer. Any person so removed from the Works shall be replaced immediately without hampering the work.

11. TAXES: -

- a) Any taxes, royalties and duties as per Govt. Law should be responsible of the contractor and must be included in their quoted rate.

12. INSURANCE: -

- a) The bidder shall arrange for any pay/cost of personnel accident insurance, medical treatment etc. in respect of their employees assigned to the works for all time and shall govern by Law of the land.

13. DAMAGE TO PERSON AND PROPERTY: -

- a) The Contractor shall be responsible for all injury to the work or to workmen, to persons, animals or things and for all damages to the structural and/or decorative part of property which may arise from the operations or neglect of contractor or its employees, against whether such injury or damage arise from carelessness, accident or any other cause whatsoever in any way connected with the carrying out of this Contract. The Contractor shall at his cost effect the insurance necessary and indemnify AEGCL entirely from all responsibility in this respect. The scope of insurance is to include loss or damage to the work and workmen due to carelessness, accident including fire, earthquake, floods, all medical expenses, compensation to be borne in the event of accident etc., damage or loss to the Contract itself till this is made over a complete state. Insurance is compulsory and must be affected from the very initial stage and should cover the entire contract period till handing over of complete works. The Contractor shall also be responsible for anything which may be excluded from damage to any property arising out of incidents, negligence or defective carrying out of this Contract. AEGCL shall be at liberty and is hereby empowered to deduct the amount of any damages, compensations, costs, charges and expenses arising or occurring from or in respect of any such claim for damages from any sums due or to become due to the Contractor.

14. ACCEPTANCE OF BID AND CONTRACT AGREEMENT:-

- a) An agreement shall have to be drawn on non-judicial stamp of appropriate value with AEGCL by the selected Contractor in AEGCL's General Conditions of Supply and Erection 2009 of contract within 15 (fifteen) days from the date of issue of the LOA/NOA.

Wherever there is any variation in between the conditions of AEGCL's General Conditions of Supply and Erection 2009 and the above terms & conditions, this bid conditions will supersede the conditions of AEGCL's General Conditions of Supply and Erection 2009.

15. STATUTORY AND SAFETY REQUIREMENT: -

- a) Each and every safety measure for MAN and MACHINE will be the sole responsibility of the Contractor without any prejudice. Compensation claims if any will also be the responsibility of the contractor without any prejudice.
- b) During the execution of the work, the contractor shall have to mark the site with banner warning/indicating precautions.
- c) The Contractor shall, throughout the execution and completion of the Works and the remedying of any defects therein:
- d) Have full regard for the safety of all persons entitled to be upon the Site and keep the Site (So far as the same is under his control) and the Works in an orderly state appropriate to the avoidance of danger to such persons, and
- e) Provided and maintain at his own cost all lights, guards, fencing, warning signs and watching, when and where necessary or required by the Engineer or by any duly constituted authority for the protection of the Works or for the safety and convenience of the public or others, and Take all reasonable steps to protect the environment on and off the Site and to avoid damage or nuisance to persons or to property of the public or others resulting from pollution, noise or other causes arising as a consequence of his methods.

16. PAYMENT TERMS: -

- a) No advance/Mobilization advance shall be made in this contract.
- b) No claim for interest shall be entertained by AEGCL in respect of any money or balance which may be in AEGCL's hands owing to any dispute or difference or misunderstanding between the contractor and the AEGCL or due to the reason beyond the reasonable control of AEGCL.
- c) First running bill shall be paid to the contractor on 40% completion of the work and Second running bill shall be paid to the contractor on 70% completion of the work.
- d) Final bill must contain the original site register.
- e) Final payment shall be released to the contractor only after completion of the work/final acceptance by AEGCL.
- f) Payment is subject to availability of specific fund.
- g) The Bidder / Firm will have to be submitted the following Net Banking details.
- Banker's Name & Branch
 - Account No
 - Banker's address
 - Banker's IFSC Code
 - Banker's RTGS Code
 -

17. ADDITIONAL WORKS: -

The Contractor shall, when ordered in writing by the concerned authority, perform extra work and furnish extra

materials not required by the invitation or included in the “Bill of Quantities”, but forming an inseparable part of the work concerned. For extra work and, materials will ordinarily be paid for the lump sum or unit price/rates stated in the order. Whenever in the judgement of the concerned authority, it is impractical, because of the nature of the work or for any other reason to otherwise fixed the price/rate in order, the extra work and materials shall be paid for on the basis of actual necessary cost plus overhead and profit allowances as indicated hereunder.

The actual necessary cost will include:

- a) Market value of the materials utilized in the extra work, including taxes and duties, if any.
- b) Actual cost of handling and transportation of materials wherever applicable.
- c) Direct labour charges.
- f) Further supervision charges and profit will be allowed at 10% on the sum. In case any material or parts are furnished by the department no overhead and profit will be allowed on the value of such materials or parts.

18. RETENTION MONEY: -

- a) 10% retention money will be deducted from running bill, which will be released along with the final bill on completion of the work in all respect.

19. WARRANTY: -

- a) The term period of warranty shall mean the period of 18 months from the date of Taking Over of the Work by AEGCL. A Taking over Certificate (TOC) will be issued by the appropriate authority.
- b) The Contractor must handover the warranty card or other relevant documents from the OEM at the time of submission of the bill.

20. SUSPENSION OF WORK: -

- a) If the contractor persistently neglects to carry out his obligations under the contract and/or commits default in complying with any of the terms and conditions of the contract and does not remedy it or take effective steps to remedy it within 7 days after a notice in writing is given to him in that behalf by AEGCL subject to other provisions contained, AEGCL may without prejudice to his any other rights or remedy against the Contractor in respect of any delay in commencing, completing the work may serve notice in writing absolutely determine and cancel the Contract.

21. EXTENSION OF TIME: -

- a) Time is the essence of the contract. No extension of time shall be allowed except on valid reason after pre-approval from competent authority.

22. CHANGE OF NAME OF THE TENDERER: -

- a) At any stage after tendering, AEGCL shall deal with the Contractor only in the name and the address under which he submitted the tender. All the liabilities/ responsibilities for due execution of the contract shall be that of the Contractor.
- b) Any change/ alteration of name/ constitution/ organization of contractor shall be duly notified to the AEGCL and the AEGCL reserves the right to determine the contract, in case of any such notification.

23. DEATH, BANKRUPTCY ETC.: -

If the Contractor becomes bankrupt or being a corporation is in the process of winding up, amalgamation or reorganization, the AEGCL shall be at liberty to:

- i. Terminate the contract forthwith by notice in writing to the Contractor or to the liquidator or receiver or to any person in whom the contract may become vested.
- ii. Give such liquidator, receiver or other person the option of carrying out the contract subject to his providing a guarantee for the due and faithful performance of the contract up to an amount to be determined by the AEGCL.

In case of death of the Contractor before completion of work and supply, the Engineer or AEGCL shall be at liberty to:

- i. Close up the contract and take over the completed portion of work done and made as per specification and make final payment to the legal heir of the Contractor on receipt of claim from such legal heir.
- ii. Give the contract to the legal heir of the Contractor subject to his depositing a performance security for the due and faithful performance of the contract. The performance security amount shall be determined by the AEGCL commensurate with the incomplete portion of the work. The AEGCL will enter into a fresh contract with the legal heir of the Contractor on the same terms and conditions of the earlier contract.

24. CONTRACTUAL FAILURE, LIQUIDATED DAMAGE AND PENALTY: -

- a) Liquidity Damages 0.5% of the amount of delayed work per week subjected to the maximum 10 % of the contract value.

25. TERMINATION OF CONTRACT: -

- a) If the performance of the contract is not satisfactory and not corrected within 15 days of receiving notice, then employer shall be at liberty to terminate the contract and get the work executed through other means at the risk and cost of the Contractor.

26. PAYMENT ON TERMINATION: -

- a) In the event of termination of the contract, AEGCL shall be at liberty to get balance work done by any third

party at the risk and cost of the contractor and due payment of the contractor, if any shall be released after the completion of whole of the works.

27. SUSPENSION OF BUSINESS DEALINGS WITH FIRMS/ CONTRACTORS: -

- a) The AEGCL may suspend business dealings with a Firm/ Contractor, if:-
 - i. The Central Bureau of Investigation or any other investing agency recommends such a course in respect of a case under investigation; and if a prima facie case is made out that the firm is guilty of an offence involving unethical, unlawful, fraudulent means in relation to business dealings, which, if established, would result in business dealings with it being banned.
 - ii. The AEGCL has past record of non-performance of the Firm in its previously awarded contracts.
 - iii. The AEGCL has record of ban against the Firm by other Government /Public sector utility.
- b) However, the AEGCL shall give the Firm/ Contractor a fair chance to explain the circumstances of such previous suspensions.

28. BANNING OF BUSINESS DEALINGS WITH FIRMS/ CONTRACTORS: -

- The AEGCL may ban business dealings with a Firm/ Contractor, if: -
- a) The owner (s) of the Firm/ Contractor is convicted by a court of law following prosecution for offences involving unethical, unlawful, fraudulent means in relation to business dealings.
 - b) There is strong justification that the Firm has been guilty of malpractices such as, bribery, corruption, fraud, substitution of tenders, interpolation, mis-representation, evasion or habitual default in payment of any Government tax etc.
 - c) The Firm continuously refuses to return government dues without showing adequate cause and government are reasonably satisfied that this is not due to reasonable dispute which would attract proceeding in arbitration or court of law.
 - d) The Firm is found guilty of involving in unethical practices, such as:-
 - i. "corrupt practice" involving offering, giving, receiving or soliciting, directly or indirectly, of anything of value to influence the action of any such official/ party in procurement process or in contract execution.
 - ii. "fraudulent practice" involving misrepresentation or omission of facts in order to influence a procurement process or the execution of a contract to the detriment of the Employer.
 - iii. "collusive practice" involving a scheme among bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the Employer of the benefits of free and open competition.
 - iv. "coercive practice" involving harming or threatening to harm directly or indirectly, persons or their property to influence procurement process or the execution of a contract.
- The AEGCL may sanction a Firm/ Contractor or its successor, including declaring ineligible, indefinitely or for a period of not less than 3 (three) years.

29. FORCE MAJEURE CONDITION

30. SETTLEMENT OF DISPUTE AND ARBITRATION: -

31. POLLUTION AND ENVIRONMENT: -

32. ACCEPTANCE AND TAKEOVER: -

- a) When the term of contract shall be fully complied with completing all works as per approved drawing and technical specifications to the satisfaction of the Department for a period as applicable, the Contractor/Firm shall have to submit Performance Certificate to the office of the undersigned after the satisfactory completion of the work through the executing authority for finalization of the work/payment as well as for the final acceptance and taking over the completed work and to issue the necessary certificate thereof.

(C) WORK SCHEDULE:

1. SITE HANDOVER: -

- a) Handing over of the work site will be done in presence of AEGCL Officials of concerned site and contractor or its authorized representative.
- b) The contractor has to submit the list of manpower along with contact numbers to be engaged for the work to the AEGCL Officials.
- c) The date of site handing over to be noted on the Site register duly signed by the AEGCL Officials and contractor or its authorized representative.

2. WORK COMMENCEMENT: -

The work should be started only after having the following documents.

- a) Site Register
- b) Measurement Book
- c) Drawings
- d) Specifications of item & schedule of Quantity
- e) Approved Material

3. SITE REGISTER:-

- a) It will be issued by the department along with the work order.

- b) It will be the responsibility of the Contractor to record and update the site register with details of Day-to-Day activities and other details.
- c) Any instruction by AEGCL officials during site visit must be noted properly and should be jointly signed by the official and the contractor or its authorized representative.
In case of any disagreement, the Contractor must notify AEGCL in written.
- d) Any deviation in works must be properly noted in the site register by the Contractor along with proper justification for it.
- e) Progress report along with work completion percentage must be prepared by the Contractor on the basis of site register log and has to be submitted to AEGCL on 1st and 16th date of the month.
- f) Site register shall be verified from time to time by the Site In-charge and any anomalies found will be forwarded to higher authorities in written by the Site In-charge.

4. WORKING PROCEDURE:

- a) **All materials must be procured only after verification and approved at store by AEGCL or any authorized representative.**
- b) Any materials bought to the site of work without approval from AEGCL, those materials will not be accepted and cannot be used in carrying out the work.
- c) All the work must be carried out as per the directions of AEGCL and no deviation from the directions shall be allowed under any circumstances. In case of inevitable discourse, the contractor must get the deviation approved from the AEGCL.
- d) If any kind of unapproved deviations are observed during the course of the work, the contractor shall have to redo the work as per the direction of AEGCL at the cost of the Contractor.
- e) It shall be the contractor's responsibility to clear any unusable debris/left out materials from the AEGCL campus. No unwanted material can be left unattended by the contractor and the same must be cleared before handing over the site to AEGCL.
- f) The reusable or valuable dismantled materials during the work have to be shifted to a place as decided and directed by the AEGCL.
- g) Since multiple Agencies will be working on the same work site, there should be proper coordination between different contractors involved in the same project or related projects under AEGCL.
- h) The requirement of electricity and water for execution of mentioned work is in scope of the concerned contractor.

5. PERT CHART OR BAR CHART: -

- (A)** The successful bidder within 10 (ten) days before the contract is awarded will make out a detailed PERT Chart covering all activities along with detailed program chart on accepted scheme indicating various stages of execution, method of execution and completion of work in different stages keeping the period of completion in view and submit the same to the Engineer for the consideration and approval

A. GENERAL SPECIFICATION OF WORK:

The work is to be executed as per specifications of the BOQ as provided by AEGCL. Any unauthorised deviation is strictly prohibited and any deviation is to be corrected by the contractor at his own risk and cost.

1. Terms and conditions as laid down in work contract as well as the following clauses, as mentioned hereinafter, will be binding on this contract. Unless specifically mentioned otherwise, all works shall be governed by latest revisions of IS 2800 (Part I):1991 & IS 2800 (Part II): 1997 with respect of workmanship, quality & method of testing.

2. The contractor shall make or repair the approach roads at his own cost, for which no extra amount will be payable to him.

3. The area of operation will be available for use to the contractors till the final yield test of the tube well is carried out. After the completion of the work, the contractor shall remove all plants and machinery including all ancillary structures and shall make good to the extent feasible and reasonable.

4. GENERAL REQUIREMENT:

Selection of site – The site where the Department wants to sink the tube-well should be examined by the driller and, if necessary, a more suitable alternative site should be selected, so that the chances of success of the tube well might be increased. Any previous data available with the drilling agency or Department regarding nearby wells, tube wells or borings made for any other purpose should be made use of to evolve suitable procedure for drilling, developing, testing, etc, of the tube well to be sunk.

5. DRILLING METHODS:

a) **Direct Mud Circulation:** A drill bit is rotated mechanically through a hollow shaft known as drill pipe, circulating prepared drilling mud (usually bentonite with certain chemicals added to give it a gelling quality) under pressure, through the drill pipe. This process of circulation lubricates the bit, carries in suspension the drilled cuttings and also plasters the wall of the hole to prevent it from caving in.

b) **REVERSE CIRCULATION METHOD:** A string of drill pipes with a drill bit at the bottom is rotated by mechanical means. Plain water or a fluid of gelling quality, depending on the strata conditions, is circulated to prevent the hole from caving in and for sucking up the drill cutting through drill pipes. Drilling: The tube well shall be constructed by hydraulic rotary drilling either by reverse circulation rotary drilling method or by direct rotary drilling method. The drill bit size shall be **not less than 200 mm diameter** or of sufficient size to facilitate lowering of the **150 mm diameter MS casing and strainer assembly** with adequate gravel packing. The diameter of the drill bit shall be measured after completion of the drilling work by the Engineer-in-Charge and certified. Drilling shall be carried out **8 to 10 m below the last water-bearing zone or sand formation**. If bentonite is required for drilling, the contractor shall arrange the same at his own cost. The **150 mm diameter MS plain and strainer assembly** shall be lowered up to the required depth. Where hard rock is encountered, drilling shall be continued with suitable rock drilling tools up to the desired depth.

6. DESIGN AND LOWERING OF PIPE ASSEMBLY:

DESIGN OF PIPE SIZES AND LENGTHS – From the data collected about the nature of the aquifers met, the size and lengths of the housing pipe, plain pipes, slotted or perforated pipes or screens, and bail plug are determined. Though it is ideal to have the length of the slotted or perforated pipes or screens exactly equal to thickness of the aquifers being tapped, in practice the actual length of each of the housing pipes, plain pipes and the slotted or perforated pipes or screens can be kept as multiple of the length of the pipes available in the market, provided there is no special difficulty, such as intrusion of water from a saline aquifer and gradation in the texture of formation material.

DESIGN OF SLOTS OR PERFORATIONS: The size of perforations or slots for strainers are so designed that the total opening available is adequate to pass the water in filtering from the aquifer without exceeding the critical velocity. It is recommended that the slots or perforations are milled so that the strength of the pipe is not impaired. Slots should be rectangular in shape in preference to being square or circular and it is desirable that they are tapered with the smaller opening on the outside of the pipes so that the solid particles through the outer lip do not clog it but pass into the pipes. The outer lip should be sharp-edged.

USE OF STRAINERS:

In case of mesh type strainers, the space between the strainer material and the slotted or perforated tube should be such that the total area of the strainer opening is equal to the area of the slots or perforations so that the velocities of flow through the slots or perforations and the strainer opening are equal. The strainer materials and the pipes should be separated by an adequate distance with steel flats or similar contrivance.

- When patented strainers are used, the manufacturer's directions should be followed to obtain the best results.
- The circumferential, longitudinal or spiral seams of the metal casing should be welded in such a manner as to develop strength nearly equal to that of the parent metal. It is preferable to use seamless steel tubes.
- The metal casing should be free from defective material or poor workmanship and should be of standard size. The pipe should be coated both inside and outside with a protective coating of bituminous base material.
- Depending on the sub-stratum formation the tubewell assembly may have to be compound with non-standard length of pipes both for casing tube well pipes and for strainer portion. The contractor will be paid according to the actual length of pipe used in the assembly and lowering in the borehole.
- No extra claim for cutting pipes, welding etc. will be entertained. This should be included in relevant

items of work.

7. GRAVEL PACKING OF TUBE WELL:

All gravel shall consist of hard well-rounded particles reasonably uniform in diameter and shall be of a size determined after analyzing the character of the water bearing formation packed. The thickness (normally a minimum of 100 mm) of the gravel shroud around the screen should be sufficient to ensure that no sand flows into the shroud under normal operating conditions.

8. CEMENT SEALING:

Contractor must do cement sealing with necessary cement slurry the cement sealing should be done in presence engineers in-charge.

9. CLAY PACKING:

After doing cement sealing clay packing must be done with better quality of clay up to the ground level and after that machine should shift from the bore point.

10. DEVELOPMENT OF TUBE WELL:

After the completion of the tubewell the contractor shall have to develop the tube well in the following manners. The well shall be developed either by surging, including washing and agitating, or by pumping and back washing with an air lift. Any other acceptable method may also be adopted. This development process shall be continued until the stabilization of sand and gravel-pack is completely assured.

11. PUMP TEST OR YIELD TEST:

After the development the tube-well starts getting specified quantity of clear and send free water the contractor has to give pumping test as provided in schedule of items and for this purpose he is to pump water from the well continuously for a period of not less than 8 hours at a minimum rate of the guaranteed yield. With all equipments like motor pump, cable, panel, column and all fittings whichever is necessary for pump test.

12. WATER TEST REPORT:

Water shall be collected after completion of boring work and same should be sent for chemically and bacteriologically analysis from NABL Certified Lab, as desired by the Engineer-in-Charge. No extra payment will be made on this account.

13. SPECIFICATION FOR PUMP:

Depending upon the discharge and drawdown noted during the tests, a suitable submersible pump shall be fitted in the tube well or as per the BOQ.

Note: All other specifications shall be as per the approved drawings and as described in the price schedule

PRICE BID

(Rates should be inclusive of GST)

Name of work: Construction and installation of Water Supply and Filtration System for GSS and colony residents at 132 kV GSS, AEGCL, Sarupathar

Annexure-I

Name of Work:- Construction of RCC slow sand water filter unit (36kL) at 132kV GSS, AEGCL, Sarupathar

Sl no	Description of items	Qty	Unit	Rate(Rs)	Amount(Rs)
1	Earth work in excavation by mechanical means (Hydraulic excavator)/ manual means over areas (exceeding 30 cm in depth, 1.5 m in width as well as 10 sqm on plan) including getting out and disposal of excavated earth lead upto 50 m and lift upto 1.5 m, as directed by Engineer-in- charge All kinds of soil	7.97	cum		
2	Brick work with common burnt clay F.P.S. (non modular) bricks of class designation 7.5 in foundation and plinth in: Cement mortar 1:4 (1 cement : 4 coarse sand)	1.13	cum		
3	Providing and laying in position cement concrete of specified grade excluding the cost of centering and shuttering - All work up to plinth level : 1:3:6 (1 Cement : 3 coarse sand (zone-III) derived from natural sources : 6 graded stone aggregate 20 mm nominal size derived from natural sources)	2.68	cum		
4	Random rubble masonry with hard stone in foundation and plinth including levelling up with cement concrete 1:6:12 (1 cement : 6 coarse sand : 12 graded stone aggregate 20 mm nominal size) upto plinth level with : Cement mortar 1:6 (1 cement : 6 coarse sand).	14.18	cum		
5	Making plinth protection 50mm thick of cement concrete 1:3:6 (1 cement : 3 coarse sand (zone-III) derived from natural sources : 6 graded stone aggregate 20 mm nominal size derived from natural sources) over 75mm thick bed of dry brick ballast 40 mm nominal size, well rammed and consolidated and grouted with fine sand, including necessary excavation, levelling & dressing & finishing the top smooth.	10.05	Sqm		
6	Steel reinforcement for R.C.C. work including straightening, cutting, bending, placing in position and binding all complete upto plinth level. Thermo-Mechanically Treated bars of grade Fe-500D or more.	2389.71	Kg		
7	Centering and shuttering including strutting, propping etc. and removal of form for				
7.01	Walls (any thickness) including attached pilasters, butteresses, plinth and string courses etc.	131.80	Sqm		

7.02	Suspended floors, roofs, landings, balconies and access platform	20.00	Sqm		
8	Providing and laying in position specified grade of reinforced cement concrete, excluding the cost of centering, shuttering, finishing and reinforcement - All work up to plinth level : 1:1.5:3 (1 cement : 1.5 coarse sand (zone-III) derived from natural sources : 3 graded stone aggregate 20 mm nominal size derived from natural sources)	2.66	Cum		
9	Reinforced cement concrete work in walls (any thickness), including attached pilasters, buttresses, plinth and string courses, fillets, columns, pillars, piers, abutments, posts and struts etc. above plinth level up to floor five level, excluding cost of centering, shuttering, finishing and reinforcement 1:1.5:3 (1 cement : 1.5 coarse sand(zone-III) derived from natural sources : 3 graded stone aggregate 20 mm nominal size derived from natural sources)	10.59	Cum		
10	Providing and fixing factory made precast RCC perforated drain covers, having concrete of strength not less than M-25, of size 1000 x 450x50 mm, reinforced with 8 mm dia four nos longitudinal & 9 nos cross sectional T.M.T. hoop bars, including providing 50 mm dia perforations sectional T.M.T. hoop bars, including providing 50 mm dia perforations flats of size 50 mm x 1.6 mm complete, all as per direction of Engineer- in-charge.	9.00	Each		
11	CEMENT PLASTER WITH A FLOATING COAT OF NEAT CEMENT Cement plaster 1:3 (1 cement: 3 coarse sand) finished with a floating coat of neat cement.	177.30	Sqm		
12	Providing and applying integral crystalline slurry of hydrophilic in nature for waterproofing treatment to the RCC structures like retaining walls of the basement, water tanks, roof slabs, podiums, reservoir, sewage & water treatment plant, tunnels / subway and bridge deck etc., prepared by mixing in the ratio of 5 : 2 (5 parts integral crystalline slurry : 2 parts water) for vertical surfaces and 3 : 1 (3 parts integral crystalline slurry : 1 part water) for horizontal surfaces and applying the same from negative (internal) side with the help of synthetic fiber brush. The material shall meet the requirements as specified in ACI 212-3R-2010 i.e by reducing permeability of concrete by more than 90% compared with control concrete as per DIN 1048 and resistant to 16 bar hydrostatic pressure on negative side. The crystalline slurry shall be capable of self-healing of cracks up to a width of 0.50mm. The work shall be carried out all complete as per specification and the direction of the engineer-in-charge. The product performance shall carry guarantee for 10 years against any leakage.	42.75	Sqm		
13	Coarse sand (zone III) for filter bed	15.00	Cum		
14	Structural steel work riveted, bolted or welded in built up sections, trusses and framed work, including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer all complete.	141.84	Kg		

15	Providing corrugated G.S. sheet roofing including vertical / curved surface fixed with polymer coated J or L hooks, bolts and nuts 8 mm diameter with bitumen and G.I. limpet washers or with G.I. limpet washers filled with white lead, including a coat of approved steel primer and two coats of approved paint on overlapping of sheets complete (up to any pitch in horizontal/ vertical or curved surfaces),excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required. 12.1.3 0.63 mm thick with zinc coating not less than 275 gm/ m ² .	23.85	Sqm		
16	Providing and laying in position cement concrete of specified grade excluding the cost of centering and shuttering - All work up to plinth level : 4.1.5: 1:3:6 (1 Cement : 3 coarse sand (zone-III) derived from natural sources : 6 graded stone aggregate 20 mm nominal size derived from natural sources)	2.40	cum		
17	Supplying and filling in plinth with sand under floors, including watering, ramming, consolidating and dressing complete.	19.50	cum		
18	Providing and fixing 3 layer PP-R (Poly propylene Random copolymer) pipes conforming to IS:15801 UV stabilized & anti - microbial fusion welded, having thermal stability for hot & cold water supply, including all PP - R plain & brass threaded polypropylene random fittings, including trenching, refilling & testing of joints complete as per direction of Engineer-in-Charge.	17.50	metre		
19	Providing and fixing G.I. pipes complete with G.I. fittings including trenching and refilling etc. External work 18.12.6 50 mm dia nominal bore	25.00	metre		
20	Providing and fixing gun metal gate valve with C.I. wheel of approved quality (screwed end) :	2.00	each		
21	Supplying including installation, connection as approved by the Dep'tt., testing and commissioning of OPENWELL SUBMERSIBLE PUMP SET complete with submersible cable etc. as directed and specified by the deptt. 3 HP Single Phase open well Submersible monoblock water cooled pump set (Crompton Greaves/ Aquatic/ CRI/ V-Guard make) . 220v 50hz, 2900 rpm with control panel.	1.00	Each		

In Words: Rupees.....

Annexure -II

Name of work: **Distribution pipe line and valves for the water supply scheme at 132kV GSS, AEGCL, Sarupathar**

Sl no	Description of item	Qty	Unit	Rate(Rs)	Amount (Rs)
1	Supplying fitting and fixing Pipes with all necessary fittings in exposed or in trenches including trenching and refilling the same etc complete as directed C) CPVC pipe with CPVC fittings (Using SUPREME/ PRINCE/ SFMC/ FUSION brand pipe) vi) 50mm (OD) diameter	450	m		
2/	Bronze/ Gunmetal Full Way Valve (Zoloto or Equivalent) 50 mm	7	each		

In Words: Rupees.....

Total Amount in words (Annexure I +Annexure-II):

Rupees.....
.....

COVERING LETTER (ON THE BIDDERS LETTER HEAD)

To,

The Dy. General Manager,
UAT&T Circle, AEGCL,
Garmur, Jorhat-07

Sub: Submission of Tender.

Ref: -

NIT No: **AEGCL/DGM/UATTC/O&M/TC-010/2026/2404, date: 29.06.2026**

Name of work: Construction and installation of Water Supply and Filtration System for GSS and colony residents at 132 kV GSS, AEGCL, Sarupathar

Sir,

Having examined the terms & conditions, technical specifications, detailed items of work etc. as well as acquainting myself/ourselves with site of work, surroundings to get the required materials etc. I am/we are to submit herewith my/our tender for the above mentioned work. My/our rates are quoted as per the specification laid down in the schedule of items of work.

I /We clearly understand that all materials, tools and plants, machineries, labours, testing of material, storage, haulage etc. required in the work shall have to be arranged by me/us from my/our own resources in the events of allotment of the work to me/us.

I /We also clearly understand that in the event of acceptance/approved of my/our tender, the work shall have to be executed strictly as per specifications and the same shall have to be completed in all respects within the stipulated time failing which I am/We are liable to be penalized as per rules laid down in Tender document as well as agreement thereof.

Signature of Contractor

Appendix-2

PROFILE OF THE BIDDER

Hard copy of the following documents to be submitted with Techno-Commercial Bid.

Sl. No.	Particulars	To be filled by Bidder
a)	Name of the Bidder	:-
b)	Registration with Memorandum of Association	:-
c)	PAN	:-
d)	GST Registration number	:-
e)	EPF	
f)	ESIC	
g)	Labour License registration	:-
h)	Date of Establishment/ Incorporation	:-
i)	Postal Address	:-
	House No.	:-
	Lane	:-
	Street	:-
	Town/Village	:-
	Post Office	:-
	P.S.	:-
	District	:-
	Pin code	:-
j)	Telephone Number	:-
	Mobile No.	:-
	E-Mail Address	:-
	Website	:-
k)	Name(s) of the Owners / Directors/Partners	:-
l)	Name of the Banker with Address and Telephone Number	:-
m)	Contact Person Details <i>(Furnish here name of that person with whom AEGCL may get in touch for more information or clarifications)</i>	Name: - Designation: - Mobile Number: - Email Address:-