



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR, GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

ADDENDUM-II

1. **Bid Identification No.:** AEGCL/MD/Tech-1230/Sarusajai GSS Upg/2026/BID, Dated: 14.08.2026.
2. **IFB No.:** AEGCL/MD/Tech-1230/Sarusajai GSS Upg/2026/IFB, Dated: 14.08.2026.
3. **NIT No.:** AEGCL/MD/ Tech-1230/Sarusajai GSS Upg/2026/NIT, Dated: 14.08.2026.
4. **Work:** "Turnkey Conversion of Existing 220 kV Sarusajai AIS Grid Substation into 220 kV GIS Grid Substation with Provision for Future Upgradation to 400 kV Substation".

With reference to the above mention NIT and Bid Identification,

1. The following clause has been amended:

Sl. No.	Clause of Tender Data Sheet	As Existing	As Amended
1	Bid Volume-II CHAPTER 17: TECHNICAL SPECIFICATION FOR TRANSFORMER Bid Clause No. 17.4.0. SPECIFIC REQUIREMENT (ii) Dynamic Effect of Short Circuit: For 220 kV Class Transformer	For 220 kV Class Transformer: Bidder / Manufacturer should have successfully carried out Dynamic Short Circuit Test on 200 MVA or above rating 220/132 kV Auto transformer as on the originally scheduled date of bid opening and shall enclose the relevant Test Report / Certificate along with bid. In case bidder has not successfully tested 220/132/33 kV, 160 MVA or above rating Auto-transformer for Dynamic Short Circuit Test, their bid shall be considered technically non-responsive. The offered transformer should comply the requirement of similarity clause specified in IS 2026 (PART 5) / IEC 60076-5 with respect to short circuit tested transformer. Further, design review of offered transformer shall be carried out based on the design of short circuit tested transformer.	For 220 kV Class Transformer: Bidder / Manufacturer should have successfully carried out Dynamic Short Circuit Test on 160 MVA or above rating, 220 kV Class Auto transformer as on the originally scheduled date of bid opening and shall enclose the relevant Test Report / Certificate along with bid. In case bidder has not successfully tested 220 kV class, 160 MVA or above rating Auto-transformer for Dynamic Short Circuit Test, their bid shall be considered technically non-responsive. The offered transformer should comply the requirement of similarity clause specified in IS 2026 (PART 5) / IEC 60076-5 with respect to short circuit tested transformer. Further, design review of offered transformer shall be carried out based on the design of short circuit tested transformer.
2	Bid Vol-I, Section IV Bid Clause No. 4.2.1 (c) Manufacturers/Subcontractor	The proposed manufacturers or subcontractors by the tenderer for the following major items of plant and services must meet the minimum qualification criteria as mentioned below: 2. Power Transformers of 220/132KV, or above voltage level	The proposed manufacturers or subcontractors by the tenderer for the following major items of plant and services must meet the minimum qualification criteria as mentioned below: 2. Power/Auto Transformers of 220/132KV, or above voltage level

2. Time for bid submission end date and opening date for the bidding documents referred to the abovementioned works/tenders is extended as detailed below:

Bid Submission End Date: 12:00 Hrs. of 16.10.2026.

Bid Opening Date: 14:00 Hrs. of 17.10.2026.



ASSAM ELECTRICITY GRID CORPORATION LIMITED

OFFICE OF THE MANAGING DIRECTOR

Regd. Office: (FIRST FLOOR), BIJULEE BHAWAN, PALTANBAZAR; GUWAHATI - 781001

CIN: U40101AS2003SGC007238 GSTIN: 18AAFCA4973J9Z3

PHONE: 0361-2739520 Web: www.aegcl.co.in

The above Time Extension-I/Addendum-II shall form an integral part of the above-referred Bid Identification Numbers. Except to the extent expressly stated herein, all other clauses, terms, and conditions of the bid documents shall remain unchanged. Bidders are requested to regularly visit the website <https://assamtenders.gov.in/nicgep/app> to keep themselves updated regarding the above tenders. **Bidders who have already submitted their bids are also requested to suitably modify their bids, if required, in accordance with this Time Extension-I/Addendum-II.**

Sd/-

Chief General Manager, (PP&D)

Assam Electricity Grid Corporation Limited

Memo No. AEGCL/MD/TECH- Tech-1230/Sarusajai GSS Upg/2026/22

Date:28.09.2026

Copy to:

1. PS to the Managing Director, AEGCL for kind appraisal to the MD, AEGCL.
2. The AGM - IT, O/o the MD, AEGCL for publication in the AEGCL's website.

Sd/-

Chief General Manager, (PP&D)

Assam Electricity Grid Corporation Limited